				tural Resources Li JRE VESSEL INF			Job	# 10.113190		
District: GP South				Skid No. 58757						
Facility: Hamburg Water injection Vessel Name & Equipment Number: Free Water Kn				Location (LSD): 13-20-96-09 W6M						
		rice water Kin	ock Out							
Orientation: Hori	zontal									
Status: In Se	rvice			latory Inspection						
			RE VES	SSEL NAMEPLAT						
"A" or "G" or "S" (Sask.) or BC Registration Number. A0435016			CRN Number A 2352.32							
Vessel serial number: 2040 V100				Size: 8 ft x 38 ft approx						
Shell thickness: 31.7 mm				Shell material: SA 516 70N						
Head thickness: 30.7 mm				Head material: SA 516 70N						
Tube wall thickness:				Tube material:						
Tube diameter:			Tube length: Channel material:							
Channel thickness: Shell: 2779 (403 psi)					Shell:					
Design pressure	Tubes:		Operating pressure		Tubes:					
	Shell: 38°C		Operating temperature		Shell:					
Design Temp.	Tubes:				Tubes:					
X-ray: RT-1			Heat treatment: No							
·	SME VIII DIV 1		Joint efficiency (if on nameplate):							
Code parameters: ASME VIII DIV 1 Manufacturer: Plains Oil Ltd.				Year built: 1997						
Corrosion allowance			Manway Yes							
		PRESSURE S	SAFETY	VALVE NAMEP	LATE DATA					
Tag Number(s)	Manufacture	Model		Serial Number	Set Pressure Capacity		,	Set Date		
	Crosby	453110L46/9	91	807-06461	408 psi	2259 gal/min		2009		
CRN#	Serviced by	Block valve		Location	Size	Code Stamp				
	Crosby	No		Inlet piping	4 x 6					
	S	SERVICE CON	DTION	S-INDICATE ALI	L THAT APPL	Y				
Sweet X	Sour			Oil X	Gas X		Water X			
Amine LPG				Condensate	Air		Glycol			
Other (Describe):										
Inspection Interval				PSV Service I	nterval					
(Determined by MIC in co Reports reviewed and	l accepted by:	ector following guide	elines of C							
Mechanical Integrity	y Coordinator				Date_					

External Inspection Items	G	F	P	N/A	Comments
Insulation Verify sealed around manways, nozzles, no damage present, and there is no egress of moisture.	Х				Vessel is 60% insulated. Cladding in good condition. Straps are secure. Wall closure is sealed. No egress of moisture.
External Condition Assess paint condition, areas peeling, record any corrosion, damage, etc (record location, size and depth of corrosion or damage)	Х				Paint is in good condition. No exposed metal. No damage.
Leakage Record any leakage at flanges, threaded joints, weep holes on repads, etc.	X				No leaks found.
Skirt/Saddle Assess condition of paint, fire protection, concrete. Look for corrosion, buckling, dents, etc. Look at vessel surface area near supports. Verify no signs of leakage at attachment to vessel and attachment welds are acceptable. Ground wire attached?	Х				Saddle is bolt to steel structure. No evidence of corrosion at saddle to shell. Paint is in good condition-no exposed metal. No distortion. No buckles. Skid is welded to pilings above ground level. Ground wire is attached to saddle and to skid.
Anchor Bolts Hammer tap to ensure secure. Look for cracking in threads or signs of deformation.	X				Anchor bolts are tight and secured. No sign of deformation.
Concrete foundation Check for cracks etc.				X	
Ladder / Platform Describe general condition, ensure support is secure to vessel, and describe any hazards.				Х	
Nozzle Assess paint, look for leakage, and ensure stud threads are fully engaged. Record any damage, deflection, etc. Are nozzles gusseted?	Х				Threaded nozzle joints are fully engaged. Studs fully engaged to nuts – no short bolts. Nozzles are not gusseted. No damage. No deflections. Paint in good condition – no exposed metal.
Gauges Ensure gauges are visible, working, no leakage, and suitable for range of MAWP/ Temp.	Х				Gauges are visible, working and suitable for range of MAWP.
External Piping Ensure pipe is well supported. All clamps, supports, shoes, etc. in place. Look for evidence of structural overload, deflection, etc. Paint condition, external corrosion?	Х				Paint is in good condition – no exposed metal. Piping is well supported with clamps and supports in place. No structural overloads or deflections noted.
Valving Ensure no leaks are visible. Valves are properly supported and chained if necessary.		Х			All valves are well supported. Liquid seepage at pressure gauge valve.
PSV Ensure PSV is set at pressure at or below that of vessel. Discharge piping is same size as inlet to valve and is properly supported and routed. Ensure no block valves between psv and vessel or if there are they are locked open.	X				Located on inlet piping – removed for service No block valve between vessel and PSV.
NDE methods Was UT/ MPI done on vessel (MI coordinator to review results) Other	X				Ultrasonic corrosion survey carried out – pipe metal thickness detected below nominal minus corrosion allowance. Thickness calculations carried out: 3" Elbow – nominal thickness is 5.5mm / min thickness is 4.1mm / T min thickness is 1.6mm 4" Elbow – nominal thickness is 6.0mm / min thickness is 5.0mm / T min thickness is 1.6mm.
O UIIOI					

Recommendations or corrective actions: Vessel is Fit for Service or describe corrective actions required)

(MIC to review corrective actions with Operations, discuss with Chief Inspector where necessary, and get remedial action implemented)

Recommendations: See Internal Summary
Summary: See Internal Summary
Vessel is fit for service.

Date: June 26, 2013

Demister pad Is it in place? Is it clean? If any corrosion is apparent in vessel, lift pad and check top head for corrosion.	X		Demister pad was found clean and in good condition at the time of inspection.
Welds Inspect all welds, including attachment welds. Record all service-related damages and if there is any discuss with Chief Inspector before closing.	X		Welds were in good condition, no corrosion or mechanical damage at time of inspection.

Recommendations or corrective actions (indicate if fit for service)

Recommendations: 1. Repair valve at pressure gauge. 2. Fill weld isolated pit on manway using an approved CNRL weld procedure.

Summary: Vessel is in overall good condition, visual external inspection, visual internal and ultrasonic corrosion survey performed – Manway metal thickness measured below nominal <u>nearing</u> corrosion allowance. One isolated pit identified at 14 inch manway throat. Nominal 12.7 mm. Measured pit depth to 0.110 inch (2.8 mm) deep. Long term corrosion rate based on greatest thickness loss (manway throat) 0.175 mm per year - Loss from new 2.8 mm. Retirement Date to "T"min is year 2044. Using MAWP of vessel, Maximum allowable working pressure of vessel.

June 27: Pit was further excavated by REED Energy to remove corrosion and blended out to a max depth of 0.350 inch (8.9 mm). Nominal 12.7 mm - 8.9 mm removed = 3.8 mm remaining wall.

June 29: Pit was fill-welded by REED Energy. MT inspection carried out on repair-No cracking detected.

Vessel is fit for service.

Inspected By: Chris Maxsom **Date:** June 26, 2013

Shell Calculation:

P (MAWP of vessel) x R (Inside radius of the vessel or pipe)

S/4 (Tensile Strength of metal/safety factor of 4) x E (Efficiency Factor) – 0.6 x P (MAWP of vessel)

Required Values:

Pressure (MAWP): 403 psi Inside Radius: 6.5 in Tensile Strength: 60000 lbs Efficiency Factor: 1

result: 0.177494545 in result: 4.508361453 mm











