



- NOTES**
- THIS DRAWING IS NOT TO BE USED FOR CONSTRUCTION UNLESS STAMPED 'ISSUED FOR CONSTRUCTION'.
 - ALL DIMENSIONS ARE IN INCHES UNLESS OTHERWISE NOTED.
 - ALL WELDS TO BE 1/4" FILLER UNLESS OTHERWISE NOTED.
 - PAINT AS PER DESIGN SPEC (1) COAT PRIMER (2) COAT ANTI-RUST (3) COAT ANTI-UV (4) COAT ANTI-CORROSION.
 - SURFACE PREP: VESSELS - SSPC-SP6, PIPING - SSPC-SP1.
 - 002-V-22-2022 & -2023 MUST BE REMOVED WHEN MOVING AND/OR SHIPPING THE PACKAGE DUE TO WEIGHT.

MAJOR EQUIPMENT LIST							
TAG NO.	QTY.	DESCRIPTION	LBS.	REV	DESCRIPTION	DATE	OWN
002-K-22-2010/2012	2	COMPRESSOR, COMPAIR L110, 583 SCFM@125 PSIG	11720	7	REVISED AS PER CUSTOMER MARKUPS & REISSUED FOR CONSTRUCTION	14-01-18	HC
002-V-22-2026	1	WET AIR RECEIVER, 680USG, STEEL, FAB TBA	1560	5	ADDED ANOTHER INTAKE LOUVER	13-11-14	PLC
002-T-22-2027	1	DRAIN TANK, 50USG, MPI CHEM-BROW	76	4	REVISED AS PER CUSTOMER MARKUPS & REISSUED FOR CONSTRUCTION	13-10-11	HC
002-V-22-2022	1	DRY AIR RECEIVER, 2580USG, STEEL, FAB TBA	4169	3	REVISED AS PER CUSTOMER MARKUPS & REISSUED FOR CONSTRUCTION	13-09-18	HC
002-V-22-2023	1	START AIR RECEIVER, 6800USG, STEEL, FAB TBA	11500	2	REVISED AS PER CUSTOMER MARKUPS & REISSUED FOR CONSTRUCTION	13-08-23	HC
002-D-22-1000A/B	2	DESICCANT DRYER, NW600-Y	2400	1	REVISED AS PER CUSTOMER MARKUPS & ISSUED FOR CONSTRUCTION	13-08-14	HC
002-FL-22-2014/2015	2	PRE-FILTER, COALESCING, AIRTEK JC0625-C	40	0	ISSUED FOR APPROVAL	13-07-02	PLC
002-FL-22-2020/2021	2	AFTER-FILTER, PARTICULATE, AIRTEK JC0625-F	40	REV	DESCRIPTION	DATE	OWN
002-EFM-22-2082/2083	2	EXHAUST FAN, SOPER/MARATON, 575V/3PH/0.25HP	75				CHK
002-UHM-22-2080/2081	2	C/W BACK DRAFT DAMPER, HOOD & SCREEN	208				
002-UHM-22-2080/2081 BLDG	1	BUILDING, PRE-PAINTED STEEL, GABLE 4:12 SLOPE	12300				
11' EAVE, ICE RAKES, EAVE & DOWNSPOUT			28245				
NW1770SK	1	STRUCTURAL SKID, W18 x 50, 15' x 51'	900				
PIPING, ELECTRICAL & MISC.			73233				
(APPROX.) TOTAL WEIGHT			73233				

GENERAL ARRANGEMENT			
DUPLX COMP/GO L110-125 INSTRUMENT AIR PACKAGE (002-PK-22-1000)			
CLIENT	DEVON CANADA CO WORLEY PARSONS	SCALE	NTS
LOCATION	LIQUID EXTRACTION PLANT, near FERRIER, AB.	DWN BY	PLC
LSD	11-02-038-08 WSM	DATE	13-06-18
	P.O.# 4100001313		
JOB	NW1770-KD	DWG	NW1770GA
		REV	8