

CNR-PVI-14-00014

Criticality Designation

Pressure Vessel Static Information

Insp. Comp: Summit Inspection Services Ltd					District:	Slave Lake						Fiel	d: BRINTNEL	L 1362		
Location: 12-09-081-22W4 BR BATTERY Unit/Skid:						LSD : 12-09-081-22W4										
Jurisdiction #:	A0218208			Α	lt. Jur #:						Εqι	uip Tag	#:			
Serial #:	26978A				CRN#:	C4936.23					Y	ear Bui	lt: 1985			
Manufacturer: Western Rock Bit Co. Ltd.						Equipment Description: LPG STORAGE BULLET										
Status:	In Service		-			Equip Ty	/pe:	Bull	et				Service: S	Sweet		
Shell MAWP:	1723.70	kPa	@	65.5600	С	Volu	me:				bbl	С	ode Stamp:	Yes	0	No
Tube MAWP:		kPa	@	(С	Len	gth:		1	6.66	m		Insulated	Yes	0	No
Shell MDMT:	-20.0000	С		RT: RT2		Diame	ter:			2.74	m	OD	PWHT: () Yes	•	No
Tube MDMT:		С	Supp	ort: Saddle)								Manway:	Yes	0	No
Shell C.A.:	0.00	С	Shell	JE: 1.00		Coa	ted:	0	Yes	•	No		Clad: () Yes	•	No
Tube C.A.:		mm	Tube	JE:		Remote Acc	ess:	0	Yes	•	No					
Dim Text:																
					Data:	Updated										

Corrosion Monitoring Location (CML) Static Information

Side	TML#	Test PT Name	Material	Nom Thick	Diameter	CORR Allow
S	4000	Bottom North Head	SA-516-70	19.61 mm	2743 mm OD	0
S	4005	Top Shell (north of center)	SA-516-70	19.76 mm	2743 mm OD	0
S	4010	Middle West Shell (north of center)	SA-516-70	19.76 mm	2743 mm OD	0
S	4015	Bottom Shell (north end)	SA-516-70	19.76 mm	2743 mm OD	0
S	4020	Bottom South Head	SA-516-70	19.76 mm	2743 mm OD	0
S	4025	Bottom Shell (south end)	SA-516-70	19.76 mm	2743 mm OD	0
S	4030	Bottom South Head	SA-516-70	19.61 mm	2743 mm OD	0
S	4040	4" Inlet Elbow	SA-234-WPB	6.02 mm	114.3 mm OD	1.6 mm
S	4050	2" Inlet Elbow	SA-234-WPB	5.54 mm	60.32 mm OD	1.6 mm
S	4060	3" Outlet Elbow	SA-234-WPB	5.49 mm	88.9 mm OD	1.6 mm
S	4070	2" PSV Elbow	SA-234-WPB	5.54 mm	60.32 mm OD	1.6 mm

Comment:			

Printed On: Mar/19/2015 07:46:10 AM PAGE # 1 Of 12



CNR-PVI-14-00014

Criticality Designation

PSV Static Data

Tag #: PSV-6330 **Serial #:** 561718-1-A10 CRN: 0G8442.5C Capacity: 409 Model No: 26LA10-120/S7-1362228-2 m³/min Set Pressure: 250 psi Manufacturer: Farris Engineering Location of PSV: On Vessel Last Service Date: Conn. Type: Flanged Inlet Size: 3.00 in Inlet Carseal: ● Yes ○ No Inlet Block: ● Yes O No **Outlet Size:** 4.00 in Code Stamp: Outlet Block: O Yes No PSV Side: SHELL Service Comp: Out For Service: O Yes No Comment: Meets code requirements, Last PSV service date is June 2010.

Printed On: Mar/19/2015 07:46:10 AM PAGE # 2 Of 12



CNR-PVI-14-00014

Criticality Designation

External Inspection Results - VE

External Inspection Complete: 2014-08-18

Item	N/A	Condition	Comment	NCR	Action Item Integrity	Action Item Maintenance		
Nameplate		Accept	A# could not be confirmed., covered by insulation.					
Foundation & Supports		Accept						
Anchor Bolts	V							
Grounding		Accept						
Insulation Condition		Accept						
PSV		Reject	No code stamp.	V	$\overline{\checkmark}$	$\overline{\checkmark}$		
Shell Heads & Nozzles		Accept						
Metal Surfaces (Paint)	V							
Aux. Equipment		Accept						
Cathodic Protection	Ø							
Alignment		Accept						
Flange Connections		Accept						
Pressure Gauge		Accept						
Temperature Gauge		Accept						
Sight Glass	V							
Ladder / Platform		Accept						
Leak		No						
Piping From Vessel		Accept						
Previous UT Survey		Pick	Survey Date:	UT Cor	npany:			
External Visual Observat	ions							
Recommendations								

Printed On: Mar/19/2015 07:46:10 AM



CNR-PVI-14-00014

Criticality Designation

NDE and Final Summary NDE Report #: Report #: UT $\sqrt{}$ UT(SW) Performed: Report #: Report #: П PΤ MΤ Report #: Other **Drawing Found? Observations Summary** The A# is not visible, most likely covered by insulation. No ASME code stamp found on the PSV nameplate. UT corrosion survey was performed on the vessel and associated piping. Please see attached copy of report for inspection details. **Recommendations Summary** Contact the PSV manufacturer to confirm ASME code stamp. Expose the A#. **Actions Corrected at Time of Inspection** Additional Visual Observations Any other safety concerns or observations from associated equipment

Printed On: Mar/19/2015 07:46:10 AM PAGE # 4 Of 12



CNR-PVI-14-00014

Criticality Designation

Thickness and Remaining Life Evaluation

MUST BE COMPLETED AND R	ESOL	VED WITH CNRL I	MMEDIATELY U	PON DISCOVERY	OF LOW WALL THIC	KNESS AREAS			
Was any thi	cknes	s measurement lo	cation (Nomina	I WT - Corrosion A	Allowance)?: No				
			Report #:						
Which component(s) were found	d belo	w (Nominal WT - 0	Corrosion Allow	ance)?					
Components below (Nom - CA)			Component	Components below (Nom - CA)					
	-								
	-								
	-								
	-								
	-								
Component Worksheet:									
Component		Low Reading	Calculated T-Min	Reading Below T-Min	Nature Of Pitting	Remaining Life			
Notes:									
Contact CNRL Integrity Coordin	ator to	o discuss above re	esults.						
N	lame C	of CNRL Contact:							
Date and	Time	Of Conversation:							
Summary/Results Of Conversat	ion:								

Printed On: Mar/19/2015 07:46:10 AM PAGE # 5 Of 12



CNR-PVI-14-00014

Criticality Designation

Crack Evaluation by Magnetic Particle or Alternative Inspection

MUST BE COMPLETED AND RESOLVED WITH CNRL IMMEDIATELY UPON DISCOVERY OF CRACK-LIKE INDICATIONS

Were any indications found to suggest the vessel contained cracks? : No

Report #:

Name Of CNRL Contact:

Date and Time Of Conversation:

Summary/Results Of Conversation:

Printed On: Mar/19/2015 07:46:10 AM PAGE # 6 Of 12



CNR-PVI-14-00014

Criticality Designation

CNRL Criticality Evaluation

	YES	NO					
1. Is the vessel fit-for-sevice? :	\checkmark						
2. Was the measured thickness less than the calculated minimum required thickness (T-Min) of any component?:							
3. Were MT indications found?:		$\overline{\checkmark}$					
4. Was the remaining life less than 6 yrs for sour service vessels or less than 10 yrs for sweet service vessels?:							
5. Were NCR's or Action Items generated as a result of the inspection?:							
6. Were UT readings below (Nominal WT - Corrosion Allowance) found?:							
Information on CNRL Owner User Program - Criticality Designation and Required Review							
RED - Vessel Inspection Results are deemed RED if one of the following occurred:							
* The measured thickness was less than the calculated minimum required thickness (T-Min) for any component							
* MT Indications were found							
* The remaining life was calculated to be less than 6 years for sour-service or less than 10 years for sweet-service veseels							
RED inspection reports must be signed off by the CNRL Chief Inspector.							
YELLOW - Vessel Inspection Results are deemed YELLOW if one or more of the following occurred:							
* The vessel was declared NOT fit-for-service by the 3rd Party In-Service PV Inspector							
* NCR's or Action Items were generated as a result of the inspection.							
* UT Readings below (Nominal WT - Corrosion Allowance) were found.							
YELLOW inspection reports must be signed off by the CNRL Pressure Equipment Integrity Coordinator							
GREEN - Vessel Inspection Results are deemed GREEN if <u>all</u> of the following are true:							
* The vessel was declared fit-for-service by the 3rd Party In-Service PV Inspector.							
* UT Readings below (Nominal WT - Corrosion Allowance) were NOT found.							
* MT indications were NOT found.							
* NCR's or Action Items were NOT generated as a result of the VE inspection.							
GREEN Inspection reports must be signed off by the 3rd Party In-Service Pressure Vessel Inspector.							
Criticality Designation							

Printed On: Mar/19/2015 07:46:10 AM PAGE # 7 Of 12




CNR-PVI-14-00014

Criticality Designation

Inspection Photographs and Relevant Files

Title:



Description: Vessel nameplate

Printed On: Mar/19/2015 07:46:10 AM PAGE # 8 Of 12



CNR-PVI-14-00014

Criticality Designation

Inspection Photographs and Relevant Files

Title:



Description: General view of vessel

Printed On: Mar/19/2015 07:46:10 AM




CNR-PVI-14-00014

Criticality Designation

Inspection Photographs and Relevant Files

Title:



Description: PSV nameplate

Printed On: Mar/19/2015 07:46:10 AM PAGE # 10 Of 12



CNR-PVI-14-00014

Criticality Designation

Inspection Photographs and Relevant Files

Title:



Description: General view of PSV

Printed On: Mar/19/2015 07:46:10 AM



CNR-PVI-14-00014

Criticality Designation

Job Information

Vehicle #: Inspector (name): Maria Savulescu

Time In: Time Out: Hrs: PESL #: 000162 API: 24958

Time In: Time Out: Hrs: Inspector (signature):

Personnel 1: Nyssa Moore CNRL Coordinator (name):

Personnel 2: Tyler Cameron CNRL Coordinator (signature):

Billing Info: - CNRL Chief Inspector (signature):

Report ID: CNR-PVI-14-00014-32 Inspector Job Number:

Printed On: Mar/19/2015 07:46:10 AM PAGE # 12 Of 12