



PRV INSPECTION AND TEST REPORT

BRANCH: Fort St John

UVL ID#: 20343F

Work Order: 308260

Customer PO#:

Customer: CANADIAN NATURAL RESOURCES LIMITED
 Facility: SOUTH BUICK LSD: d-035-A/94-A-14
 A#: A534234 Vessel SN:
 Cust. Ref.: FSJ 2460 Valve PO:
 Cust WO#: Cust AFE#:

Date: 4/17/2012
 PSV Location: DISCHARGE
 Cust Id:
 PO Line#: 31001600
 Cost Centre #:

VALVE DATA

Man.: MERCER Model: 91-38G11V13U1S Serial: 195879 Seat: Soft
 Conn: Flanged Inlet: 1.5 " 300 RF Orifice: G Outlet: 2.5 " 150 RF
 Set Pres: 300 PSI Back Press: 0 PSI Cold/Diff Set: PSI Temp: 70°F Cap: 2441 SCFM
 Lift Lever: Cap Assembly: Closed Code Symbol: UV CRN#: 0G8841.5C

CUSTOMER INSTRUCTIONS

Instructions: Pretest, Service, and Test Pretest Required? Reset Required?
 Replaces UVL ID#: Replaces Serial #: Replaces Cust ID#:
 RESET INFO: New Pressure: New Cold/Diff: New Capacity: New Model:

CONDITION AS RECEIVED

Visual Condition: Good Data Plate Condition: OK Date of last service: 12/05
 Seal Condition: Top: Intact Bottom: N/A Insignia: MVC Fittings Attached: Inlet: Outlet:
 Inlet: SCALE/PARTIAL Inlet Plugged: Outlet: RUSTY SCALE/PA Outlet Plugged: Initial Insp. Signoff: Tara Stones

PRETEST 1

Simmer: 322 PSI Set Press: 323 PSI Reseat: 279 PSI Leakage: 0 BPM Test gauge: FSJ 1&2
 Tested by: Harley Anderson Pretest comments:

PRETEST 2

Simmer: PSI Set Press: PSI Reseat: PSI Leakage: BPM Test gauge:
 Tested by: Pretest comments:

ITEM	CLEAN	OILY	RUSTY	CARBON	OTHER	COMMENTS	OK / REPLACE	
							REPLACED?	REPAIRS PERFORMED
DISC	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		OK	<input type="checkbox"/>
NOZZLE	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		OK	<input type="checkbox"/>
CAP-LEVER ASSY	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		OK	<input type="checkbox"/>
COMP SCREW and LOCKNUT	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		OK	<input type="checkbox"/>
SPRING and BUTTONS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		OK	<input type="checkbox"/>
SPINDLE / STEM	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	N/A		<input type="checkbox"/>
STEM RETAINER	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	N/A		<input type="checkbox"/>
DISC HOLDER	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	N/A		<input type="checkbox"/>
GUIDE / UPPER RING	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		OK	<input type="checkbox"/>
LOWER RING	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	N/A		<input type="checkbox"/>
RING PIN(S)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	N/A		<input type="checkbox"/>
BELLOWS	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	N/A		<input type="checkbox"/>
GASKET / SEALS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Worn	REPLACE	<input checked="" type="checkbox"/>
CONNECTION ENDS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		OK	<input type="checkbox"/>
OTHER	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/>

Disc: MIN= ACT= Nozzle: : SOFT ACT= Spring Number: 05-013

Comments:

Disassembly: Brian Gunson Inspection: Brian Gunson Reassembly: Brian Gunson

FINAL TEST:

Test Medium: Air Simmer: 299 PSI Set Pressure: 300 PSI
 Reseat: 253 PSI Leakage Acceptable: B.P. Test: 60 PSI
 ADJ. RING SETTING (NOTCHES): Upper: N/A Lower: N/A Test Gauge FSJ 1&2 Set Press Def: POP
 Tested by: Harley Anderson

FINAL INSPECTION:

SEAL: Top: Bottom: End Protectors Installed: Painted: Palletized: Ship Container: Flex Gaskets Supplied:
 Final Inspection: Tara Stones Customer Inspection
 Comments: ADD A# S.S. TAG