

AFFIDAVIT OF MANUFACTURER

LABOUR

General Safety Services Division Boilers Branch COVERING BOILER OR PRESSURE VESSEL

PURCHASE ORDER No. 77-12-12

As Approved by the Boiler & Pressure Vessel Committee of the C.S.A.

Upon shipment of Boiler or Pressure Vessel this form fully and correctly fillful in and attested to must be mailed to the office of the Chief In-pector in the province of installation in accordance with the regilations under the Act governing the construction and installation of boilers and pressure vessels, otherwise the use of same may be prohibited or the working pressure serverly penalized.

i.	Manufactured by I.P. Constructors Ltd, 1115-46th Avenue S.W., Calgary, Alberta Name and Addges of Manufacturer of Phoenix Construction Holdings Ltd, #523,550-6 Ave. S.W., Calgary
	(Name and Address of Purchaser or Consistent)
	Ultimate owner Amoco Canada Petroleum Co. Ltd., 444-7th Avenue S.W., Calgary
	Location of installation Josephine Gas Plant, Josephine, Alberta
	[This address is essential]
2.	Type of boiler or presoure vessel Inlet Liquids Separator Mfg. Serial No. 77-52
	Provincial Registration No. C-9740.2 Drvig Mo. J 52-01-R2
	To be used for; (Air, Co ₂ , Propane, Ammonia, Steam, Hot Water, etc.) Natural Gas
3.	Dia. 30 " O.D. Overall length 10 "0" s/s Ou. ft. capacity 46.5 Heating surface N/A os. ft.
	Were test reports checked on all plates used in the Education of this baller or pressure vessel? $\frac{\chi_{\text{eS}}}{}$
4.	
	Does all material meet A.S.M.E. Code requirements?
	Does all material meet A.S.M.E. Code requirements/ A-516 Gr. 70 A-506 Gr. B Tensile strength 60,000 PSI ASM.E., A.S.T.M., or other material specification No. A-106 Gr. B Tensile strength 60,000 PSI
	A-105 Gr.II
5.	Fabrication to A.S.M.E. Code, Para. No. 1977 Preheat 250 oF Postheat No. X.R. Complete (Spot or Complete)
	(year) Yes or No.) (year) (year) Yes Postweid heat procedure N/A
	Were X-ray films examined and found to meet Code requirements? Yes

6. Welders employed upon boiler or pressure vessel.

Name of welders and Province or State in which qualified	ldentifying Symbol	Date of last weld test	Qualified for welding under Code Para	Name of Inspector supervising tests	National Board No.
Bill Zacharias	D	10-13-76	UW 12A	Davison	W2140
Stanley Jones	C	7-29-76	UW 12A	Davison	W2959
Daniel E. HIll	E	4-20-77	UW 12A	C. Hendry	4188

Does all welding on this vessel and the sesting of coupons where required meet A.S.M.E. Code requirements? Yes

. Hydrostatic test

and Working Pressures.	NAME OF PART	Temperature of Testing Medium	Final test psi,	Maximum working pressure psi.	Maximum operating temperature degrees F.
	Complete Vessel	70	2130	1420	150
•					

Did the hydrostatic tests fully conform to Code requirements? Yes

- 8. Boiler rating, max-steaming capacity (rated 8.T.U.)hr. output for horwater boilers) ...M A......
- 9. SAFETY VALVES: By Others

No. valve	 Name, Trade or Type No.	Provincial Registration No.	inlet Diameter	Seat Diameter	Sot to relieve at psi.	Free discharge area	Capacity Its, per hour