

Equip. No F Code/Div. ASME VIII, Div 1									
C. Stamp: <u>U</u>	Service: SOUR	PWHT: <u>HT</u>	Radiogr	aphy: <u>RT-1</u>	Insulated: <u>10%</u>				
Design & Materials Data HEAD: Top Mat'l. <u>SA 516 70</u> To	op Nom. <u>21.5mm</u> Top C.A	CLIENT CANAE	DIAN NAIC	ATURAL RES	OURCES LTD				
Btm. Mat'l Btr CHANNFL:	m. Nom Btm. C.A Nominal: C.A	 - FACILITY SOUTH BUICK							
	ad Nom Head C.A			3-1/94-A-					
SHELL	ell Nom Shell C.A Nominal: 22.2mm	 ITEM		R EMULSIOI EPARATOR	N				
MAWP Tube Side:		 BY: LR		DATE: 07/2007	DWG.# 3—1				

CLIENT: CANADIAN NATURAL RESOURCES

EQUIPMENT: SOUR EMULSION SEPARATOR

CRN#: M-9977.231 **PROV REG:** CN 96122

TESTED ON STREAM

FACILITY: SOUTH BUICK COMPRESSOR STATION

SERVICE: SOUR

LOCATION: d-78-l/94-A-11 **RTD JOB #:**05.000082

Test Point	T	HICKNESS DATA	Flag	Crit	C.A.	Nom.	Short Term	Long Term	Ave. mm/py	Flag Date
110										
Description:	BOOT-SHELL									
	2007 3									
Min. Thick.	12.7		0						L	
Average:	12.9						0	0	L	
Analysis:										
115										
Description:	UPPER SHELL									
	2007 3									
Min. Thick.	22.8		22.2			22.2			L	
Average:	22.9						0	0	L	
Analysis:										
120										
Description:	BOTTOM SHELL									
	2007 3									
Min. Thick.	22.5		22.2			22.2			L	
Average:	22.6						0	0	L	
Analysis:										
125										
Description:	LOWER SHELL									
	2007 3									
Min. Thick.	22.5		22.2			22.2			L	
Average:	22.6						0	0	L	
Analysis:										
130										
Description:	LOWER SHELL									
	2007 3									
Min. Thick.	22.7		22.2			22.2			L	
Average:	22.8						0	0	L	
Analysis:										
135										
Description:	LOWER HEAD									
	2007 3									
Min. Thick.	22.2		21.5			21.5			L	
Average:	22.3						0	0	L	
Analysis:										

CLIENT: CANADIAN NATURAL RESOURCES

EQUIPMENT: SOUR EMULSION SEPARATOR

CRN#: M-9977.231 **PROV REG:** CN 96122

TESTED ON STREAM

FACILITY: SOUTH BUICK COMPRESSOR STATION

SERVICE: SOUR

LOCATION: d-78-I/94-A-11 **RTD JOB #:**05.000082

Test Point		THICKNESS DATA	Flag	Crit	C.A.	Nom.	Short Term	Long Term	Ave. mm/py	Flag Date
140										
Description:	2" CIR	CBAND								
	2007	3								
Min. Thick.	10.2		11.1	1.6		11.1			L	2007
Average:	10.4						0	0	L	2007
Analysis:	2007/0	3 CRITICAL THICKNESS CALCULATIONS CARRIED OUT	ΓTO 0.5mm	BUT C	ODE MIN	NIMUM IS	MAINTA	AINED AT	1.6mm	
145										
Description:	2" CIR	CBAND								
	2007	3								
Min. Thick.	10		11.1	1.6		11.1			L	2007
Average:	10.2						0	0	L	2007
Analysis:	2007/03	3 CRITICAL THICKNESS CALCULATIONS CARRIED OUT	ΓTO 0.5mm	BUT C	ODE MIN	NIMUM IS	MAINTA	INED AT	1.6mm	
150										
Description:	2" CIR	CBAND								
	2007	3								
Min. Thick.	10		11.1	1.6		11.1			L	2007
Average:	10.2						0	0	L	2007
Analysis:	2007/03	CRITICAL THICKNESS CALCULATIONS CARRIED OUT	ΓTO 0.5mm	BUT C	ODE MIN	NIMUM IS	MAINTA	INED AT	1.6mm	
155										
Description:	3" 90°	NOZZLE								
·	2007									
Min. Thick.	10.2		11.1	1.6		11.1			L	2007
Average:	10.4						0	0	L	2007
Analysis:	2007/0	3 CRITICAL THICKNESS CALCULATIONS CARRIED OUT	ΓTO 0.5mm	BUT C	ODE MIN	NIMUM IS	MAINTA	INED AT	1.6mm	
160										
Description:	3" 90°	NOZZLE								
·	2007									
Min. Thick.	11		11.1	1.6		11.1			L	2007
Average:	11.8						0	0	L	
Analysis:		B MIN SCAN AT MID APEX. CRITICAL THICKNESS CALC AINED AT 1.6mm	CULATIONS	CARRI	ED OUT	TO 0.5mr	n BUT C	ODE MIN	IIMUM IS	
165										
Description:	3" 90°	NOZZLE								
	2007	3								
Min. Thick.	10		11.1	1.6		11.1			L	2007
Average:	10.7						0	0	L	2007
Analysis:		B MIN SCAN AT MID APEX. CRITICAL THICKNESS CALC AINED AT 1.6mm	CULATIONS	CARRI	ED OUT	TO 0.5mr	n BUT C	ODE MIN	IIMUM IS	

CLIENT: CANADIAN NATURAL RESOURCES

EQUIPMENT: SOUR EMULSION SEPARATOR

CRN#: M-9977.231 **PROV REG:** CN 96122

TESTED ON STREAM

FACILITY: SOUTH BUICK COMPRESSOR STATION

SERVICE: SOUR

LOCATION: d-78-I/94-A-11 **RTD JOB #:**05.000082

Test Point	THICKNESS DATA	Flag	Crit	C.A.	Nom.	Short Term	Long Term	Ave. mm/py	Flag Date
170									
Description:	2" 90° NOZZLE								
	2007 3								
Min. Thick.	9.9	11.1	1.6		11.1			L	2007
Average:	10.6					0	0	L	2007
Analysis:	2007/03 MIN SCAN AT MID APEX. CRITICAL THICKNESS CALCU MAINTAINED AT 1.6mm	ILATIONS	CARRI	ED OUT	TO 0.5mi	m BUT C	ODE MIN	NIMUM IS	

CLIENT: CANADIAN NATURAL RESOURCES

EQUIPMENT: SOUR EMULSION SEPARATOR PIPING

CRN#: PROV REG:

TESTED ON STREAM

FACILITY: SOUTH BUICK COMPRESSOR STATION

SERVICE: SOUR

LOCATION: d-78-I/94-A-11 **RTD JOB #:**05.000082

Test Point	THICKNESS DATA	Flag	Crit	C.A.	Nom.	Short Term	Long Term	Ave. mm/py	Flag Date
105									
Description:	6" 90° ELBOW								
	2007 3								
Min. Thick.	6.4	6.21		.9	7.1			L	
Average:	6.6					0	0	L	
Analysis:									
175									
Description:	3" 90° ELBOW								
	2007 3								
Min. Thick.	5.5	4.81		.7	5.5			L	
Average:	5.6					0	0	L	
Analysis:									
180									
Description:	3" 90° ELBOW								
	2007 3								
Min. Thick.	5.8	4.81		.7	5.5			L	
Average:	5.9					0	0	L	
Analysis:									
185									
Description:	2" 90° ELBOW								
	2007 3								
Min. Thick.	4.9	4.81		.7	5.5			L	
Average:	5.3					0	0	L	
Analysis:	2007/03 MIN SCAN AT MID APEX								
190									
Description:	2" x 2" TEE								
	2007 3								
Min. Thick.	6.8	4.81		.7	5.5			L	
Average:	7.1					0	0	L	
Analysis:									
195									
	6" 90° ELBOW								
	2007 3								
Min. Thick.	6.5	6.21		.9	7.1			L	
Average:	6.7					0	0	L	
Analysis:									