

## PRV INSPECTION AND TEST REPORT

BRANCH: Fort St John UVL ID#: 1049F

307633 Work Order: **Customer PO#:** CANADIAN NATURAL RESOURCES LIMITED Date: 09/20/2011 Customer Facility: **EAST BUICK** LSD: d-17-D/94-A-15 PSV Location: INLET SEPARATOR A#: A0408218 Vessel SN: Cust Id: PV CRN M2318.21 Valve PO: PO LINE#: Cust. Ref.: Cust AFE#: Cost Centre#: 30025600 Cust. WO#: **VALVE DATA FARRIS** 26GA12-120 Serial: CE-312960-2-A10 Seat: POP Man.: Model: Flanged Inlet: 1.5" 300RF Orifice: G Outlet: 2.5" 150RF Conn. 165 PSI Back Press.: 0 PSI Cold/Diff Set Press: Cap: 1716 SCFM Set Press. Temp: Lift Lever Cap Assembly: Closed Code Symbol: UV CRN#: 0G2369.5C **CUSTOMER INSTRUCTIONS** Service from Customer Inventory Instructions: Pretest Required? Reset Required? PV CRN M2318.21 Replaces UVL ID#: 3546F Replaces Valve Serial#: 80C2100 Replaces Valve Cust ID# **RESET INFO:** New Pressure: New Cold/Diff Set: New Capacity: New Model: **CONDITION AS RECEIVED** Visual Condition: Good **Data Plate Condition:** Replace 5/04 Date of last service: **Seal Condition:** Тор: Intact Bottom: Intact Insignia: UVL Fittings Attached: Inlet: Outlet: Inlet: Clean Outlet Plugged: ☐ Initial Insp. Signoff: Inlet Plugged: Outlet: Clean Tara Stones **PRETEST 1** Simmer: Set Press: Reseat: Leakage: Test Gauge: Tested By: **Pretest Comments: PRETEST 2** Set Press: Simmer: Leakage: Test Gauge: Reseat: Tested By: **Pretest Comments: COMPONENTS INSPECTION** OK / ITEM OILY RUSTY CARBON OTHER COMMENTS REPLACED REPLACED? REPAIRS PERFORMED CLEAN DISC Scratched ΟK Lap and Polish  $\sqrt{\phantom{a}}$  $\overline{\mathsf{A}}$ П NOZZLE Scratched OK Lap and Polish  $\overline{\mathbf{M}}$  $\overline{\mathbf{M}}$ **CAP-LEVER ASSY** OK  $\square$ COMP SCREW and LOCKNUT OK П  $\sqrt{\phantom{a}}$ SPRING and BUTTONS REPLACE RESET G0093CR  $\sqrt{\phantom{a}}$  $\square$  $\square$ SPINDLE / STEM OK  $\overline{\mathbf{Q}}$ REPLACE STEM RETAINER 303767X6-010 Damaged  $\square$  $\square$ П  $\overline{\mathbf{M}}$ DISC HOLDER OK  $\square$ **GUIDE / UPPER RING** Damaged **REPLACE** 304182X23-010  $\square$  $\sqrt{\phantom{a}}$  $\overline{\mathbf{M}}$ LOWER RING OK  $\sqrt{\phantom{a}}$ RING PIN(S) ΟK  $\mathbf{\Delta}$ П BELLOWS N/A GASKET / SEALS Crushed REPLACE  $\sqrt{\phantom{a}}$  $\sqrt{\phantom{a}}$  $\sqrt{\phantom{a}}$ CONNECTION ENDS ΩK  $\overline{\mathsf{V}}$ OTHER REPLACE DATA PLATE RESET  $\mathbf{\Delta}$  $\overline{\mathbf{M}}$ DISC: .2096 ACT - .314 NOZZLE: MIN -4.234 ACT -4.329 NUMBER: 2G2017CR Comments: Brian Gunson Brian Gunson Brian Gunson Inspection: Reassembly: Disassembly: **FINAL TEST Test Medium:** Air Simmer: 164 PSI Set Pressure: 165 PSI 154 PSI 10 BPM B.P. Test: 60 PSI Cold/Diff Set: PSI Reseat: Leakage: ADJ. RING SETTING (NOTCHES): POP Upper: N/A Lower: Test Gauge: FSJ 1+2 Set Press Def: Tested by: **FINAL INSPECTION:** 

SEAL: Top: Bottom: End Protectors Installed: Painted: Palletized: Ship Container: Flex Gaskets Supplied:

Final Inspection: Tara Stones Customer Inspection:

Comments: REPLACING UVL# 3546F