



PRV INSPECTION AND TEST REPORT

BRANCH: Fort St John

UVL ID#: 19083F

Work Order: 307578

Customer PO#:

Customer: CANADIAN NATURAL RESOURCES LIMITED
Facility: MILLIGAN
A#: A454495
Cust. Ref.:
Cust. WO#:

LSD: d-31-G/94-H-2
Vessel SN:
Valve PO:
Cust AFE#:

Date: 08/24/2011
PSV Location: SEPARATOR
Cust Id:
PO LINE#:
Cost Centre#: 35000295

VALVE DATA

Man.: FARRIS Model: 26JA13-120 Serial: 4625104-1-A10 Seat: POP
Conn. Flanged Inlet: 2.5" 600 RF Orifice: J Outlet: 4" 150 RF
Set Press. 1440 PSI Back Press.: 0 PSI Cold/Diff Set Press: Temp: Cap: 35956 SCFM
Lift Lever Cap Assembly: Closed Code Symbol: UV CRN#: 0G8442.5C

CUSTOMER INSTRUCTIONS

Instructions: Service from Customer Inventory Pretest Required? [checked] Reset Required? [ ]
Replaces UVL ID#: Replaces Valve Serial#: Replaces Valve Cust ID#
RESET INFO: New Pressure: New Cold/Diff Set: New Capacity: New Model:

CONDITION AS RECEIVED

Visual Condition: Good Data Plate Condition: OK Date of last service: N/A
Seal Condition: Top: Intact Bottom: Intact Insignia: N Fittings Attached: Inlet: [ ] Outlet: [ ]
Inlet: Clean Inlet Plugged: [ ] Outlet: Rusty Outlet Plugged: [ ] Initial Insp. Signoff: Tara Stones

PRETEST 1

Simmer: Set Press: Reseat: Leakage: Test Gauge:
Tested By: Pretest Comments:

PRETEST 2

Simmer: Set Press: Reseat: Leakage: Test Gauge:
Tested By: Pretest Comments:

COMPONENTS INSPECTION

Table with columns: ITEM, CLEAN, OILY, RUSTY, CARBON, OTHER, COMMENTS, OK / REPLACED, REPLACED?, REPAIRS PERFORMED. Rows include DISC, NOZZLE, CAP-LEVER ASSY, COMP SCREW and LOCKNUT, SPRING and BUTTONS, SPINDLE / STEM, STEM RETAINER, DISC HOLDER, GUIDE / UPPER RING, LOWER RING, RING PIN(S), BELLOWS, GASKET / SEALS, CONNECTION ENDS, OTHER.

DISC: Min: .296 ACT - .314 NOZZLE: MIN - 5.187 ACT - 5.302 NUMBER: HG0866CR

Comments:

Disassembly: Brian Gunson Inspection: Brian Gunson Reassembly: BRAD WATSON

FINAL TEST

Test Medium: Air Simmer: 1438 PSI Set Pressure: 1440 PSI
Reseat: 1343 PSI Leakage: 5 BPM B.P. Test: 60 PSI Cold/Diff Set: PSI
ADJ. RING SETTING (NOTCHES): Upper: N/A Lower: -11 Test Gauge: FSJ 1+2 Set Press Def: POP
Tested by:

FINAL INSPECTION:

SEAL: Top: [checked] Bottom: [checked] End Protectors Installed: [checked] Painted: [checked] Palletized: [checked] Ship Container: [ ] Flex Gaskets Supplied: [checked]

Final Inspection: Grant Watson Customer Inspection:

Comments: PREVIOUSLY SET @ 1400 PSI, NEW CAPACITY AS PER SPARTAN ONLINE.