Canadian Natural Resources Limited GENERAL PRESSURE VESSEL INFORMATION Job # 10.112227												
District: Fort St. Jo	hn BC.	Skid No.										
Facility: Milligan C	Location (LSD): d-31-G-94-H-2											
Vessel Name Equipment Number: 3 Phase Horizontal Separator												
Orientation: Horizontal												
Status: In Serv			Decade town In succession									
Status: In Service Regulatory Inspection PRESSURE VESSEL NAMEPLATE DATA												
"A" or "G" o	r "S" (Sask.) or BC R	CRN Number:										
	A0454495	L 7688.213										
Vessel serial number		Size: 48 in. x 15 ft.										
Shell thickness: 57.2		Shell material: SA 516-70N										
Head thickness: 54.9	91mm	Head material: SA 516-70N										
Tube wall thickness:	:	Tube material:										
Tube diameter:				Tube length:								
Channel thickness:	Channel material:											
Design pressure	Shell: 1440 PSI	Operating pressure		Shell:	0 – 2000 PSI							
Besign pressure	Tubes:			Tubes:								
Design Temp.	Shell: 100 Deg F			Operating temperature								
	Tubes:	Shell: 0 – 200 Deg F										
	Tubes.					Tubes	Tubes:					
X-ray: RT 1		Heat treatment: HT										
Code parameters: A		Coated: No										
Manufacturer: Larse		Year built: 2000										
Corrosion allowance	e: 3.2mm	Manway: No										
	Pl	RESSURE SAFETY	VALV	E NAMEPLATE	DATA							
PSV Tag #	Manufacture Model #					essure	Capacity	Service				
						a)	(scfm)	Date				
19083F	Farris	26JA13-120	46	625104-1-A10	1440 PSI		35956	8/2011				
CRN#	Service By	Block Valve		Location	Size		Code Stamp					
	Unified Valve	No		top shell	2.5"x4"		UV					
	SERV	VICE CONDITIONS	S-INDI	CATE ALL THE	AT APPL	Y		<u> </u>				
							I					
Sweet	Sour X Oil					Gas X		Water X				
Amine	LPG			densate X		Air		Glycol				
Other (Describe):												
Inspection IntervalPSV Service Interval												
_	conjunction with Chief Insp	ector following guidelines	of CNR	_		m)						
				1	Č							
Reports reviewed and accepted by: Mechanical Integrity Coordinator												

External Inspection Items	G	F	P	N/A	Comments
	Ü	1	•	1 1/ / 1	
Insulation Verify sealed around manways, nozzles, no damage present, and there is no egress of moisture.				X	Vessel not insulated
External Condition Assess paint condition, areas peeling, record any corrosion, damage, etc (record location, size and depth of corrosion or damage)	X				Paint in good overall condition – No exposed metal.
Leakage Record any leakage at flanges, threaded joints, weep holes on repads, etc.	X				No leaks observed.
Saddle/Skirt Assess condition of paint, fire protection, concrete. Look for corrosion, buckling, dents, etc. Look at vessel surface area near supports. Verify no signs of leakage at attachment to vessel and attachment welds are acceptable. Ground wire attached?	X				Saddle: bolted directly to skid floor. No buckling or dents. No corrosion at attachment welds to vessel. Ground wire attached to skid.
Anchor Bolts Hammer tap to ensure secure. Look for cracking in treads or signs of deformation.	X				Anchor bolts are securely fastened. No deformation.
Concrete foundation Check for cracks, spalling, etc.				X	
Ladder / Platform Describe general condition, ensure support is secure to vessel, describe any hazards.				X	
Nozzle Assess paint, look for leakage, and ensure stud threads are fully engaged. Record any damage, deflection, etc. Are nozzles gusseted?	X				Stud threads are fully engaged No leaks observed. No damage or deflections. Nozzles are not gusseted
Gauges Ensure gauges are visible, working, no leakage, and suitable for range of MAWP/Temp.	X				Clear and clean – no leakage. Suitable for range of MAWP/Temperature. Pressure gauge 0 -2000/temp. gauge 0 -250 Deg F.
External Piping Ensure pipe is well supported. All clamps, supports, shoes, etc. in place. Look for evidence of structural overload, deflection, etc. Paint condition, external corrosion?	X				Piping is well supported – all clamps and supports are in place. No structural overloads or deflections. Paint in good condition.
Valving Ensure no leaks are visible. Valves are properly supported and chained if necessary.	X				No leaks are visible. Valves are supported properly.
PSV Ensure PSV is set at pressure at or below that of vessel.	X				Location: top shell - set at MAWP of vessel. Discharge piping is same size as valve outlet. PSV seal in place – no block valve between vessel and PSV.
NDE methods Was UT/ MPI done on vessel (MI coordinator to review results)	X				Ultrasonic corrosion survey carried out – no metal thickness detected below nominal minus corrosion allowance.

Recommendations or corrective actions: Vessel is Fit for Service or describe corrective actions required) (MIC to review corrective actions with Operations, discuss with Chief Inspector where necessary, and get remedial action implemented)

Recommendations: No recommendations at this time

SUMMARY: Vessel is in overall good condition, visual external inspection and ultrasonic corrosion survey performed – no metal thickness detected below nominal minus corrosion allowance. Thickness calculations carried out to ensure sufficient metal exists for safe operation.

Long term corrosion rate based on greatest thickness loss (head) 0.925mm per year. Retirement Date to "T"min is year 2025. Vessel is fit for service.







Date: September 27, 2012

Data Plate LSD





Overview Saddle bolted to skid floor







PSV



PSV service tag