



LABOUR  
General Safety Services Division  
Boilers and Pressure Vessels Branch

VESSEL (A) : 0216150  
DATE OF INSPECTION : 1990 MAY 02

# Certificate of Inspection

HOME OIL CO. LTD.  
C/O BRENT TROTTIER  
1700, 324-8 AVE SW  
CALGARY, ALBERTA

T2P 2Z5

LOCATION: MISCIBLE FLOOD PROJECT, SWAN HILLS UNIT NO. 1  
COMPANY CODE: V-107

DESCRIPTION: EXPANSION TANK

PREFERRED RE-INSP. INTERVAL: 3.00 YRS  
CRN: F2910.2

MANUFACTURER: DACRO INDUSTRIES LIMITED

SERIAL # : 85-071-1

HEATING SURFACE:

m2

YEAR BUILT: 1985

CUBICAL CAPACITY:

3.040 m3

| PART           | MAX. AUTHORIZED PRESSURE | MAX. TEMP/ MIN. TEMP | ID/LOCATION  | SAFETY VALVES SET/CAPACITY | AT TEMP |
|----------------|--------------------------|----------------------|--------------|----------------------------|---------|
| EXPANSION TANK | 1207 kPa                 | 150 C<br>0 C         | SV1<br>SHELL | 610 kPa<br>18 MM           |         |

### OWNER INSTRUCTIONS/REMARKS:

CERTIFICATE HAS BEEN ISSUED BASED ON SATISFACTORY  
ULTRASONIC THICKNESS READINGS.

INSPECTOR: PLASKITT, DONALD WILLIAM

SIGNATURE: *D. W. Plaskitt*

NOTE: REQUIREMENTS OF THE BOILERS AND PRESSURE VESSELS ACT AND THE REGULATIONS  
ISSUED THEREUNDER:

THE OWNER OR PERSON IN CHARGE SHALL REPORT ALL ACCIDENTS INVOLVING A BOILER, PRESSURE VESSEL OR PRESSURE  
PIPING SYSTEM TO THE DISTRICT INSPECTOR IMMEDIATELY AND SHALL SEND A FULL REPORT IN WRITING TO THE CHIEF  
INSPECTOR AS REQUIRED BY THE ACT. NO REPAIRS OR ALTERATIONS MAY BE MADE UNLESS AUTHORIZED BY AN INSPECTOR.

*File was reviewed in Feb 22/2009  
By R. Anshelkus FAIA.*

*Recommend inspection in 2009  
to see if 2004 coating is OK.*

*Rd. A.*