

VESSEL (A) : 0212592

DATE OF INSPECTION : 1992 JUL 06

Certificate of Inspection

HOME OIL COMPANY LTD
C/O BRENT TROTTLER
1600, 324 8TH AVE S W
CALGARY, AB
T2P 2Z5

LOCATION: SWAN HILLS FLOOD PROJECT
COMPANY CODE: V102
DESCRIPTION: NGL INLET SURGE VESSEL

PREFERRED RE-INSP. INTERVAL: 3.00 YRS
CRN: F2556.2

MANUFACTURER: MALONEY STEEL LTD.
SERIAL # : 84-9148-A
HEATING SURFACE:

YEAR BUILT: 1985
CUBICAL CAPACITY: 13.300 m3

PART ----- MAX. AUTHORIZED MIN. TEMP / ID/LOCATION ----- SAFETY VALVES SET/CAPACITY AT TEMP -----

TANK 10200 kPa 37 C SVL SHELL
0 C

9929 kPa
107 M3M

SIGNATURE: *D. Plaskitt*

INSPECTOR: PLASKITT, DONALD WILLIAM

NOTE: REQUIREMENTS OF THE BOILERS AND PRESSURE VESSELS ACT AND THE REGULATIONS ISSUED THEREUNDER:

THE OWNER OR PERSON IN CHARGE SHALL REPORT ALL ACCIDENTS INVOLVING A BOILER, PRESSURE VESSEL OR PRESSURE PIPING SYSTEM TO THE DISTRICT INSPECTOR IMMEDIATELY AND SHALL SEND A FULL REPORT IN WRITING TO THE CHIEF INSPECTOR AS REQUIRED BY THE ACT. NO REPAIRS OR ALTERATIONS MAY BE MADE UNLESS AUTHORIZED BY AN INSPECTOR.