



PRV INSPECTION AND TEST REPORT

BRANCH: Fort St John

UVL ID#: 4079F

Work Order: 307424

Customer PO#:

Customer: CANADIAN NATURAL RESOURCES LIMITED
 Facility: FLATROCK
 A#: N/A
 Cust. Ref.:
 Cust. WO#:

LSD: 05-02-085-17W6
 Vessel SN:
 Valve PO:
 Cust AFE#:

Date: 06/23/2011
 PSV Location: TREATER
 Cust Id:
 PO LINE#:
 Cost Centre#:

VALVE DATA

Man.: WELLMARK Model: W9503-60N Serial: 69622-1 Seat: POP
 Conn. Threaded Inlet: 3" FNPT Orifice: Outlet: 3" FNPT
 Set Press. 75 PSI Back Press.: PSI Cold/Diff Set Press: Temp: Cap: 3528 SCFM
 Lift Lever Cap Assembly: Closed Code Symbol: UV CRN#: OGO321.23

CUSTOMER INSTRUCTIONS

Instructions: Pretest, Service, and Test Pretest Required? Reset Required?
 Replaces UVL ID#: Replaces Valve Serial#: Replaces Valve Cust ID#
 RESET INFO: New Pressure: New Cold/Diff Set: New Capacity: New Model:

CONDITION AS RECEIVED

Visual Condition: Good Data Plate Condition: OK Date of last service: 6 08
 Seal Condition: Top: Intact Bottom: N/A Insignia: UVL Fittings Attached: Inlet: Outlet:
 Inlet: Rusty Inlet Plugged: Outlet: Rusty Outlet Plugged: Initial Insp. Signoff: Jenna Wolsey

PRETEST 1

Simmer: 74 PSI Set Press: 77 PSI Reseat: 56 PSI Leakage: 5 BPM Test Gauge: FSJ 1+2
 Tested By: Grant Watson Pretest Comments:

PRETEST 2

Simmer: PSI Set Press: PSI Reseat: PSI Leakage: BPM Test Gauge:
 Tested By: Pretest Comments:

COMPONENTS INSPECTION

ITEM						COMMENTS	OK /	REPLACED?	REPAIRS PERFORMED
	CLEAN	OILY	RUSTY	CARBON	OTHER		REPLACED		
DISC	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		OK	<input type="checkbox"/>	
NOZZLE	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		OK	<input type="checkbox"/>	
CAP-LEVER ASSY	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		OK	<input type="checkbox"/>	
COMP SCREW and LOCKNUT	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		OK	<input type="checkbox"/>	
SPRING and BUTTONS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		OK	<input type="checkbox"/>	
SPINDLE / STEM	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	N/A		<input type="checkbox"/>	
STEM RETAINER	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	N/A		<input type="checkbox"/>	
DISC HOLDER	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	N/A		<input type="checkbox"/>	
GUIDE / UPPER RING	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		OK	<input type="checkbox"/>	
LOWER RING	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	N/A		<input type="checkbox"/>	
RING PIN(S)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	N/A		<input type="checkbox"/>	
BELLOWS	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	N/A		<input type="checkbox"/>	
GASKET / SEALS	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Worn	REPLACE	<input checked="" type="checkbox"/>	
CONNECTION ENDS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		OK	<input type="checkbox"/>	
OTHER	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/>	

DISC: : ACT - NOZZLE: MIN - ACT - NUMBER:
 Comments:
 Disassembly: PRAS BARRETTE Inspection: PRAS BARRETTE Reassembly: PRAS BARRETTE

FINAL TEST

Test Medium: Air Simmer: 74 PSI Set Pressure: 75 PSI
 Reseat: 69 PSI Leakage: 0 BPM B.P. Test: 60 PSI Cold/Diff Set: PSI
 ADJ. RING SETTING (NOTCHES): Upper: N/A Lower: N/A Test Gauge: FSJ 1+2 Set Press Def: POP
 Tested by:

FINAL INSPECTION:

SEAL: Top: Bottom: End Protectors Installed: Painted: Palletized: Ship Container: Flex Gaskets Supplied:
 Final Inspection: Jenna Wolsey Customer Inspection:
 Comments: