		Canadian Nat GENERAL PRESSU		esources Limite ESSEL INFORI			Job # 10.11()452	
District: Fort St J	John, B.C.	Skid No.							
Facility: Flat Roc	Location (LSD): 5-2-85-17 W6M								
	ipment Number: Treate	r			,				
Orientation: Hori	*								
Status: In Se				Regulatory	Inspection				
		PRESSURE VES	SEL N						
"A" or "G	" or "S" (Sask.) or BC R	egistration Number.			C	CRN Nun	ıber:		
	A2842374	H1645.231							
Vessel serial num		Size: 6' x 20'							
Shell thickness: 9	9.5mm			Shell material: SA 516 70					
Head thickness:	12.4mm	Head material: SA 106 B							
Tube wall thickne	ess:			Tube material:					
Tube diameter:		Tube length:							
Channel thickness	s:	Channel material:							
	Shell: 75 PSI	Shell: 75 PSI				Shell: 37 PSI			
Design pressure	Tubes:			Operating pressure		Tubes:			
	10000								
Design Temp.	Shell: 200 F	Shell: 200 F				Shell: 120 F			
Design Temp.	Tubes:			Operating Temp.					
X-ray: NIL	14005.	Heat treatment: NIL							
Code parameters:	non code			Coated: N/S					
Manufacturer: Pe		Year built: 1993							
Corrosion allowa	nce: 1.6mm	Manway: Yes							
	P	RESSURE SAFETY	VALV						
PSV Tag #	Manufacture	Model #		Serial #	Set Pre	essure	Capacity	Service	
					(PS	SI)	(scfm)	Date	
4079F	Wellmark	W9503-60N		69622-1	75	5	3528	06-2008	
CRN #	Service By	Block Valve	Location		Size		Code Stamp		
N/S	Unified	No		Top Shell	3" x 3"		UV NB		
	SER	VICE CONDITION	<u> </u> S-INDI	CATE ALL TH	IAT APPL	Y		<u> </u>	
<u> </u>			1						
Sweet	Sour X		Oil	X		Gas X	K	Water X	
Amine	LPG		Cone	densate		Air		Glycol	
Other (Describe):									
Inspection Inter	val			_PSV Service In	nterval				

(Determined by MIC in conjunction with Chief Inspector following guidelines of CNRL's Owner-User Inspection Program) Reports reviewed and accepted by:

Mechanical Integrity Coordinator_

Date Fill out all forms as completely as possible. <u>All information</u> is important! Use back of sheets to record additional information or sketch if required. Copy of report to be filed by MIC at site, and copy sent to Chief Inspector

A2842374

External Inspection Items	G	F	Р	N/A	Comments
	Ŭ	-	-	1 1/ 1 1	
Insulation Verify sealed around manways,					No Insulation present.
nozzles, no damage present, and there is no	Х				
egress of moisture.					
External Condition Assess paint condition,					Paint is in good condition – no exposed metal
areas peeling, record any corrosion, damage,	Х				
etc (record location, size and depth of					
corrosion or damage)					
Leakage Record any leakage at flanges,	X				No leaking detected.
threaded joints, weep holes on repads, etc.					
Saddle/skirt Assess condition of paint, fire					Saddle is in good condition – no buckles or distortion.
protection, and concrete. Look for corrosion,					Paint intact – with little to no corrosion.
buckling, dents, etc. Look at vessel surface	Х				Vessel grounded through the skid package.
area near supports. Verify no signs of leakage					No signs of leakage.
at attachment to vessel and attachment welds					
are acceptable. Ground wire attached?					
Anchor Bolts Hammer tap to ensure secure.	X				Firmly secured.
Look for cracking in treads or signs of					No signs of deformation.
deformation.					
Concrete foundation Check for cracks,				X	None.
spalling, etc.					
Ladder / Platform Describe general					None.
condition, ensure support is secure to vessel,				Х	
and describe any hazards.					
Nozzle Assess paint, look for leakage, and					All threads engaged.
ensure stud threads are fully engaged. Record	X				No deflection – no leaks.
any damage, deflection, etc. Are nozzles					Stud threads fully engaged, no gussets.
gusseted?					Paint is in good overall condition.
Gauges Ensure gauges are visible, working,					Temperature Gauge (0-250F) Suitable for range
no leakage, and suitable for range of MAWP/	Х				Pressure Gauge (0-100 PSI) Suitable for MAWP
Temp.					Clear and clean.
External Piping Ensure pipe is well					Well supported – no deflection – all clamps and shoes in place
supported. All clamps, supports, shoes, etc. in					Piping is painted and is in good overall condition.
place. Look for evidence of structural			Х		Water dump piping spool to fiberglass piping should be replac
overload, deflection, etc. Paint condition,					low of 2.0mm detected on 3" std piping. General corrosion and
external corrosion?					pitting.
Valving Ensure no leaks are visible. Valves					Well supported – no leaks.
are properly supported and chained if	X				i on supported no leaks.
necessary.					
PSV Ensure PSV is set at pressure at or below	+				PSV is set below MAWP of vessel.
that of vessel. Discharge piping is same size as					PSV Discharge piping is equal to inlet piping and is properly
inlet to valve and is properly supported and	Х				supported and routed.
routed. Ensure no block valves between PSV					Car Seals Intact.
and vessel or if there are they are locked open.					Location: Top shell
NDE methods Was UT/ MPI done on vessel					Ultrasonic corrosion survey carried out, metal thickness
(MI coordinator to review results)	X				detected below nominal minus corrosion allowance. On Water
(in coordinator to review results)					dump piping
	<u> </u>	• •			rvice or describe corrective actions required)

Recommendations or corrective actions : Vessel is Fit for Service or describe corrective actions required) (MIC to review corrective actions with Operations, discuss with Chief Inspector where necessary, and get remedial action implemented)

Recommendations: 1) Replace Water Dump spool to fiber glass connection.

Summary: This vessel is in good condition, visual external and ultrasonic thickness inspection carried out – metal thickness detected below nominal minus corrosion allowance on water dump spool *replace. Review UT Survey

Vessel is fit for service.

Inspected By: Dellas Weidman

Internal Inspection Items	G	F	P	N/A	Comments
Coating Assess coating. Describe area coated, general condition of coating.		X			Coating is in fair condition. Some minor failures at manways, shell and nozzles. Surface corrosion to depths of 0.010 inches at failed locations. <u>These coating failures were patched with Davoe #142</u>
Anodes. How many, type, condition. % consumed. Are they being replaced?	X				2 Anodes measuring 42 x 3 inches are installed in Treater. Consumption of approximately 10 %. Existing anodes will be installed.
Internal Piping Is there any? If so, carbon or stainless steel. Describe condition, dents, corrosion, erosion, etc. Ensure supports are secure and any bolts are suitable for future	X				Internal piping is in good condition. No signs of deflection. Well supported.
use. Trays How many? Type of material. Are valves in place? Check for erosion/ corrosion; wear on tray valve legs. Cleanliness?				Х	No trays.
Baffles, deflector plates, etc. If present, describe condition. Look closely at welds attached to vessel wall.	X				Inlet deflector plating is intact. No signs of erosion. No damage or distortion. Coating intact.
South Head Note all corrosion, erosion or mechanical damage. (If vessel is horizontal identify direction of this head)	X				Head is in good condition. No corrosion or no pitting. No signs of damage or distortion.
North Head Note all corrosion, erosion or mechanical damage. (If vessel is horizontal identify direction of this head)	Х				Head is in good condition. No corrosion or no pitting. No signs of damage or distortion.
Shell Sections Record number of shell sections. Record location, size and depth of all erosion, corrosion or mechanical damage. Describe general condition. If any corrosion greater than corrosion allowance is observed in either shell or head, discuss with Chief Inspector before closing vessel.	X				Shell sections are in good condition. No signs of damage or distortion. No signs of erosion or corrosion.
Demister pad Is it in place? Is it clean? If any corrosion is apparent in vessel, lift pad and check top head for corrosion.			X		Dirty and corroded.
Welds Inspect all welds, including attachment welds. Record all service-related damages and f there is any discuss with Chief Inspector before closing.	X				Good condition, no corrosion or pitting.
Repairs Required . If yes, ensure procedure and copy of AB 40 is on file, and one sent to ocal ABSA, and Chief Inspector	X				Patch repairs to coating were carried out.
NDE Was any NDE done. (MI coordinator to review results)				Х	No internal NDE at this time.

Recommendations: Replace demister pad. Plan for possible complete coating of vessel next outage. Summary: This vessel is in good overall condition, visual internal carried out. **Vessel is fit for service**



Overview

Water Dump Line



Overview

Overview















Fire Tube

Typical Anode – 10 % loss