



**CUSTOMER:** CNRL **FACILITY:** Dubamel **LSD:** 04-07-045-21W4M  
**P & ID:** \_\_\_\_\_ **DRAWN BY:** RD **DATE:** 5/23/12 **DRAWING NO.:** 156825-20-13

**VESSEL DESCRIPTION:** Level Bridge  
 Equip. No. \_\_\_\_\_ Pro.Reg.No. (A) C51189 C.R.N. \_\_\_\_\_ Serial No. \_\_\_\_\_ Yr. Inst. \_\_\_\_\_  
 Code/Div. \_\_\_\_\_ Size: 6" ID/OD \_\_\_\_\_ Manufacturer: \_\_\_\_\_ Yr. Blt. \_\_\_\_\_  
 C. Stamp \_\_\_\_\_ Service: \_\_\_\_\_ PWHT: \_\_\_\_\_ J.E.: \_\_\_\_\_ Radiography: \_\_\_\_\_ Insulated: \_\_\_\_\_

**HEAD** **SHELL:**  
 Top Mat'l \_\_\_\_\_ Top Nom. \_\_\_\_\_ Top C.A. \_\_\_\_\_ Material Plate Nominal \_\_\_\_\_ C.A. \_\_\_\_\_  
 Btm Mat'l \_\_\_\_\_ Btm Nom. \_\_\_\_\_ Btm C.A. \_\_\_\_\_ MDMT \_\_\_\_\_ @Temp \_\_\_\_\_

**BOOT** **CHANNEL:**  
 Head Mat'l \_\_\_\_\_ Head Nom. \_\_\_\_\_ Head C.A. \_\_\_\_\_ Top Mat'l \_\_\_\_\_ Top Nom. \_\_\_\_\_ Top C.A. \_\_\_\_\_  
 Shell Mat'l \_\_\_\_\_ Shell Nom. \_\_\_\_\_ Shell C.A. \_\_\_\_\_ Btm Mat'l \_\_\_\_\_ Btm Nom. \_\_\_\_\_ Btm C.A. \_\_\_\_\_  
 MAWP Shell side: \_\_\_\_\_ @ Temp. \_\_\_\_\_ MAWP Tube side: \_\_\_\_\_ @ Temp. \_\_\_\_\_

**PIPING INFORMATION:**  
 Circuit. No. \_\_\_\_\_ Line No. (s) **(PLEASE PUT LINE NUMBERS ON APPLICABLE LINES ON THE DRAWING)**  
 Piping Class \_\_\_\_\_ Service: \_\_\_\_\_ Yr. Blt. \_\_\_\_\_  
 MAWP: \_\_\_\_\_ @ Temp. \_\_\_\_\_ Size & Schedule of Piping **(PLEASE PUT APPROPRIATE SIZES AND SCHEDULES OF PIPING ON DRAWING)**

C51189 UT Readings  
Readings in Inches

	SOB	EOB	MIN
LOC 5	0.441	0.437	0.435
LOC 10	0.446	0.449	0.444
LOC 15	0.433	0.452	0.427
LOC 20	0.516	0.408	0.375