



CUSTOMER: CURL FACILITY: 04-07 Duhamel Battery LSD: 04-07-045-21W4M  
 P & ID: \_\_\_\_\_ DRAWN BY: KK DATE: 05-23-12 DRAWING NO. 156225-KK-16

VESSEL DESCRIPTION: Treater  
 Equip. No. \_\_\_\_\_ Pro.Reg.No. (A) A0220737 C.R.N. F2429.213 Serial No. HT-4662 Yr. Inst. \_\_\_\_\_  
 Code/Div. \_\_\_\_\_ Size: 48" ID/OD X 18' Manufacturer: Lowland D Amico Yr. Blt. 1985  
 C. Stamp \_\_\_\_\_ Service: Sour PWHT: HT J.E.: \_\_\_\_\_ Radiography: \_\_\_\_\_ Insulated: YOS

HEAD SHELL:  
 Top Mat'l 516-70 Top Nom. 4.8 Top C.A. - Material SA36 Nominal 61 C.A. -  
 Btm Mat'l 516-70 Btm Nom. 11.8 Btm C.A. - MDMT \_\_\_\_\_ @Temp \_\_\_\_\_

BOOT CHANNEL:  
 Head Mat'l \_\_\_\_\_ Head Nom. \_\_\_\_\_ Head C.A. \_\_\_\_\_ Top Mat'l \_\_\_\_\_ Top Nom. \_\_\_\_\_ Top C.A. \_\_\_\_\_  
 Shell Mat'l \_\_\_\_\_ Shell Nom. \_\_\_\_\_ Shell C.A. \_\_\_\_\_ Btm Mat'l \_\_\_\_\_ Btm Nom. \_\_\_\_\_ Btm C.A. \_\_\_\_\_  
 MAWP Shell side: 50psi @ Temp. 200°F MAWP Tube side: \_\_\_\_\_ @ Temp. \_\_\_\_\_

PIPING INFORMATION:  
 Circuit. No. \_\_\_\_\_ Line No. (s) (PLEASE PUT LINE NUMBERS ON APPLICABLE LINES ON THE DRAWING)  
 Piping Class \_\_\_\_\_ Service: \_\_\_\_\_ Yr. Blt. \_\_\_\_\_  
 MAWP: \_\_\_\_\_ @ Temp. \_\_\_\_\_ Size & Schedule of Piping (PLEASE PUT APPROPRIATE SIZES AND SCHEDULES OF PIPING ON DRAWING)

A0220737 UT Readings  
Readings in Inches

	SOB	EOB	MIN
LOC 5	0.361	0.396	40.250
LOC 10	0.317	0.340	0.282
LOC 15	0.265	0.271	0.265
LOC 20	0.274	0.274	0.271
LOC 25	0.258	0.256	0.238
LOC 30	0.213	0.211	0.208
LOC 35	0.200	0.204	0.196
LOC 40	0.223	0.210	0.201
LOC 45	0.232	0.217	0.203