



**PRESSURE VESSEL
VISUAL INSPECTION
REPORT**

Report #: **156825-KK-16**
 Inspect Date: 05/23/2012
 Page: 1 of 21
 Insp. Co. Job #: 156825

Criticality Designation:



Insp. Comp: Matrix_Inspection District: St Albert - South Field: Duhamel
 Location: 04-07 Battery Unit / Skid #: N/A LSD: 04-07-045-21W4M
 Jurisdiction #: A0220737 Equip Tag #: N/A Serial #: HT-4662
 CRN #: F2429.213 Nat'l Bd #: N/A Year Built: 1985
 Manufacturer: Larson & D'amico Equipment Description: Other: Treater
 Status: Out of Service - 999 - Standby Equip. Type: Vessel: Treater Service: Sour
 MAWP Shell: 50 Psi @ 200 °F Volume: N/A Code Stamp: Y N
 MAWP Tube: N/A @ N/A Height/Length: N/A Insulated: Y N
 MDMT: _____ RT: _____ Size/Diameter.: 48 in. O.D. PWHT: Y N
 Support Saddle Vessel on Original CNRL Inventory List: Y N Manway: Y N
 C.A.: N/A Coated: No Clad: No J.E.: N/A Remote Access: - _____

Component	Material	Nominal Thk	Diameter	OD/ID	Tube Side	Shell Side
1 Main - Shell	SA 36	6.100 mm	48.000 in.	OD	<input type="checkbox"/>	<input checked="" type="checkbox"/>
2 East - Head	SA 516-70	4.800 mm	48.000 in.	OD	<input type="checkbox"/>	<input checked="" type="checkbox"/>
3 West - Head	SA 516-70	4.870 mm	48.000 in.	OD	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4 -					<input type="checkbox"/>	<input type="checkbox"/>
5 -					<input type="checkbox"/>	<input type="checkbox"/>

Static Data: Confirmed Changed (See Comments)

Comments:

Data not provided from MaxiTrack prior to inspections.
 Confirm data before overwriting database.
 Limited data available from data plate.

PSV Static Data

PSV -1 Tag #: E10155 Serial #: 10086*660 CRN: OG1316.2C
 Model #: T-8200-2 Capacity: 474 SCFM Set Pressure: 50 psi
 Manufacturer: Taylor Service Company: POWELL
 Inlet Size & Type: 2.00 in. - Threaded Last Service Date: 05-23-2012
 Outlet Size & Type: 2.00 in. - Threaded Block Valve: N/A - -
 Carseal Intact: Yes Code Stamp: Yes
 Shell Side / Tube Side: Shell Side Out for Service During Insp.: Y Location of PSV: On Vessel

PSV -2 Tag #: N/A Serial #: N/A CRN: N/A
 Model #: N/A Capacity: N/A Set Pressure: _____
 Manufacturer: N/A Service Company: N/A
 Inlet Size & Type: _____ Last Service Date: N/A
 Outlet Size & Type: _____ Block Valve: _____
 Carseal Intact: _____ Code Stamp: _____
 Shell Side / Tube Side: _____ Out for Service During Insp.: _____ Location of PSV: _____

PSV Comments

PSV was removed during the external visual inspection and UT corrosion survey.
 PSV data was provided at a later date for updating reports with current service data.



**PRESSURE VESSEL
VISUAL INSPECTION
REPORT**

Report #: **156825-KK-16**
 Inspect Date: 05/23/2012
 Page: 2 of 21
 Insp. Co. Job #: 156825

Insp. Company: Matrix Inspection LSD: 04-07-045-21W4M Jurisdiction #: A0220737

External Inspection Results – VE External Inspection Performed

Item	N/A	Condition	Comment (Check Status Bar or Press F1 for Help)	NCR	Action Item Integrity	Action Item Maintenance
Nameplate	<input type="checkbox"/>	Accept	secure and legible	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Foundation and Supports	<input type="checkbox"/>	Accept	Secure and level	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Anchor Bolts	<input type="checkbox"/>	Accept	secure and level	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Grounding	<input type="checkbox"/>	Accept	grounded through building	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Insulation Condition	<input type="checkbox"/>	Accept	good condition	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PSV	<input checked="" type="checkbox"/>		PSV removed for service at time of inspection	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Shell Heads & Nozzles	<input type="checkbox"/>	Accept	good condition	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Metal Surfaces (Paint)	<input type="checkbox"/>	Accept	isolated mild surface corrosion and scale	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Aux Equipment	<input type="checkbox"/>	Accept	good condition	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Cathodic Protection	<input checked="" type="checkbox"/>		not applicable	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alignment	<input type="checkbox"/>	Accept	good alignment	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Flange Connections	<input type="checkbox"/>	Accept	proper bolt engagement	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Pressure Gauge	<input type="checkbox"/>	Accept	clear and legible	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Temperature Gauge	<input type="checkbox"/>	Accept	clear and legible	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Sight Glass	<input type="checkbox"/>	Accept	clear and clean	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ladder / Platform	<input checked="" type="checkbox"/>		no ladders or platforms attached	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Leaks	<input type="checkbox"/>	No	no leaks noted	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Piping from Vessel	<input type="checkbox"/>	Accept	isolated surface corrosion and flaking paint			
Previous UT Survey	<input type="checkbox"/>	Yes	evidence of previous survey	UT Company: unknown		

External Visual Observations

This vessel is not in service at the time of inspection. A "dirty" inspection was performed to determine if equipment is worthy to relocate and inspect thoroughly.

Nameplate is secure and easy to read, and contains adequate information.

The vessel is secure and level, with properly aligned piping and external attachments.

The paint is in fair condition, with scale and minor surface corrosion noted.

The paint is thick and rough in some locations.

The attached piping is in good condition with isolated areas of surface corrosion.

The vessel piping to wall and vessel to roof interface is in fair condition, and could use minor sealant repairs.

The PSV is removed for service at the time of the inspection.

The plumbing for the PSV appears to be in good condition, and of adequate size and proper rating.

The PSV service data has been supplied from the service company to update the static information in this report.

The overall condition of this vessel is good.

A UT corrosion survey was performed at the time of the inspection by IRISNDT using DMS2 SN 020448.

Typical locations on the vessel heads, shell, and attachments were selected for the UT survey.

No thickness values of concern were noted during the UT survey.

See attached UT values and drawing for complete details.

Recommendations:

Continue to perform regular maintenance and regulatory inspections to maintain equipment integrity and continued safe operation. Monitor the vessel and piping paint and building conditions.

Ensure PSV's are serviced, installed, and rated correctly before putting this equipment back into service post TAR.



**PRESSURE VESSEL
VISUAL INSPECTION
REPORT**

Report #: **156825-KK-16**
 Inspect Date: 05/23/2012
 Page: 3 of 21
 Insp. Co. Job #: 156825

Insp. Company: Matrix Inspection LSD: 04-07-045-21W4M Jurisdiction #: A0220737

Internal Inspection Results – VI Internal Inspection Performed

Item	N/A	Condition	Comment (Check Status Bar or Press F1 for Help)	NCR	Action Item Integrity	Action Item Maintenance
Shell	<input type="checkbox"/>	Accept	good condition	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Heads	<input type="checkbox"/>	Accept	good condition	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Manway	<input type="checkbox"/>	Reject	coating damage	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Gasket Surfaces	<input type="checkbox"/>	Reject	coating damage at flange faces	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Welds	<input type="checkbox"/>	Accept	good condition	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Refractory	<input checked="" type="checkbox"/>		no refractory	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Heating Coils	<input checked="" type="checkbox"/>		no heating coil	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Demister Pad	<input checked="" type="checkbox"/>		no demister	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Vane Pack	<input checked="" type="checkbox"/>		no vanes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Baffles	<input type="checkbox"/>		good condition	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Trays	<input checked="" type="checkbox"/>		no trays	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter	<input type="checkbox"/>	Reject	drain filters plugged	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Internal Coating	<input type="checkbox"/>	Reject	coating damage at manways	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Tubesheet	<input type="checkbox"/>	Accept	good condition	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Tube Bundle	<input type="checkbox"/>	Accept	good condition	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Internal Visual Observations

This vessel is not in service at the time of inspection.
 A "dirty" inspection was performed to determine if equipment is worthy to relocate and inspect thoroughly.
 Multiple areas of coating failure noted on the shell and manway openings.
 Superficial coating damage noted on the internal supports.
 No active corrosion was noted on the supports where the coating had failed.
 The firetube support structure has similar superficial coating failure.

The inlet diverter was not disassembled and limited the inspection.

The inlet diverter, and weirs are in overall good condition.
 The bottom drain filters are plugged solid.
 The anodes are in good condition.

Recommendations:

Perform an installation inspection once this vessel is relocated or determined to be put back into service.
 Replace the drain filters.
 Repair coating damage on the shell and manway throats.



**PRESSURE VESSEL
VISUAL INSPECTION
REPORT**

Report #: **156825-KK-16**
 Inspect Date: 05/23/2012
 Page: 4 of 21
 Insp. Co. Job #: 156825

Insp. Company: Matrix Inspection LSD: 04-07-045-21W4M Jurisdiction #: A0220737

Firetube Static Data Firetube Inspection Performed

Diameter: _____ Nom Thickness: _____ Bend: _____
 Length: _____ Firetube Description: _____
 Firetube NDE UT Report#: included ET Report#: _____
 Performed: MT Report#: included RT Report#: _____
 PT Report#: _____ Other Report#: _____

Firetube Inspection Results

Item	N/A	Condition	Comment (Check Status Bar or Press F1 for Help)	NCR	Action Item Integrity	Action Item Maintenance
Burner	<input type="checkbox"/>	Accept	good condition	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Stack	<input type="checkbox"/>	Accept	good condition	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Flange (Throat)	<input type="checkbox"/>	Accept	coating damage noted	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tube Sheet	<input type="checkbox"/>	Accept	good condition	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Hot Side	<input type="checkbox"/>	Accept	good condition	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Miter	<input type="checkbox"/>	Accept	good condition	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Return Bend	<input type="checkbox"/>	Accept	good condition	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Supports	<input type="checkbox"/>	Accept	superficial coating damage noted	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Butt Welds	<input type="checkbox"/>	Accept	good condition	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Fillet Welds	<input type="checkbox"/>	Accept	good condition	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Firetube Visual Observations

There is mild product scale noted along top dead center of the hot side of the firetubes.

A magnetic particle (black on white) inspection was performed on all accessible welds using IRISNDT yoke SN 40225. All locations were inspected to the full access of the equipment and inspector. No indications were noted at the time of the inspection.

A UT corrosion survey was performed on the tubes at the time of the inspection by IRISNDT using DMS2 SN 020448. Typical locations on the tube (as applicable) were selected for the UT survey. Some mild erosion losses (up to 0.025") were noted throughout the tube. Nominal Thickness 0.375"
 No thickness values of concern were noted during the UT survey.
 See attached UT values and drawing for complete details.

Recommendations:

Perform an installation inspection once this vessel is relocated or determined to be put back into service.
 Replace the drain filters.
 Repair coating damage on the shell and manway throats.



PRESSURE VESSEL
VISUAL INSPECTION
REPORT

Report #: **156825-KK-16**
Inspect Date: 05/23/2012
Page: 5 of 21
Insp. Co. Job #: 156825

Insp. Company: Matrix Inspection LSD: 04-07-045-21W4M Jurisdiction #: A0220737

Vessel NDE and Final Summary:

NDE Performed: UT Report#: Included ET Report#: _____
MT Report#: included RT Report#: _____
PT Report#: _____ Other Report#: _____

Maxi-Trak Observations Summary (Summarize inspection results Max 255 Characters):

Coating damage noted at manway openings. Drain filters plugged. Overall vessel is in good condition.

Maxi-Trak Recommendations Summary (Summarize Recommendations Max 255 Characters):

Repair coating damage as required. Perform an installation inspection before this vessel is put into service.

Actions Corrected at Time of Inspection: (If actions were corrected at the time of Inspection – note the corrected actions here.)

None required.

Additional Visual Observations

Overall site conditions are very good.
It is clear that operations and maintenance staff take pride in the plant, and maintain a tidy and clean workplace.

Any other safety concerns or observations from associated equipment: (for example associated piping, buildings, pumps etc...)

None noted



PRESSURE VESSEL
VISUAL INSPECTION
REPORT

Report #: 156825-KK-16
Inspect Date: 05/23/2012
Page: 6 of 21
Insp. Co. Job #: 156825

Insp. Company: Matrix Inspection LSD: 04-07-045-21W4M Jurisdiction #: A0220737

Thickness and Remaining Life Evaluation “ Must be Completed ”

MUST BE COMPLETED AND RESOLVED WITH CNRL IMMEDIATELY UPON DISCOVERY OF LOW WALL THICKNESS AREAS

Step 1: Was any thickness measurement location found to be less than (Nominal WT – Corrosion Allowance)?: **No**

If YES, proceed to Step 2; if NO, proceed to “Crack Evaluation” and “CNRL Criticality Designation”.

Step 2: Which component(s) were found below (Nominal WT – Corrosion Allowance)?

Components found below Nom - CA:

Components
N/A - N/A
N/A - N/A
N/A - N/A
N/A - N/A
N/A - N/A

Perform Steps 3 – 8 for each component with actual thickness less than (Nominal WT – Corrosion Allowance).

Step 3: Describe Location and Extent of Corrosion:

Components	Location and Extent of Corrosion
N/A - N/A	Not Applicable for this Inspection
N/A - N/A	Not Applicable for this Inspection
N/A - N/A	Not Applicable for this Inspection
N/A - N/A	Not Applicable for this Inspection
N/A - N/A	Not Applicable for this Inspection

Notes:
Not Applicable for this Inspection

Step 4:

- For shells and nozzles, calculate minimum required thickness (T-min) as per ASME Section VIII UG-27.
- For heads, calculate minimum required thickness (T-min) as per ASME Section VIII UG-32.

Components	T-Min
N/A - N/A	N/A
N/A - N/A	N/A
N/A - N/A	N/A
N/A - N/A	N/A
N/A - N/A	N/A



PRESSURE VESSEL
VISUAL INSPECTION
REPORT

Report #: **156825-KK-16**
Inspect Date: 05/23/2012
Page: 7 of 21
Insp. Co. Job #: 156825

Insp. Company: Matrix Inspection LSD: 04-07-045-21W4M Jurisdiction #: A0220737

Thickness and Remaining Life Evaluation (Continued)

Step 5: Is any measured thickness less than calculated minimum required thickness (T-min)? **N/A**

*If YES, complete Step 6
If NO, proceed to Step 7..*

Step 6: Is nature and extent of pitting acceptable as per API 510? **N/A**

Step 7: Calculate Remaining Life as per API 510. How? (Find last reading; use nominal thickness if nothing available). Short Term Corrosion Rates and Long Term Corrosion Rates.

Components	Remaining Life (Yrs)
N/A - N/A	N/A
N/A - N/A	N/A
N/A - N/A	N/A
N/A - N/A	N/A
N/A - N/A	N/A

Step 8: Contact CNRL Integrity Coordinator to discuss above results.

- Name of CNRL contact: Not Applicable for this Inspection
- Date and time of conversation: Not Applicable for this Inspection

Summary/results of conversation:
Not Applicable for this Inspection

Crack Evaluation by Magnetic Particle or Alternative Inspection “Must be Completed”

MUST BE COMPLETED AND RESOLVED WITH CNRL IMMEDIATELY UPON DISCOVERY OF CRACK-LIKE INDICATIONS

Were any indications found to suggest the vessel contained cracks? **N/A**

If NO, proceed to “CNRL Criticality Designation”.

If YES, Contact CNRL Integrity Coordinator to discuss results.

- Name of CNRL contact: Not Applicable for this Inspection
- Date and time of conversation: Not Applicable for this Inspection

Summary/results of conversation:
Not Applicable for this Inspection



**PRESSURE VESSEL
VISUAL INSPECTION
REPORT**

Report #: **156825-KK-16**
 Inspect Date: 05/23/2012
 Page: 8 of 21
 Insp. Co. Job #: 156825

Insp. Company: Matrix Inspection LSD: 04-07-045-21W4M Jurisdiction #: A0220737

CNRL Criticality Evaluation – “MUST BE COMPLETED”

The CNRL In-Service Pressure Vessel Inspector MUST answer all the following questions

1. Is the vessel fit-for-service? : **Yes**
2. Was the measured thickness less than the calculated minimum required thickness (T-min) for any component?: **No**
3. Were MT indications found?: **N/A**
4. Was the remaining life less than 6 years for sour service vessels or less than 10 years for sweet service vessels?: **No**
5. Were NCR's or Action Items generated as a result of the inspection? : **No**
6. Were UT readings below (Nominal WT – Corrosion Allowance) found? : **No**

Information on CNRL Owner User Program - Criticality Designation and Required Review

RED – Vessel Inspection Results are deemed RED if one of the following occurred:

- The measured thickness was less than the calculated minimum required thickness (T-min) for any component.
- MT indications were found.
- The remaining life was calculated to be less than 6 years for sour-service vessels or less than 10 years for sweet-service vessels.

RED inspection reports must be signed off by the CNRL Chief Inspector.

YELLOW – Vessel Inspection Results are deemed YELLOW if one or more of the following occurred:

- The vessel was declared NOT fit-for-service by the 3rd Party In-Service PV Inspector.
- NCR's or Action Items were generated as a result of the inspection.
- UT readings below (Nominal WT – Corrosion Allowance) were found.

YELLOW inspection reports must be signed off by the CNRL Pressure Equipment Integrity Coordinator.

GREEN – Vessel Inspection Results are deemed GREEN if all of the following are true:

- The vessel was declared fit-for-service by the 3rd Party In-Service PV Inspector.
- UT readings below (Nominal WT – Corrosion Allowance) were NOT found.
- MT indications were NOT found.
- NCR's or Action Items were NOT generated as a result of the VE inspection.

GREEN inspection reports must be signed off by the 3rd Party In-Service Pressure Vessel Inspector.

Criticality Designation



Vehicle #: _____ Kms: _____
 Time In: 00:00 Time Out: 00:00 Hrs _____
 Time In: 00:00 Time Out: 00:00 Hrs _____
 Personnel: _____
 Billing Info: _____

Inspector (Name): Kris Katryniuk PESL: N/A
 Inspector (Signature): _____
Inspector Signature
06/30/2010 08:43:20 am
 API: 510-35238
 CNRL Coordinator (Name): _____
 CNRL Coordinator (Signature): _____
Coordinator Signature
06/30/2010 08:44:03 am
 CNRL Chief Inspector (Signature): _____
 (I am in full agreement with report contents)
Chief Inspector Signature
06/30/2010 08:45:29 am
 (I am in full agreement with report contents)

Equipment Photographs:



01-A0220737 Data Plate



02-A0220737 Overview Inside



03-A0220737 Overview Outside



04-A0220737 Vessel to Wall Interface



05-A0220737 Manway Opening



06-A0220737 Firetube Support Coating Damage



07-A0220737 Firetube Support Coating Damage



08-A0220737 Anode Condition



09-A0220737 Internal Overview



10-A0220737 Drain Filter Plugged



11-A0220737 Internal Overview



12-A0220737 Coating Damage at Manway



13-A0220737 Coating Chips on Flange



14-A0220737 Side Manway Coating Chips



15-A0220737 Firetube Overview



16-A0220737 Firetube Hot Side Scale



PRESSURE VESSEL
VISUAL INSPECTION
REPORT

Report #: 156825-KK-16
Inspect Date: 05/23/2012
Page: 17 of 21
Insp. Co. Job #: 156825



MAGNETIC PARTICLE
INSPECTION REPORT

156825-MT-01
Page 1 of 1

Procedures: MT-1V Black on White

Code: Client information

Job / P.O. #:

IRISNDT #: 156807

Date: 01-May-

Client: CNRL

Location: 04-07-045-21W4M Duhamel Battery

Item Inspected: A0202737 Treater firetube welds

Surface Condition: Painted Sandblasted Machined As Cast As Forged
Weldment Other

Magnetizing Equipment: Yoke Coil Prod Bench: Headshot
 Central Conductor Coil

IRISNDT #: 40225

Mfg: Contour Probe

Calibration Date: 25-Apr-

Blacklight:

IRISNDT #:

Mfg:

Calibration Date: -Jan-03

Whitelight:

Battery Powered Min. 3V

Held within 30cm (12in) of the inspection surface

110V Power Min. 60W Bulb

Held within 30cm (12in) of the inspection surface

Method of Magnetization:

AC DC Continuous Residual

Magnetic Particles: Dry Wet

Red Grey Black Fluorescent

Batch #: 10203

Mfg: Magnaflux

Type: 7C & Water

Background:

Batch #: 1048

Mfg: Ardrex

Type: 8901W

Scope:

As per client request a Black on white magnetic particle inspection was carried out on Treater A0220737 firetube welds.

Results:

No indications were noted during the inspection.

Inspection Limitation(s): None

Unit #:	Kilometers:		Consumables:	Interpretation by:	SNT-TC-1A II
In: See	Out: Time	Hrs: Sheet	White contrast	Rodney Charchuk	C.G.S.B. II
In:	Out:	Hrs:	7C and Water		C.G.S.B. # 8996
Personnel:				_____ (Signature)	
Kris Katryniuk				I am in full agreement with report contents:	
Rodney Charchuk				Client Representative: _____	

5908 – 96 Street Edmonton, Alberta T6E 3G3 Ph. (780) 437-2022 Fax. (780) 436-4873	Barrhead (780) 674-3018 Fort McMurray (780) 743-1536 Grande Prairie (780) 532-2283 Rainbow Lake (780) 956-4094	Lloydminster (780) 875-6455 Cold Lake (780) 594-1114 Red Deer (403) 347-1742 Tulsa, OK (918) 446-8773	5442 – 56 Avenue S.E. Calgary, Alberta T2C 4M6 Ph. (403) 279-6121 Fax. (403) 236-0716
--	---	--	--

Procedures: BW-1A
Thickness/Lamination
Code: Client Information

Job / P.O. #: IRISNDT #: 156825 **Date:** 23-May-12
Client: CNRL
Location: 04-07-045-21W4M Duhamel Battery
Item Inspected: Vessel UT Thickness survey on Treater A0220737 Firetube

Material: Carbon Steel **Surface Condition:** Buffed **Heat Treatment:** Not Applicable

Equipment: GE DMS2 **Mfg. S/N:** 020448 **Calibration Date:** 22-Mar-12

Calibration Block(s): IIW <input type="checkbox"/> Other <input checked="" type="checkbox"/> Step Wedge	Transducer: S/N Angle	022XTY			
		0			
		7.5			
Test Piece: 1/2" Step Wedge 4027	Frequency (MHz)	0.312"			
Cable Type: dual Length: 30"	Crystal Size				

Dis. AMPL. Calibration: Not Applicable **Couplant:** Exosen 30 **Batch #:** 1023

Transfer Loss Calibration: Direct Comparison: Other: **TL:** +3 db

Reference Flaw Size: Backwall **Primary Reference Level:** 82% **Reference Gain:** 56 db

Lamination **Shear Wave** **Volumetric** **Thickness** **Scan Methods:** Contact
Immersion

Inspection Results:

Per client request perform a UT thickness survey on Treater A0220737 Firetube.


See attached pages for UT thickness survey locations and thickness values.

No readings of concern were recorded during the inspection.

Inspection Limitation(s): None

<p>Unit#: _____ Kilometers: _____</p> <p>In: <u>see</u> Out: <u>time</u> Hrs: <u>sheet</u></p> <p>In: _____ Out: _____ Hrs: _____</p> <p>Personnel:</p> <p>Kris Katryniuk Justin Dittrick</p>	<p>Consumables:</p>	<p>Interpretation by: <u>Kris Katryniuk</u> SNT-TC-1A <u>II</u></p> <p>_____ C.G.S.B. <u>II</u></p> <p>(Print) _____ (Level)</p> <p>_____ C.G.S.B. # <u>12095</u></p> <p>_____ (Signature)</p> <p>Client Representative: _____</p> <p>(Print)</p> <p>I am in full agreement with report contents _____</p> <p>(Sign) _____</p>
---	---------------------	--

5311 – 86 Street Edmonton, Alberta, T6E 5T8 Phone: (780) 437-2022 Fax: (780) 438-1436			
Calgary (403) 279-6121	Cold Lake (780) 594-1114	Corpus Christi, TX (361) 888-4700	
Lloydminster (780) 875-6455	Fort McMurray (780) 743-1536	Deer Park, TX (281) 476-4444	
Barrhead (780) 674-3018	High Level (780) 956-4094	Matrix, Houston, TX (713) 722-7177	
Nisku (780) 955-7616	Red Deer (403) 347-1742	Texas City, TX (490) 945-2262	
	Medicine Hat (403) 427-6284	Tulsa, OK (918) 446-8773	



CUSTOMER: CURL FACILITY: 04-07 Duhamel Battery LSD: 04-07-045-21W4M
 P & ID: _____ DRAWN BY: KK DATE: 05-23-12 DRAWING NO. 156225-KK-16

VESSEL DESCRIPTION: Treater
 Equip. No. _____ Pro.Reg.No. (A) A0220737 C.R.N. F2429.213 Serial No. HT-4662 Yr. Inst. _____
 Code/Div. _____ Size: 48" ID/OD X 18' Manufacturer: Lowland D Amico Yr. Blt. 1985
 C. Stamp _____ Service: Sour PWHT: HT J.E.: _____ Radiography: _____ Insulated: YOS


HEAD SHELL:
 Top Mat'l 516-70 Top Nom. 4.8 Top C.A. - Material SA36 Nominal 61 C.A. -
 Btm Mat'l 516-70 Btm Nom. 11.8 Btm C.A. - MDMT _____ @Temp _____

BOOT CHANNEL:
 Head Mat'l _____ Head Nom. _____ Head C.A. _____ Top Mat'l _____ Top Nom. _____ Top C.A. _____
 Shell Mat'l _____ Shell Nom. _____ Shell C.A. _____ Btm Mat'l _____ Btm Nom. _____ Btm C.A. _____
 MAWP Shell side: 50psi @ Temp. 200°F MAWP Tube side: _____ @ Temp. _____

PIPING INFORMATION:
 Circuit. No. _____ Line No. (s) (PLEASE PUT LINE NUMBERS ON APPLICABLE LINES ON THE DRAWING)
 Piping Class _____ Service: _____ Yr. Blt. _____
 MAWP: _____ @ Temp. _____ Size & Schedule of Piping (PLEASE PUT APPROPRIATE SIZES AND SCHEDULES OF PIPING ON DRAWING)

A0220737 UT Readings
Readings in Inches

	SOB	EOB	MIN
LOC 5	0.361	0.396	40.250
LOC 10	0.317	0.340	0.282
LOC 15	0.265	0.271	0.265
LOC 20	0.274	0.274	0.271
LOC 25	0.258	0.256	0.238
LOC 30	0.213	0.211	0.208
LOC 35	0.200	0.204	0.196
LOC 40	0.223	0.210	0.201
LOC 45	0.232	0.217	0.203



A0220 737 Firetube UT Values

UT	Top	Outside	Bottom	Inside
UT 1	.370"	.368"	.366"	.368"
UT 2	.366"	.370"	.368"	.370"
UT 3	.364"	.366"	.364"	.363"
UT 4	.364"	.368"	.373"	.369"
UT 5	.363"	.367"	.381"	.366"
UT 6	.357"	.368"	.372"	.369"
UT 7	.344"	.392"	.374"	.372"

CUSTOMER: _____

FACILITY: _____

LSD: _____

P & ID: _____

DRAWN BY: _____

DATE: _____


DRAWING NO. _____

VESSEL INFORMATION:

A0220737 Firetube UT Readings
Readings in Inches

	PNT1	PNT2	PNT3	PNT4
LOC1	0.370	0.368	0.366	0.368
LOC2	0.366	0.370	0.368	0.370
LOC3	0.364	0.366	0.364	0.363
LOC4	0.364	0.368	0.373	0.369
LOC5	0.363	0.367	0.381	0.366
LOC6	0.357	0.368	0.372	0.369
LOC7	0.344	0.392	0.374	0.372

Equipment Photographs:



CUSTOMER: _____ FACILITY: _____ LSD: _____
 P & ID: _____ DRAWN BY: _____ DATE: _____ DRAWING NO. _____
 VESSEL INFORMATION: _____

01a-A0220737_firetube_IRISNDT UT INSP MAY2012