

Canadian Natural Resources Limited
GENERAL PRESSURE VESSEL INFORMATION

Job# 10.111395

District: Fort St. John North		Skid No.					
Facility: Umbach Compressor		Location (LSD): c-37-F/94-H-03					
Vessel Name Equipment Number: Inlet Separator							
Orientation: Vertical							
Status: Not in Service				Regulatory Inspection			
PRESSURE VESSEL NAMEPLATE DATA							
“A” or “G” or “S” (Sask.) or BC Registration Number. A0550804				CRN Number: K 9873.213			
Vessel serial number: 5-1758				Size: 30 inch x 144 inch			
Shell thickness: 31.8 mm				Shell material: SA 516 70N			
Head thickness: 30.2 mm				Head material: SA 516 70N			
Tube wall thickness:				Tube material:			
Tube diameter:				Tube length:			
Channel thickness:				Channel material:			
Design pressure	Shell: 1480 PSI			Operating pressure	Shell:		
	Tubes:				Tubes:		
Design Temp.	Shell: 100° F			Operating temperature	Shell:		
	Tubes:				Tubes:		
X-ray: RT 1				Heat treatment: yes			
Code parameters: ASME VIII, DIV 1				Coated: No			
Manufacturer: SILVERADO OILFILED				Year built: 2006			
Corrosion allowance: 3.2mm				Manway: No			
PRESSURE SAFETY VALVE NAMEPLATE DATA							
PSV Tag Shell	Manufacture // Model // Serial	Set Pressure (PSI / kPa)	Capacity (scfm / usgpm)	Block Valve	Size	Location	Service by / Date
	Taylor // 82G11651311 // 24883-35	1440 PSI	10871 SCFM	No	2 x 2	Upper Shell	DALCO – 6/2011
PSV Tag Tube	Manufacture // Model // Serial	Set Pressure (PSI / kPa)	Capacity (scfm / usgpm)	Block Valve	Size	Location	Service by / Date
SERVICE CONDITIONS-INDICATE ALL THAT APPLY							
Sweet	Sour X	Oil			Gas X	Water X	
Amine	LPG	Condensate X			Air	Glycol	
Other (Describe):							

Inspection Interval _____ **PSV Service Interval** _____

(Determined by MIC in conjunction with Chief Inspector following guidelines of CNRL's Owner-User Inspection Program)

Reports reviewed and accepted by:

Mechanical Integrity Coordinator _____ **Date** _____


Fill out all forms as completely as possible. All information is important! Use back of sheets to record additional information or sketch if required.

Copy of report to be filed by MIC at site, and copy sent to Chief Inspector

External Inspection Items	G	F	P	N/A	Comments
Insulation Verify sealed around manways, nozzles, no damage present, and there is no egress of moisture.	X				Vessel is not insulated.
External Condition Assess paint condition, areas peeling, record any corrosion, damage, etc (record location, size and depth of corrosion or damage)	X				Paint in good overall condition – No exposed metal – no corrosion.
Leakage Record any leakage at flanges, threaded joints, weep holes on repads, etc.	X				No leaks observed.
Skirt: Assess condition of paint, fire protection, and concrete. Look for corrosion, buckling, dents, etc. Look at vessel surface area near supports. Verify no signs of leakage at attachment to vessel and attachment welds are acceptable. Ground wire attached?	X				Skirt is bolted to skid floor - No corrosion - no leaks at attachment welds to vessel - No buckling or dents Ground wire attached to skid
Anchor Bolts Hammer tap to ensure secure. Look for cracking in treads or signs of deformation.	X				Anchor bolts are securely fastened - no sign of deformation
Concrete foundation Check for cracks, spalling, etc.				X	None.
Ladder / Platform Describe general condition, ensure support is secure to vessel, describe any hazards.				X	None.
Nozzle Assess paint, look for leakage, and ensure stud threads are fully engaged. Record any damage, deflection, etc. Are nozzles gusseted?	X				Paint in good condition - Stud threads are fully engaged - No damage or deflections observed – no leaks. Nozzles are not gusseted.
Gauges Ensure gauges are visible, working, no leakage, and suitable for range of MAWP/ Temp.	X				Pressure gauge: 0 – 1000 PSI Temp gauge: -40 – 160 F
External Piping Ensure pipe is well supported. All clamps, supports, shoes, etc. in place. Look for evidence of structural overload, deflection, etc. Paint condition, external corrosion?	X				Piping is well supported - No signs of structural overload, all clamps and supports are in place. Paint in good overall condition – no corrosion
Valving Ensure no leaks are visible. Valves are properly supported and chained if necessary.	X				No leaks are visible. Valves are properly supported.
PSV Ensure PSV is set at pressure at or below that of vessel.		X			Located on upper shell – set below the vessel MAWP –PSV discharge is blinded off – seal intact
NDE methods Was UT/ MPI done on vessel (MI coordinator to review results)	X				Ultrasonic corrosion survey carried out – pipe metal thickness detected below nominal minus corrosion allowance. Thickness calculations carried out: UT point 410 (3" Elbow) – nominal thickness is 5.5mm / min thickness is 4.3mm / T min thickness is 3.2mm.
Recommendations or corrective actions : Vessel is Fit for Service or describe corrective actions required) (MIC to review corrective actions with Operations, discuss with Chief Inspector where necessary, and get remedial action implemented) Recommendations: Summary: This vessel is in good over all condition, visual external and ultrasonic thickness survey carried out-pipe metal thickness detected below nominal minus corrosion allowance. Thickness calculations carried out to ensure sufficient metal exists for safe operation. Long term corrosion rate based on greatest thickness loss – no corrosion rate to assess. Vessel is fit for service.					

Inspected By: Andrew Neis / D. Wiedman


Date: March 12, 2012



Data plate



Overview



Temp Gauge



Bolted to skid floor



Pressure Gauge



PSV



PSV Data Plate