



PRV INSPECTION AND TEST REPORT

BRANCH: Fort St John

UVL ID#: 2955G

Work Order: 307311

Customer PO#:

Customer: CANADIAN NATURAL RESOURCES LIMITED

Date: 5/26/2011

Facility: SOUTH BUICK

LSD: d-78-l/94-A-11

PSV Location: SEPARATOR

A#: A3151394

Vessel SN: AB790604

Cust Id: N/A

Cust. Ref.:

Valve PO#:

PO Line#:

Cust WO#:

Cust AFE#:

Cost Centre #: 30747000

VALVE DATA

Man.: CONSOLIDATED Model: 1905KC-XAS Serial: 80C5117 Seat: Hard
Conn: Flanged Inlet: 3" 150 RF Orifice: K Outlet: 4" 150 RF
Set Pres: 75 PSI Back Press: 0 PSI Cold/Diff Set: PSI Temp: N/A Cap: 3246 SCFM
Lift Lever: [ ] Cap Assembly: Closed Code Symbol: UV CRN#: 01832.568312

CUSTOMER INSTRUCTIONS

Instructions: Pretest, Service, and Test Pretest Required? [x] Reset Required? [ ]
Replaces UVL ID#: Replaces Serial #: Replaces Cust ID#:
RESET INFO: New Pressure: New Cold/Diff: New Capacity: New Model:

CONDITION AS RECEIVED

Visual Condition: Good Data Plate Condition: OK Date of last service: 4 07
Seal Condition: Top: Intact Bottom: Intact Insignia: UVL Fittings Attached: Inlet: [ ] Outlet: [ ]
Inlet: Clean Inlet Plugged: [ ] Outlet: Clean Outlet Plugged: [ ] Initial Insp. Signoff: Jenna Wolsey

PRETEST 1

Simmer: 77 PSI Set Press: 78 PSI Reseat: 64 PSI Leakage: 15 BPM Test gauge: FSJ 1+2
Tested by: Grant Watson Pretest comments:

PRETEST 2

Simmer: PSI Set Press: PSI Reseat: PSI Leakage: BPM Test gauge:
Tested by: Pretest comments:

Table with columns: ITEM, CLEAN, OILY, RUSTY, CARBON, OTHER, COMMENTS, OK / REPLACE, REPLACED?, REPAIRS PERFORMED. Rows include DISC, NOZZLE, CAP-LEVER ASSY, COMP SCREW and LOCKNUT, SPRING and BUTTONS, SPINDLE / STEM, STEM RETAINER, DISC HOLDER, GUIDE / UPPER RING, LOWER RING, RING PIN(S), BELLOWS, GASKET / SEALS, CONNECTION ENDS, OTHER.

Disc: MIN=.422 ACT=.485 Nozzle: Min: .437 ACT=.523 Spring Number: HOA257CR

Comments:

Disassembly: Harley Anderson Inspection: Harley Anderson Reassembly: Harley Anderson

FINAL TEST:

Test Medium: Air Simmer: 73 PSI Set Pressure: 75 PSI
Reseat: 69 PSI Leakage Acceptable as per API 527.: [x] B.P. Test: 60 PSI
ADJ. RING SETTING (NOTCHES): Upper: N/A Lower: -6 Test Gauge FSJ 1+2 Set Press Def: POP
Tested by: Grant Watson

FINAL INSPECTION:

SEAL: Top: [x] Bottom: [x] End Protectors Installed: [x] Painted: [x] Palletized: [x] Ship Container: [ ] Flex Gaskets Supplied: [x]
Final Inspection: Jenna Wolsey Customer Inspection
Comments: