



IML	DESL	DIR	SOS
0.5	V05IE	T-3	2"
D.7	VMSL	T-3	4"
10	VULL	T-3	5"
12	VOI	T-3	E0B
15	VLLL	T-3	E0B
20	V04N	T-3	E0B
25	V06DE	T-3	7"

G-LYCOL CONTACTOR

CUSTOMER: CNRL FACILITY: BIG BEND LSD: 13-36-066-27W4M  
 P & ID: \_\_\_\_\_ DRAWN BY: MD DATE: Mar 26/09 DRAWING NO. 64

**VESSEL INFORMATION:**  
 Equip. No. \_\_\_\_\_ Pro.Reg.No (A) 0160405 C.R.N. D3901.2 Serial No. 79-7011-A Yr. Inst. \_\_\_\_\_  
 Code/Div. \_\_\_\_\_ Size: \_\_\_\_\_ ID / OD X \_\_\_\_\_ Manufacturer: Maloney steel Ltd. Yr. Blt. 1979  
 C. Stamp U Service: Sweet PWHT: NO J.E.: \_\_\_\_\_ Radiography: RT-1 Insulated: NO

**HEAD:**  
 Top Mat'l SAS1670N Top Nom 25.6mm Top C.A. 1.6mm Material SAS1670 Nominal 28.6mm C.A. 1.6mm  
 Btm Mat'l \_\_\_\_\_ Btm Nom. 1.05" Btm C.A. \_\_\_\_\_ 1.125" 0.0625"

**BOOT:**  
 Head Mat'l \_\_\_\_\_ Head Nom \_\_\_\_\_ Head C.A. \_\_\_\_\_ Top Mat'l \_\_\_\_\_ Top Nom. \_\_\_\_\_ Top C.A. \_\_\_\_\_  
 Shell Mat'l \_\_\_\_\_ Shell Nom. \_\_\_\_\_ Shell C.A. \_\_\_\_\_ Btm Mat'l \_\_\_\_\_ Btm Nom. \_\_\_\_\_ Btm C.A. \_\_\_\_\_  
 MAWP Shell side: 1100 PSI @ Temp. 200°F MAWP Tube Side: \_\_\_\_\_ @ Temp. \_\_\_\_\_

**PIPING INFORMATION:**  
 Circuit. No. \_\_\_\_\_ Line No. (s) (PLEASE PUT LINE NUMBERS ON APPLICABLE LINES ON THE DRAWING)  
 Piping Class \_\_\_\_\_ Service: \_\_\_\_\_ Yr. Blt. \_\_\_\_\_  
 MAWP: \_\_\_\_\_ @ Temp. \_\_\_\_\_ Size & Schedule of Piping (PLEASE PUT APPROPRIATE SIZES AND SCHEDULES OF PIPING ON DRAWING)

DWG # 59

A0160405 UT Readings  
Readings in mm

LOC5	6.55	7.22	6.70
LOC7	29.38	29.69	29.56
LOC10	29.69	29.98	29.84
LOC12	29.57	29.91	29.78
LOC15	29.34	29.77	29.43
LOC20	28.07	30.85	28.83
LOC25	6.94	8.06	7.42