

CNR-PVI-14-00014

#### Criticality Designation

#### **Pressure Vessel Static Information**

Insp. Comp: Summit Inspection Services Ltd District: Slave Lake Field: BRINTNELL 1362 Unit/Skid: PV-610 Location: 12-09-081-22W4 BR BATTERY LSD: 12-09-081-22W4 Jurisdiction #: A0403457 Alt. Jur #: Equip Tag #: PV-620 CRN #: L0015.2 Serial #: 97015-2-30 Year Built: 1998 Manufacturer: Resource Constructors (Canada) Inc. **Equipment Description: TREATER** Status: In Service Equip Type: Vessel Service: Sour Shell MAWP: 148.8900 C 517.11 kPa Volume: bbl **Tube MAWP:** kPa С Length: **Insulated** • Yes No Shell MDMT: Diameter: 3.05 m PWHT: O Yes -28.8900 C RT: RT1 OD No **Tube MDMT:** Support: Saddle Manway: ● Yes O No Coated: O Yes Shell C.A.: С Shell JE: 1.00 No Clad: ● Yes O No Tube C.A.: mm Tube JE: Remote Access: \( \) Yes Dim Text: Horizontal Data: New

#### **Corrosion Monitoring Location (CML) Static Information**

Side	TML#	Test PT Name	Material	Nom Thick	Diameter	CORR Allow
S	400	Bottom East Head		12.7 mm	3048 mm OD	1.6 mm
S	405	Upper South Shell (west end)		12.7 mm	3048 mm OD	1.6 mm
S	410	Lower South Shell (west end)		12.7 mm	3048 mm OD	1.6 mm
S	415	Bottom South Shell (center)		12.7 mm	3048 mm OD	1.6 mm
S	420	Bottom Shell (east end)		12.7 mm	3048 mm OD	1.6 mm
S	425	Bottom Shell (west end)		12.7 mm	3048 mm OD	1.6 mm
S	450	4" Outlet Elbow	SA-234-WPB	6.02 mm	114.3 mm OD	1.6 mm
S	460	Bottom of 2" Outlet Pipe	SA-106-B	5.54 mm	60.32 mm OD	1.6 mm
S	470	Bottom of 3" Pipe	SA-106-B	7.62 mm	88.9 mm OD	1.6 mm
S	471	3" Outlet Elbow	SA-234-WPB	7.62 mm	88.9 mm OD	1.6 mm
S	472	Bottom of 3" Outlet Pipe	SA-106-B	7.62 mm	88.9 mm OD	1.6 mm
S	473	Bottom of 3" Tee	SA-234-WPB	7.62 mm	88.9 mm OD	1.6 mm
S	474	3" Outlet Elbow	SA-234-WPB	7.62 mm	88.9 mm OD	1.6 mm
S	475	3" Outlet Elbow	SA-234-WPB	5.49 mm	88.9 mm OD	1.6 mm
S	480	2" Outlet Elbow	SA-234-WPB	3.91 mm	60.32 mm OD	1.6 mm
S	490	3" Inlet Elbow	SA-234-WPB	7.62 mm	88.9 mm OD	1.6 mm
S	492	Bottom of 3" Inlet Pipe	SA-106-B	7.62 mm	88.9 mm OD	1.6 mm
S	494	Bottom of 3" Inlet Pipe	SA-106-B	7.62 mm	88.9 mm OD	1.6 mm

Comment:				

Printed On: Mar/23/2015 10:09:54 AM PAGE # 1 Of 17



CNR-PVI-14-00014

#### **Criticality Designation**

#### **PSV Static Data**

Tag #: Serial #: SE-17489-1 CRN: 0G0201.2C USGPM Model No: JLT-JOS-15/A Capacity: 729 Set Pressure: 75 psi Manufacturer: Crosby Location of PSV: On Vessel Last Service Date: Inlet Size: Conn. Type: Flanged 3.00 in Inlet Block: O Yes **Outlet Size:** 4.00 in Code Stamp: UV Outlet Block: O Yes No PSV Side: SHELL Service Comp: Apex Valve Services Out For Service: O Yes No Comment: Meets code requirements, Last PSV service date is February 11, 2013.

Printed On: Mar/23/2015 10:09:54 AM PAGE # 2 Of 17



CNR-PVI-14-00014

External Inspection Complete: 2014-08-11

#### **Criticality Designation**

External Inspection Results - V	Έ
---------------------------------	---

Item	N/A	Condition	Comment	NCR	Action Item Integrity	Action Item Maintenance		
Nameplate		Accept						
Foundation & Supports		Accept						
Anchor Bolts		Accept						
Grounding		Accept						
Insulation Condition		Accept						
PSV		Accept						
Shell Heads & Nozzles		Accept						
Metal Surfaces (Paint)	V							
Aux. Equipment		Accept						
Cathodic Protection		Accept						
Alignment	Ø							
Flange Connections		Accept	Manway davit arm is single nutted.					
Pressure Gauge		Accept						
Temperature Gauge		Accept						
Sight Glass		Accept						
Ladder / Platform		Accept						
Leak		No						
Piping From Vessel		Accept						
Previous UT Survey		Pick	Survey Date:	UT Con	npany:			
External Visual Observations								
Recommendations	Recommendations							
Install a second nut to the r	manway	/ davit arm						



CNR-PVI-14-00014

#### **Criticality Designation**

**Internal Inspection Results - VI** 

Internal Inspection Results - VI		<u>s - VI</u>	Internal Inspection Comp	2014-08-11			
Item	N/A	Condition	Comment	NCR	Action Item Integrity	Action Item Maintenance	
Shell							
Heads							
Manway							
Gasket Surfaces							
Welds							
Refractory							
Heating Coils							
Demister Pad							
Vane Pack							
Baffles							
Trays							
Filter							
Internal Coating							
Tubesheet							
Tube Bundle							
Internal Visual Observations							
Recommendations							

Printed On: Mar/23/2015 10:09:54 AM



CNR-PVI-14-00014

#### **Criticality Designation**

Firetube Static I	<u>Data</u>		Firetube Inspection Complete: 2014-08-11					
Diameter:			Nom Thickness:					
Length:		Fi	retube Description:					
Firetube NDE	UT 🔲	Report #:	Report #: MT		oort #:			
Performed:	РТ 🗌	Report #:	Other	Report #:				
Firetube Inpecti	on Resu	<u>lts</u>						
Item	N/	A Condition	Comment	NCR	Action Item Integrity	Action Item Maintenance		
Burner		]						
Stack		]						
Flange (Throat)		]						
Tube Sheet		]						
Hot Side		]						
Miter		]						
Return Bend		]						
Supports		]						
Butt Welds		]						
Fillet Welds		]						
Firetube Visual Observations								
Recommendations								

Printed On: Mar/23/2015 10:09:54 AM PAGE # 5 Of 17



CNR-PVI-14-00014

#### Criticality Designation

# **NDE and Final Summary** NDE Report #: Report #: UT $\sqrt{}$ UT(SW) Performed: Report #: Report #: PΤ MΤ Report #: Other **Drawing Found? Observations Summary** The vessel appeared to be in good external condition. UT corrosion survey was performed on the vessel and associated piping. Please see attached copy of report for inspection details. **Recommendations Summary Actions Corrected at Time of Inspection Additional Visual Observations** Any other safety concerns or observations from associated equipment Possible indications of internal corrosion may be occurring in the bottom of the pipe to a low of .165". Nominal thickness is .218".



CNR-PVI-14-00014

#### **Criticality Designation**

## **Thickness and Remaining Life Evaluation**

MUST BE COMPLETED AND R	ESOL\	VED WITH CNRL I	MMEDIATELY L	PON DISCOVERY	OF LOW WALL THIC	KNESS AREAS
Was any thi	cknes	s measurement lo	cation (Nomina	I WT - Corrosion A	Allowance)?: No	
			Report #:			
Which component(s) were found	d belov	w (Nominal WT - C	Corrosion Allow	ance)?		
Components below (Nom - CA)			Componen	ts below (Nom - CA	A)	
	-					
	-					
	-					
	-					
	-					
Component Worksheet:						
Component		Low Reading	Calculated T-Min	Reading Below T-Min	Nature Of Pitting	Remaining Life
Notes:						
Contact CNRL Integrity Coordin	ator to	o discuss above re	esults.			
N	ame C	of CNRL Contact:				
Date and	Time (	Of Conversation:				
Summary/Results Of Conversat	ion:					

Printed On: Mar/23/2015 10:09:54 AM PAGE # 7 Of 17



CNR-PVI-14-00014

#### **Criticality Designation**

#### **Crack Evaluation by Magnetic Particle or Alternative Inspection**

MUST BE COMPLETED AND RESOLVED WITH CNRL IMMEDIATELY UPON DISCOVERY OF CRACK-LIKE INDICATIONS

Were any indications found to suggest the vessel contained cracks? : No

Report #:

Name Of CNRL Contact:

**Summary/Results Of Conversation:** 

**Date and Time Of Conversation:** 

Printed On: Mar/23/2015 10:09:54 AM PAGE # 8 Of 17



CNR-PVI-14-00014

#### **Criticality Designation**

## **CNRL Criticality Evaluation**

	YES	NO
1. Is the vessel fit-for-sevice? :	$\overline{\checkmark}$	
2. Was the measured thickness less than the calculated minimum required thickness (T-Min) of any component?:		$\checkmark$
3. Were MT indications found?:		$\checkmark$
4. Was the remaining life less than 6 yrs for sour service vessels or less than 10 yrs for sweet service vessels?:		$\checkmark$
5. Were NCR's or Action Items generated as a result of the inspection?:		$\checkmark$
6. Were UT readings below (Nominal WT - Corrosion Allowance) found?:		$\overline{\checkmark}$
Information on CNRL Owner User Program - Criticality Designation and Required Review		
RED - Vessel Inspection Results are deemed RED if one of the following occurred:		
* The measured thickness was less than the calculated minimum required thickness (T-Min) for any component		
* MT Indications were found		
* The remaining life was calculated to be less than 6 years for sour-service or less than 10 years for sweet-service veseels		
RED inspection reports must be signed off by the CNRL Chief Inspector.		
YELLOW - Vessel Inspection Results are deemed YELLOW if one or more of the following occurred:		
* The vessel was declared NOT fit-for-service by the 3rd Party In-Service PV Inspector		
* NCR's or Action Items were generated as a result of the inspection.		
* UT Readings below (Nominal WT - Corrosion Allowance) were found.		
YELLOW inspection reports must be signed off by the CNRL Pressure Equipment Integrity Coordinator		
GREEN - Vessel Inspection Results are deemed GREEN if <u>all</u> of the following are true:		
* The vessel was declared fit-for-service by the 3rd Party In-Service PV Inspector.		
* UT Readings below (Nominal WT - Corrosion Allowance) were NOT found.		
* MT indications were NOT found.		
* NCR's or Action Items were NOT generated as a result of the VE inspection.		
GREEN Inspection reports must be signed off by the 3rd Party In-Service Pressure Vessel Inspector.		
Criticality Designation		

Printed On: Mar/23/2015 10:09:54 AM PAGE # 9 Of 17



CNR-PVI-14-00014

**Criticality Designation** 

# **Inspection Photographs and Relevant Files**

Title:



**Description:** Vessel nameplate

Printed On: Mar/23/2015 10:09:54 AM PAGE # 10 Of 17



CNR-PVI-14-00014

**Criticality Designation** 

## **Inspection Photographs and Relevant Files**

Title:



**Description:** Inside view of vessel

Printed On: Mar/23/2015 10:09:54 AM



CNR-PVI-14-00014

**Criticality Designation** 

## **Inspection Photographs and Relevant Files**

Title:



**Description:** Outside view of vessel

Printed On: Mar/23/2015 10:09:54 AM PAGE # 12 Of 17



CNR-PVI-14-00014

**Criticality Designation** 

## **Inspection Photographs and Relevant Files**

Title:



**Description:** General view of burner assembly

Printed On: Mar/23/2015 10:09:54 AM PAGE # 13 Of 17



CNR-PVI-14-00014

**Criticality Designation** 

## **Inspection Photographs and Relevant Files**

Title:



**Description:** PSV nameplate

Printed On: Mar/23/2015 10:09:54 AM PAGE # 14 Of 17




CNR-PVI-14-00014

**Criticality Designation** 

#### **Inspection Photographs and Relevant Files**

Title:



Description: PSV service tag

Printed On: Mar/23/2015 10:09:54 AM PAGE # 15 Of 17



CNR-PVI-14-00014

**Criticality Designation** 

## **Inspection Photographs and Relevant Files**

Title:



**Description:** General view of PSV

Printed On: Mar/23/2015 10:09:54 AM PAGE # 16 Of 17



CNR-PVI-14-00014

#### **Criticality Designation**

#### **Job Information**

Vehicle #: Inspector (name): Maria Savulescu

Time In: Time Out: Hrs: PESL #: 000162 API: 24958

Time In: Time Out: Hrs: Inspector (signature):

Personnel 1: Nyssa Moore CNRL Coordinator (name):

Personnel 2: Tyler Cameron CNRL Coordinator (signature):

Billing Info: - CNRL Chief Inspector (signature):

Report ID: CNR-PVI-14-00014-25 Inspector Job Number:

Printed On: Mar/23/2015 10:09:54 AM PAGE # 17 Of 17