Canadian Natural Resources Limited GENERAL PRESSURE VESSEL INFORMATION Job 10.113250										
District: Fort St	. John		Skid No.							
Facility: Millig	an Battery	Location (LSD): b-63-G/94-H-02								
Vassal Nama Equ	uipmont Numbor:									
vessei Name Equ										
Orientation: Hor	rizontal									
Status: In S	Service	Regulatory Inspection								
	I	PRESSURE VES	SSEL NA	AME	PLATE DATA	L				
"A" or "G	" or "S" (Sask.) or BC Regi	CRN Number:								
	A0225408		F 5480 21							
Vessel serial nun	nber: 85C-3422-01	Size: 12 ft. x 24ft.								
Shell thickness:	19 mm	Shell material: SA 516 70								
Head thickness:	17.2 mm		Head material: SA 516 70							
Tube wall thickne	ess:		Tube material:							
Tube diameter:			Tube length:							
Channel thicknes	s:		Ch	annel material:		r				
Design pressure	Shell: 862 kPa			Operating pressure			Shell:			
	Tubes:						Tubes:			
Design Temp.	Shell: 66° C			Operating temperature		Shell:				
					Tubes:					
X-ray: RT-1			Heat treatment: HT							
Code parameters	: ASME VIII, DIV. 1		Coated: Yes							
Manufacturer: A	ALCO GAS AND OIL		Year built: 1985							
Corrosion allowa	Ince: 1.6 mm		Manway: Yes							
	PRE	SSURE SAFETY	(VALV	'E NA	MEPLATE DA	ATA				
PSV Tag #	Manufacture / Model / Serial	Set Pressure (PSI / kPa)	Capao (scfr	city n)	Size	Block Valve		Location	Service by Date	
1927V	Farris / 26PA10-120- 55M / CE-27748-A10	862 kPa	1693	30	4 x 6	No		Top Shell	Unified 06/2013	
	SERVIC	CE CONDITION	S-INDI	CAT	E ALL THAT	APPL	Y			
Sweet	Sour X	Sour X					Gas X		Water X	
Amine LPG Co					e		Air		Glycol	
Other (Describe):										
Inspection IntervalPSV Service Interval										

Inspection Interval _

(Determined by MIC in conjunction with Chief Inspector following guidelines of CNRL's Owner-User Inspection Program) Reports reviewed and accepted by:

Mechanical Integrity Coordinator_____

Fill out all forms as completely as possible. <u>All information</u> is important! Use back of sheets to record additional information or sketch if required. Copy of report to be filed by MIC at site, and copy sent to Chief Inspector

_Date_____

External Inspection Items	G	F	Р	N/A	Comments
Insulation Verify sealed around manways, nozzles, no damage present, and there is no egress of moisture.				X	Vessel not insulated
External Condition Assess paint condition, areas peeling, record any corrosion, damage, etc (record location, size and depth of corrosion or damage)	X				Paint in fair overall condition – top coat is peeling to 50% previous coat remains intact – no exposed metal – no corrosion
Leakage Record any leakage at flanges, threaded joints, weep holes on repads, etc.	x				No leaks found
Saddle/skirt Assess condition of paint, fire protection, and concrete. Look for corrosion, buckling, dents, etc. Look at vessel surface area near supports. Verify no signs of leakage at attachment to vessel and attachment welds are acceptable. Ground wire attached?	X				Saddle Paint in good condition – no corrosion, buckling or dents – no sign of leaks at attachment welds – ground wire is attached
Anchor Bolts Hammer tap to ensure secure. Look for cracking in treads or signs of deformation.		x			West saddle is welded to support steel – east saddle is not securely attached to skid – bolts not tightened – no deformation
Concrete foundation Check for cracks, spalling, etc.				Х	None
Ladder / Platform Describe general condition, ensure support is secure to vessel, and describe any hazards.		X			Ladders are in good condition – secured directly to shell – no loose or missing section – Platform in fair overall condition – holes noted in floor – secured to support steel
Nozzle Assess paint, look for leakage, and ensure stud threads are fully engaged. Record any damage, deflection, etc. Are nozzles gusseted?	X				Nozzle paint in good condition – no leaks – stud threads fully engaged – no damage or deflection – nozzles are not gusseted
Gauges Ensure gauges are visible, working, no leakage, and suitable for range of MAWP/ Temp.	x				Gauges clear and functional – within range for service
External Piping Ensure pipe is well supported. All clamps, supports, shoes, etc. in place. Look for evidence of structural overload, deflection, etc. Paint condition, external corrosion?	X				Piping is well supported – all clamps in place – no evidence of structural overload – no deflection – paint in good condition
Valving Ensure no leaks are visible. Valves are properly supported and chained if necessary.	x				Valves properly supported – no leaks
PSV Ensure PSV is set at pressure at or below that of vessel.	x				PSV found lying on side, not in proper handling condition set at MAWP – seal intact – no block valve – discharge piping does not reduce -
NDE methods Was UT/ MPI done on vessel (MI coordinator to review results)	X				Ultrasonic corrosion survey carried out – pipe metal thickness detected below nominal minus corrosion allowance. Thickness calculations carried out: UT point 261 (3" Nozzle) – nominal thickness is 15.2mm / min thickness is 7.6mm / T min thickness is 1.6mm. UT point 263 (4" Nozzle) – nominal thickness is 17.1mm / min thickness is 15.4mm / T min thickness is 1.6mm.

Recommendations or corrective actions : Vessel is Fit for Service or describe corrective actions required) (MIC to review corrective actions with Operations, discuss with Chief Inspector where necessary, and get remedial action implemented)

Recommendations: Monitor 3" Water Dump nozzle on regular basis – not to exceed 1 year.

Summary: This vessel is in good condition, visual external and ultrasonic thickness inspection carried out – pipe metal thickness detected below nominal minus corrosion allowance. Thickness calculations carried out to ensure sufficient metal exists for safe operation.

Corrosion rate based on greatest thickness loss (nozzle) 0.271mm per year. Retirement Date to "T"min is year 2035. Vessel is fit for service.

Internal Inspection Items		F	P	N/A	Comments
Coating Assess coating. Describe area coated,		Χ			Internal surface is 100% coated with epoxy – coating
general condition of coating.					failure to 5% of total area - three 3 inch nozzles with total
					coating loss – blistering and failed coating along 6 o'clock
					region
Anodes. How many, type, condition. %			Х		Two anode removed from vessel – in poor condition - over
consumed. Are they being replaced?					60% consumed
Internal Piping Is there any? If so, carbon or			Х		Internal piping removed for inspection – poor condition –
stainless steel. Describe condition, dents,					through wall corrosion – Internal piping has no use and
corrosion, erosion, etc. Ensure supports are					will not be reinstalled after inspection
secure and any bolts are suitable for future					
use.				N 7	N
Trays How many? Type of material. Are				Х	None
valves in place. Check for erosion/ corrosion;					
wear on tray valve legs. Cleanliness?	\$7				
Battles, deflector plates, etc. If present,	Х				Baffle in good overall condition – isolated area of corrosion
describe condition. Look closely at welds					at attachment weld to shell – pitting to 0.060 inch – inlet
attached to vessel wall.					deflector in good condition – minor coating loss – no
W/	\$7				corrosion or mechanical damage
west Head Note all corrosion, erosion or	Х				Isolated pitting found – pit depths to 0.150 inch –
mechanical damage. (If vessel is norizontal					
Identify direction of this head)	v				
East Head Note all corrosion, erosion of	Λ				No corrosion lound – coaling in good overall condition –
identify direction of this head)					small isolated holidays located at 6:00 – no mechanical
Shall Sections Record number of shall		v			Chall sections avaidable with corresponding found
solutions Record location size and depth of all		л			shen sections – exposed metal with corrosion pitting found throughout 6 algorithm pitting from 0.050 to
sections. Record location, size and deput of an					0.250 inch _ no machanical damaga noted
Describe general condition. If any corrosion					0.250 men – no meenamear damage noted
greater than corrosion allowance is observed					
in either shell or head discuss with Chief					
Inspector before closing vessel					
Demister nad Is it in place? Is it clean? If any			x		Vane pack demister was removed after initial inspection –
corrosion is apparent in vessel, lift pad and					found to be collapsed and full of solids
check top head for corrosion.					
Welds Inspect all welds, including attachment	Χ				Three nozzle welds found to be corroded – wall loss from
welds. Record all service-related damages and					0.300 to 0.600 inch –
if there is any discuss with Chief Inspector					All Shell and head weld found in good condition with
before closing.					minimal coating loss and no corrosion or defects noted
Repairs Required. If yes, ensure procedure	Χ				Yes – Weld repair required to build up wall loss on bottom
and copy of AB 40 is on file, and one sent to					shell and nozzle metal loss on three 3 inch nozzles
local ABSA, and Chief Inspector					
-					
NDE Was any NDE done. (MI coordinator to	Χ				
review results)					

Recommendations or corrective actions : Vessel is Fit for Service or describe corrective actions required) (MIC to review corrective actions with Operations, discuss with Chief Inspector where necessary, and get remedial action implemented)

Recommendations: 1. Cut out and replace corroded nozzles #2 and #3 - Weld build-up on corroded nozzle #1. Grit blast failed epoxy coating on bottom shell from 5 – 7 o'clock position for entire length of shell and inside repaired nozzles. Re coat epoxy to bottom shell. Repair minor coating damage around man way, internal supports and ladder with Devoe 142 Summerry Vascal is in overall good condition visual external inspection and ultrasonic corrosion survey performed – no metal

Summary: Vessel is in overall good condition, visual external inspection and ultrasonic corrosion survey performed—no metal thickness detected below nominal minus the corrosion allowance.

Vessel is fit for service.





Bottom section of demister pad collapsed - full of solids

Upper section of demister pad -





Coating blistering

