	GEN	Canadian Na ERAL PRESSU				ION		Job	: 10.113559				
District: Fort St	. John BC	Skid No.											
Facility: Graha	Location (LSD): c-76-K-94-B-08												
Vessel Name Equ													
Orientation: Ho	*	·											
	Service			D	egulatory Insp	oction							
Status. III (RESSURE VES	SEL N										
"A" or "G	" or "S" (Sask.) or BC Regi						CRN Nun	ıber:					
	A0454381					D02240	11						
Vaccal carial num	P0334.21												
	ssel serial number: 2000-6332-01Size: 66 in. X 24 ft.ell thickness: 76.2mmShell material: SA 516-70N												
Head thickness:													
	74.mm	Head material: SA 516-70N Tube material: Tube length:											
	Tube wall thickness: Tube diameter:												
	'ube diameter: 'hannel thickness:												
Chainer uneknes	Shell: 1332 PSI				annel material:								
Design pressure			Operating pressure			Shell:							
	Tubes:						Tubes:						
	Shell: 200 Deg F.	Shell: 200 Deg F.			Shell:					Shell:			
Design Temp.	•		erating temperat	ture									
V DTI						Tubes:							
X-ray: RT1					at treatment: Ht	Į							
Code parameters: ASME VIII Div 1				Coated: Yes									
Manufacturer: Alco Gas & Oil Corrosion allowance: 3.2mm					Year built: 2000 Manway: Yes								
Corrosion allowa					· ·								
	PRE	SSURE SAFETY	Y VALV	E NA	MEPLATE DA	ATA							
PSV Tag #	Manufacture / Model /	Set Pressure	Capad	city	Size	В	lock	Location	Service				
	Serial	(PSI / kPa)	(scfr			V	alve		by Date				
							No	Top shell					
	SERVIC	E CONDITION	S-INDI	CAT	E ALL THAT	APPL	Y						
Sweet			Oil						Water				
Amine	mine LPG C				e		Air		Glycol				
Other (Describe)	· · · · · · · · · · · · · · · · · · ·												

Inspection Interval

PSV Service Interval

Date

(Determined by MIC in conjunction with Chief Inspector following guidelines of CNRL's Owner-User Inspection Program) Reports reviewed and accepted by:

Mechanical Integrity Coordinator_____

Fill out all forms as completely as possible. <u>All information</u> is important! Use back of sheets to record additional information or sketch if required. Copy of report to be filed by MIC at site, and copy sent to Chief Inspector

External Inspection Items	G	F	Р	N/A	Comments
Insulation Verify sealed around manways, nozzles, no damage present, and there is no egress of moisture.				x	Vessel not insulated.
External Condition Assess paint condition, areas peeling, record any corrosion, damage, etc (record location, size and depth of corrosion or damage)	x				Paint in good condition– no exposed metal.
Leakage Record any leakage at flanges, threaded joints, weep holes on repads, etc.	x				No leaks observed.
Saddle/skirt Assess condition of paint, fire protection, and concrete. Look for corrosion, buckling, dents, etc. Look at vessel surface area near supports. Verify no signs of leakage at attachment to vessel and attachment welds are acceptable. Ground wire attached?	x				Saddles: Bolted directly to skid floor. No buckling or dents. No corrosion at attachment welds to vessel. Ground wire attached to vessel.
Anchor Bolts Hammer tap to ensure secure. Look for cracking in treads or signs of deformation.	x				Vessel saddles bolted firmly to skid floor – no deformation.
Concrete foundation Check for cracks, spalling, etc.				X	
Ladder / Platform Describe general condition, ensure support is secure to vessel, and describe any hazards.				X	
Nozzle Assess paint, look for leakage, and ensure stud threads are fully engaged. Record any damage, deflection, etc. Are nozzles gusseted?	x				Flanged and threaded nozzle joints are fully engaged. No damage or deflections – no leaks. Nozzles are not gusseted.
Gauges Ensure gauges are visible, working, no leakage, and suitable for range of MAWP/ Temp.	x				Clear and clean – no leak. Within operational range for service temperature gauge 0 – 250 Deg F. Pressure gauge 0 – 1000 PSI
External Piping Ensure pipe is well supported. All clamps, supports, shoes, etc. in place. Look for evidence of structural overload, deflection, etc. Paint condition, external corrosion?	x				Piping is well supported; no deflection, all clamps and supports are in place. Paint in good condition – no exposed metal.
Valving Ensure no leaks are visible. Valves are properly supported and chained if necessary.	x				Valves are supported properly – no leaks.
PSV Ensure PSV is set at pressure at or below that of vessel.	X				Location: top shell – PSV removed for service. No block valve between vessel and PSV. Discharge piping is same size as valve out let.
NDE methods Was UT/ MPI done on vessel (MI coordinator to review results)	x				Ultrasonic corrosion survey carried out April 2013 – pipe metal thickness detected below nominal minus corrosion allowance. Thickness calculations carried out: UT point 236 (3" Elbow) – nominal thickness is 5.5mm / min thickness is 4.4mm / T min thickness is 3.8mm. UT point 256 (2" Tee) – nominal thickness is 8.7mm / min thickness is 7.0mm / T min thickness is 2.6mm. UT point 266 (2" Elbow) – nominal thickness is 8.7mm / min thickness is 6.3mm / T min thickness is 2.6mm.

Recommendations: No recommendations. **Summary: See Internal**

Vessel is fit for service.


nternal Inspection Items	G	F	P	N/A	Comments
Coating Assess coating. Describe area coated,	Х				No blisters or peeling.
eneral condition of coating.					Coating in good condition.
nodes. How many, type, condition. %				Х	None.
onsumed. Are they being replaced?					
nternal Piping Is there any? If so, carbon or					
tainless steel. Describe condition, dents,				Х	
orrosion, erosion, etc. Ensure supports are					
ecure and any bolts are suitable for future					
se.					
Trays How many? Type of material. Are					
alves in place? Check for erosion/ corrosion;				Х	
vear on tray valve legs. Cleanliness?					
Saffles, deflector plates, etc. If present,					Inlet deflector plate welded to top shell – no mechanical
escribe condition. Look closely at welds	Х				damage or corrosion.
ttached to vessel wall.					
op Head Note all corrosion, erosion or	1				Man way access – no mechanical damage or corrosion-
nechanical damage. (If vessel is horizontal	Х				attachment welds to head in good condition - no corrosion
lentify direction of this head)					staining on coating. Coating bonded to head no peeling or
					blisters.
Sottom Head Note all corrosion, erosion or	Х				
nechanical damage. (If vessel is horizontal					
lentify direction of this head)					
hell Sections Record number of shell					3 sheet sections- nozzles are clean – boot in good condition –
ections. Record location, size and depth of all	Х				vortex breaker welded firmly to bottom of boot.
rosion, corrosion or mechanical damage.					Vortex breaker welded to shell – no damage.
Describe general condition. If any corrosion					Coating bonded to shell – no peeling or blisters.
reater than corrosion allowance is observed					Nozzles are unobstructed.
n either shell or head, discuss with Chief					Weir welded to shell – no bent or damage sections.
nspector before closing vessel.					
Demister pad Is it in place? Is it clean? If any					Demister pad in place – clean- no loose or broken sections.
orrosion is apparent in vessel, lift pad and	Х				Support bars bolted securely.
heck top head for corrosion.					
Velds Inspect all welds, including attachment					All welds are coated – no corrosion staining on welds.
velds. Record all service-related damages and	Х				
there is any discuss with Chief Inspector	1				
efore closing.					
Repairs Required. If yes, ensure procedure	1				
nd copy of AB 40 is on file, and one sent to	1			Х	
ocal ABSA, and Chief Inspector					
DE Was any NDE done. (MI coordinator to					
eview results)	1				
Norman detions on commentions actions . V		ie 1	 Fit f	for Sa	rvice or describe corrective actions required)

implemented)

Recommendations: No recommendations at this time.

Summary: This vessel is in good condition, visual external and ultrasonic thickness inspection carried out – Pipe metal thickness detected below nominal minus corrosion allowance. Thickness calculations carried out to ensure sufficient metal exists for safe operation.

Vessel is fit for service.



boot

Man way





