

VESSEL INSPECTION SUMMARY

Report #: 92181-DS-01
Inspect Date: 04/19/2007
Page: 1 of 2
IRISNDT #: 92181

Ol:t-	ONDI	Districts	Olavia Lalia	E:-I-I	N.C.	-:-:					
Client: _			Slave Lake		Nipisi 02-11-080-08W5						
· -	02-11-080-08W5 A2556400	Unit		- -							
	A2556400 H8558.21	Equip Tag # Nat'l Bd #:		_ Seliai # Voor Built:	376 19						
Manufacturer:			ment Description: Boiler	_ rear built.	19	09					
Status:		Date Removed From S	ervice:	Se	rvice:	Select					
MAWP Shell	200 Psi @	Pick Height/l	Length:	in / mm	Code Stamp:						
MAWP Tube	Select @	Pick Size/Dia		ID / OD	Insulated:						
Support Type:		RT: Ve	olume:	ft³ / m³	PWHT:	☐ Y ☐ N					
C.A.	Со	ated Y N	Clad: Y N		Manway:	\square Y \square N					
Component	Material	Nominal Minimum	Component	Material	Nominal	Minimum					
Component	Material	- William	Component	Material	rtorriira	· · · · · · · · · · · · · · · · · · ·					
PSV Static Data											
PSV –1 Tag #		Serial #:		CRN	ŀ						
Model #		Capacity:	SCFM	_): 	Select					
Manufacturer		<u> </u>		ervice Company	/: /:						
Shell/Tube Side				Service Date): 						
Size In		Size Out:	С	onnection Type):						
Carseal Intact		umber of PSV's		Location							
PSV – 2 Tag #:		Serial #:		CRN:							
Model #:		Capacity:	SCFM	Set Pressure:		Select					
Manufacturer:				vice Company:		<u> </u>					
Shell/Tube	Shell / Tube					<u> </u>					
Size In:		Size Out:	Cor	Service Date: Connection Type:							
Carseal Intact:	Yes / No Nu		Location:		-						
Carseal Intact: Yes / No Number of PSV's Location: Location:											
Last Report #:	TROCUILO VE	Last Report Dat	0.	Summa	ary Report #:						
	Y N N/A A				_						
Item	Y N N/A Acc	Comment	Item Y	N N/A Ac		mment					
Foundation			Cathodic Protection		_						
Grounding Insulation			Fireproofing								
Piping			Ladders/Platforms		.						
Supports			Berms								
Anchor Bolting			Davit Arm								
TMLs			Pressure Gauge								
20			Temp. Gauge								
Internal Inspection			1 0 1								
Internal inspection											
Item	Y N N/A Acc	Comment	Item Y	N N/A Ac		mment					
Shell			Demister								
Heads			Vane Pack								
Manway			Baffles								
Gasket Surfaces			Trays 🗆								
Welds			Filter Internal Costing								
Refractory			Internal Coating Tubesheet Tubesheet								
Heating Coils Refractory			Tubesheet Tube Bundle								
Renaciony			Tube bullule		1						



VESSEL INSPECTION SUMMARY

Report #: 92181-DS-01
Report Date: 04/19/2007
Page: 2 of 2
IRISNDT #: 92181

Client:	CNRL	LSD:	02-11-080-0	3W5 Juris	sdiction #:	A2556400
Additional Attachments NDE Performed UT		ET 🗌	Specify	to Vessel Inspectio	n Report # 9218	31-DS-01
NDE Report # 92181-U			epair Action Item F	Raised Defe	rred Action Item	Raised 🗌
Inspection Comments:						
IRISNDT witnessed a hy The following was obser - The Boiler was held at - No leaks were observe good condition. No acce	ved: 200 Psi for 1 hour. Reed. There is limited acc	ecorded on cess throug	chart A2556400. gh the bottom of th	e boiler. Tubes test	ed externally, bu	at appears to be in
Recommendations:						
Unit # Ki	ometers:	С	consumables:	Inspector:		DE01
In Out	Hrs			Dennis Simons (Prir	nt)	PESL: <u>A-47671</u>
In Out	Hrs					API:
Personnel:				(Signat I am in full agreement Client Representative		