Canadian Natural Resources Limited GENERAL PRESSURE VESSEL INFORMATION Job# 05.001317									
District: Grange Prairie AB.				Skid No.					
Facility: Gold Creek Gas Gathering				Location (LSD): 02-11-68-06-W6M					
Vessel Name Equipment Number: <b>Treater</b> ( <b>Crude Emulsion</b> )									
Orientation: Horizontal									
Status: In Service Regulatory Inspection   PRESSURE VESSEL NAMEPLATE DATA									
"A" or "G"	or "S" (Sask.) or BC R	CRN Number:							
A OF G	of 5 (Susk.) of DC R	CREATING COLORING							
	A 199858	F 4260.2							
Vessel serial numb Shell thickness: 9.5				Size: 72 in. x 16 ft.					
Head thickness: 9.5				Shell material: SA 516-70					
Tube wall thickness				Head material: SA 516-70					
Tube diameter:	S:			Tube material:					
				Tube length:					
Channel thickness:				Channel material:					
Shell: 50 PSI   Design pressure				Operating pressure		Shell:	0 – 160 PSI		
Tubes:						Tubes:			
Shell: 149 Deg F Design Temp.				Operating temp	erature	Shell:	20 – 240 Deg	F	
Tubes:						Tubes:			
X-ray: RT 2		Heat treatment: no							
Code parameters: A	ASME VIII, Div 1	Coated: yes							
Manufacturer: Alco	o Gas & Oil	Year built: 1985							
Corrosion allowand	ce: 3.2mm	Manway: yes							
	Pl	RESSURE SAFETY	VALV	E NAMEPLATI	E DATA				
PSV Tag #	Manufacture	Model #		Serial #	Set Pressure		Capacity	Service	
					(kPa)		(scfm)	Date	
G17665	Consolidated	1905HCI		84C2627	50 PSI		2788	4/05	
CRN #	Service By	Block Valve		Location	Size		Code Stamp		
01832.568312	Tyco Black Gold	No		top shell	1.5"x 3"		UV		
	SERV	VICE CONDITIONS	S-INDI	ICATE ALL TH	AT APPL	Y			
Sweet X	Sour Oi			1 X		Gas X		Water X	
Amine	e LPG Con			densate X	Air Glycol		Glycol		
Other (Describe):									
Inspection Interval PSV Service Interval									
(Determined by MIC in conjunction with Chief Inspector following guidelines of CNRL's Owner-User Inspection Program)									
Reports reviewed and accepted by: Mechanical Integrity CoordinatorDate									

Fill out all forms as completely as possible. <u>All information</u> is important! Use back of sheets to record additional information or sketch if required. Copy of report to be filed by MIC at site, and copy sent to Chief Inspector

External Inspection Items	G	F	Р	N/A	Comments
<b>Insulation</b> Verify sealed around manways, nozzles, no damage present, and there is no egress of moisture.	x				50% of vessel insulated – no damage present-no egress of moisture – sealed around skid building and nozzles
<b>External Condition</b> Assess paint condition, areas peeling, record any corrosion, damage, etc (record location, size and depth of corrosion or damage)	x				Paint in good overall condition – no exposed metal.
<b>Leakage</b> Record any leakage at flanges, threaded joints, weep holes on repads, etc.		x			Leakage at piping and valve threaded joints – all small bore items.
<b>Saddle/Skirt</b> Assess condition of paint, fire protection, concrete. Look for corrosion, buckling, dents, etc. Look at vessel surface area near supports. Verify no signs of leakage at attachment to vessel and attachment welds are acceptable. Ground wire attached?	x				Saddle: Bolted directly to skid deck. No buckling or dents to saddle – no corrosion at attachment welds to vessel. Paint in good condition – no exposed metal Ground wire attached to skid.
Anchor Bolts Hammer tap to ensure secure. Look for cracking in treads or signs of deformation.	x				Anchor bolts are securely fastened. No deformation
<b>Concrete foundation</b> Check for cracks, spalling, etc.				X	
<b>Ladder / Platform</b> Describe general condition, ensure support is secure to vessel, describe any hazards.				X	
<b>Nozzle</b> Assess paint, look for leakage, and ensure stud threads are fully engaged. Record any damage, deflection, etc. Are nozzles gusseted?	x				Threaded nozzle joints are fully engaged. No leaks observed. No damage or deflections. Nozzles are not gusseted
<b>Gauges</b> Ensure gauges are visible, working, no leakage, and suitable for range of MAWP/ Temp.	x				Gauge is clear and clean. No leakage. Suitable for range of MAWP of vessel. Temperature gauge: 20 – 240 Deg F Pressure gauge: 0 – 160 PSI
<b>External Piping</b> Ensure pipe is well supported. All clamps, supports, shoes, etc. in place. Look for evidence of structural overload, deflection, etc. Paint condition, external corrosion?	x				Piping is well supported – all clamps and supports are in place. No structural overloads or deflections. Paint in good condition – no exposed metal Leakage at threaded joints
<b>Valving</b> Ensure no leaks are visible. Valves are properly supported and chained if necessary.		x			Leaks are visible at valve. Valves are supported properly
<b>PSV</b> Ensure PSV is set at pressure at or below that of vessel.	x				Located on top shell – set at MAWP of vessel. PSV sent out for servicing at this time. Discharge piping is same size as valve outlet – found plugged with hydrate – cleaned out. PSV seal in place – no block valve between vessel and PSV.

<b>NDE methods</b> Was UT/ MPI done on vessel (MI coordinator to review results)	X		Ultrasonic thickness survey carried out – piping metal thickness detected below nominal. Calculations carried out to ensure sufficient metal exists for safe operation.
Other	X		Vessel over pressured – operator saw PSV inlet and discharge piping froze up causing over pressure of vessel

# **Recommendations or corrective actions : Vessel is Fit for Service or describe corrective actions required)** (MIC to review corrective actions with Operations, discuss with Chief Inspector where necessary, and get remedial action implemented)

#### Recommendations: Seal all leaking pipe and valve joints identified with leaks.

**Summary:** Vessel is in overall good condition, visual external, ultrasonic corrosion survey performed, and magnetic particle inspection carried out on all nozzles.


- 1. Ultrasonic thickness inspection piping metal thickness detected below nominal. Calculations carried out to ensure sufficient metal exists for safe operation.
- 2. Magnetic Particle inspection carried out on all nozzle welds no cracking detected.
- 3. Visual external and surface measurements showed no signs of distortion, some leaking at small diameter valves it is unknown as to condition of valves prior to over pressure incident. PSV discharge piping detected with hydrate blockage identified as primary source of over pressure condition 160 PSI.

Vessel is fit for service.

## Inspected By: Gerry Avery

### Date: January 21, 2008

## Photo Table



leak at valve	pipe threads leaking
vessel overview	