Canadian Natural Resources Limited GENERAL PRESSURE VESSEL INFORMATION Job # 10.110039													
District: Fort St.	John, B.C.			Skid No.									
	Compressor Station		Location (LSD): d-62-C/94-A-16										
Vessel Name Equipment Number: Glycol Contactor													
Orientation: Vertical													
Status: In Service Regulatory Inspection													
PRESSURE VESSEL NAMEPLATE DATA													
"A" or "G" or "S"		CRN Number <b>M-2316.21</b>											
Vessel serial num			Size: 23 in X 32 ft										
Shell thickness: 2		Shell material: SA 516 70MT											
Head thickness: 3 Tube wall thickness			Head material: SA 516 70MT Tube material:										
Tube diameter:	233.		Tube length:										
Channel thicknes	s:			Channel material:									
MAWP	Shell: 1440 PSI					Shell:							
	Tubes:				Tubes:								
Design Temp.	Shell: 130 deg F			Operating temperature		Shell:							
	Tubes:			Tubes:									
X-ray: RT-1			Heat treatment: Yes										
Code parameters:		Coated:											
Manufacturer: W Corrosion allowa		Year built: 1995 Manway: No											
Corrosion uno wa		RESSURE SAFETY	VALVE		DATA								
PSV Tag #	Manufacture	Model #		Serial # Set		essure	Capacity	Service					
						SI)	(scfm)	Date					
9264F	Farris	26EA13-120	480467-4-A10		1400		5501	09/05					
CRN #	Service By	Block Valve	I	Location	Size		Code Stamp						
0G8842.5C	Farris	No	Lower Shell		1" X 2"		UV/NB						
SERVICE CONDITIONS-INDICATE ALL THAT APPLY													
Sweet	Sour X	Sour X Oi			il		ζ	Water X					
Amine	LPG Co.			ondensate Air				Glycol X					
Other (Describe):													
Inspection IntervalPSV Service Interval  (Determined by MIC in conjunction with Chief Inspector following guidelines of CNRL's Owner-User Inspection Program)  Reports reviewed and accepted by:													

<b>External Inspection Items</b>		_	_	>T/A	Comments
	G	F	P	N/A	
<b>Insulation</b> Verify sealed around manways, nozzles, no damage present, and there is no egress of moisture.				X	No insulation.
External Condition Assess paint condition, areas peeling, record any corrosion, damage, etc (record location, size and depth of corrosion or damage)	X				Paint is in good overall condition – little to no external surface corrosion or exposed metal.
<b>Leakage</b> Record any leakage at flanges, threaded joints, weep holes on repads, etc.	X				No leaking detected.
Saddle/skirt Assess condition of paint, fire protection, and concrete. Look for corrosion, buckling, dents, etc. Look at vessel surface area near supports. Verify no signs of leakage at attachment to vessel and attachment welds are acceptable. Ground wire attached?	X				Skirt is in good condition – no buckles or distortion.  Paint intact – with little to no corrosion.  Vessel grounded at the skid.
Anchor Bolts Hammer tap to ensure secure.  Look for cracking in treads or signs of deformation.	X				Firmly secured. No signs of deformation.
Concrete foundation Check for cracks, spalling, etc.				X	None.
<b>Ladder / Platform</b> Describe general condition, ensure support is secure to vessel, and describe any hazards.				X	None.
Nozzle Assess paint, look for leakage, and ensure stud threads are fully engaged. Record any damage, deflection, etc. Are nozzles gusseted?	X				All threads engaged. No deflection – no leaks. No gussets. Painting good overall condition.
Gauges Ensure gauges are visible, working, no leakage, and suitable for range of MAWP/ Temp.	X				Gauge is visible, working, and suitable for range of Temp/MAWP.  Temperature gauge: 0 to 250 deg F.  Pressure gauge: 0 – 3000 PSI.  Site glasses are intact and transparent.
<b>External Piping</b> Ensure pipe is well supported. All clamps, supports, shoes, etc. in place. Look for evidence of structural overload, deflection, etc. Paint condition, external corrosion?	X				Well supported – no deflection – all clamps and shoes in place.  Piping is painted and is in good overall condition with some minor paint chips having minimal corrosion at exposed metal.
Valving Ensure no leaks are visible. Valves are properly supported and chained if necessary.	X				Well supported – no leaks.
<b>PSV</b> Ensure PSV is set at pressure at or below that of vessel.	X				Located on Lower Shell, set below MAWP. Seal intact – No block valve. Outlet piping same size as orifice.
NDE methods Was UT/ MPI done on vessel (MI coordinator to review results)	X				Ultrasonic corrosion survey carried out, no metal thickness detected below nominal minus corrosion allowance.

Recommendations or corrective actions: Vessel is Fit for Service or describe corrective actions required)

(MIC to review corrective actions with Operations, discuss with Chief Inspector where necessary, and get remedial action implemented)

**Recommendations:** Service PSV.


**Summary:** This vessel is in good condition, visual external and ultrasonic thickness inspection carried out – no metal thickness detected below nominal minus corrosion allowance.

Short term corrosion rate based on greatest thickness loss (head) 0.40 mm per year. Retirement Date to "T"min is year 2033.

Vessel is fit for service.

Inspected By: Brent Agrey Date: March 14, 2011





Overview

LSD Data Plate



Overview








Pressure gauge



Temperature gauge



Site glass



Paint chips on attached piping



PSV data tag

PSV ID tag