Canadian Natural Resources Limited GENERAL PRESSURE VESSEL INFORMATION Job # 105.00151									
District: Grande P	Skid No.								
Facility: Bonanza	Location (LSD): 13-34-81-11W6M								
	pment Number: Glyco	ol Contactor		·	-				
Orientation: Verti									
Status: In Ser				Regulatory In	nspection				
		PRESSURE VESS	SEL N						
"A" or "G" o	CRN Number:								
	M-2316.21								
Vessel serial numbe	Size: 24 in. X 30 ft.								
Shell thickness: 28.	Shell material: SA 516-70								
Head thickness: 27.	Head material: SA 516-70								
Tube wall thickness	Tube material:								
Tube diameter:	Tube length:								
Channel thickness:				Channel material:					
Design pressure Shell: 1440 PSI				Operating press	sure	Shell: 0 – 1500 PSI			
	Tubes:			Tubes:					
Design Temp	Shell: 130 Deg. F	Operating temperature		Shell: 0 – 250 Deg F					
Design Temp.	Tubes:			Tubes:					
X-ray: RT 1				Hoot trootmont:	ЦΤ	10005	•		
Code parameters: A	Heat treatment: HT Coated: no								
Manufacturer: Well	Year built: 1997								
Corrosion allowance	Manway: no								
		RESSURE SAFETY	VALV		E DATA				
PSV Tag #	Manufacture	Model #		Serial #	Set Pre	essure	Capacity	Service	
15 V 14g #	Wanufacture	Widder #		Seriar #	(kPa)				
							(scfm)	Date	
5501G	Farris	26FA13-120	CI	E43148-2-A10	1200 PSI		7774	09/2007	
CRN #	Service By	Block Valve		Location	Size		Code Stamp		
OG 2369.52	Unified valve	No]	Lower shell	1.5"x 2"		UV/NB		
	SERV	VICE CONDITIONS	S-INDI	ICATE ALL THA	AT APPL	Y			
Sweet X	Sweet X Sour O		Oil	1		Gas X		Water	
Amine LPG Con			Con	densate Air		Air		Glycol	
Other (Describe):									
Inspection Interva	ıl			PSV Service Int	terval				
-	conjunction with Chief Insp	pector following guidelines	s of CNR)			
Reports reviewed and ac Mechanical Integr					D	ate			

Fill out all forms as completely as possible. <u>All information</u> is important! Use back of sheets to record additional information or sketch if required. Copy of report to be filed by MIC at site, and copy sent to Chief Inspector

External Inspection Items		F	Р	N/A	Comments
Insulation Verify sealed around manways, nozzles, no damage present, and there is no egress of moisture.	x				No damage present- no egress of moisture. All metal cladding and straps in place and secure -sealed around nozzles.
External Condition Assess paint condition, areas peeling, record any corrosion, damage, etc (record location, size and depth of corrosion or damage)	x				Paint in good overall condition – No exposed metal.
Leakage Record any leakage at flanges, threaded joints, weep holes on repads, etc.	X				No leaks observed.
Saddle/Skirt Assess condition of paint, fire protection, concrete. Look for corrosion, buckling, dents, etc. Look at vessel surface area near supports. Verify no signs of leakage at attachment to vessel and attachment welds are acceptable. Ground wire attached?	x				Skirt: Bolted directly to skid floor. No buckling or dents. No corrosion at attachment welds to vessel. Ground wire attached to skid.
Anchor Bolts Hammer tap to ensure secure. Look for cracking in treads or signs of deformation.	x				Anchor bolts are securely fastened. No deformation.
Concrete foundation Check for cracks, spalling, etc.				X	
Ladder / Platform Describe general condition, ensure support is secure to vessel, describe any hazards.				X	
Nozzle Assess paint, look for leakage, and ensure stud threads are fully engaged. Record any damage, deflection, etc. Are nozzles gusseted?	x				Stud threads are fully engaged to nuts- no short bolting. No damage or deflections – no leaks. Nozzles are not gusseted.
Gauges Ensure gauges are visible, working, no leakage, and suitable for range of MAWP/ Temp.	x				Clear and clean – no leakage. Suitable for operational range of vessel. Pressure gauge 0 – 1500 PSI. Temperature gauge 0 – 250 Deg F.
External Piping Ensure pipe is well supported. All clamps, supports, shoes, etc. in place. Look for evidence of structural overload, deflection, etc. Paint condition, external corrosion?	x				Piping is well supported; no deflection, all clamps and supports are in place. Paint in good condition – no exposed metal.
Valve: Ensure no leaks are visible. Valves are properly supported and chained if necessary.	X				Valves are supported properly – no leaks.
PSV Ensure PSV is set at pressure at or below that of vessel.	x				Located on lower shell of vessel. Set below MAWP of vessel – PSV seal in place. Discharge piping is same size as valve outlet. No block valve between vessel and PSV.
NDE methods Was UT/ MPI done on vessel (MI coordinator to review results)	x				Ultrasonic thickness survey carried out – shell and pipe metal thickness detected below nominal minus corrosion allowance. Critical thickness calculations carried out to ensure sufficient metal exists for safe operation.
Other					ensure sufficient metal exists for safe operation.

Recommendations or corrective actions : Vessel is Fit for Service or describe corrective actions required) (MIC to review corrective actions with Operations, discuss with Chief Inspector where necessary, and get remedial action implemented)

Recommendations: No recommendations at this time.

Summary: Vessel is in overall good condition, visual external inspection and ultrasonic corrosion survey performed – shell and pipe metal thickness detected below nominal minus corrosion allowance. Critical thickness calculations carried out to ensure sufficient metal exists for safe operation.

Vessel is fit for service.



