

A0445441 - CONTACTOR INSPECTION - JAN 2001

1060-04

Canadian Natural Resources Limited  
Production - Facilities Engineering  
A0445441 Vertical Contactor Certificate of Inspection

Content Date Range: 1/16/2001 to 1/16/2001

Vessel Integrity

Inspection Data

Open: 1/22/2007 Close:

CC+2 0P P



00758183

Vital: Yes  
Original: Yes  
Confidential: No

# Certificate of Inspection

BERKLEY PETROLEUM CORP.  
1250, 202 - 6 AVENUE SW  
  
CALGARY, AB  
T2P 2R9

PREFERRED RE-INSP. INTERVAL: 4.00 Yr.

YEAR BUILT: 1999  
CRN: L7735.2  
SERIAL #: 99-135C

LOCATION: LSD 9-22-58-24 W5M (COLT) *wild by*  
DESCRIPTION: VERTICAL CONTACTOR  
COMPANY CODE:  
MANUFACTURER: ORBAN INDUSTRIES LTD

VOLUME: 4.6 M3  
HEATING SURFACE:  
SURFACE AREA:  
Safety Valves

PART	MAX. AUTHORIZED WORKING PRESSURE	MAX. TEMP	MIN. TEMP	VALVE ID	SETTING	CAPACITY	LOCATION
VESSEL	12409 KPA	66 C	-29 C	SV1	12409 KPA	496 M3/MIN	

**OWNER INSTRUCTIONS/REMARKS:**

PRESSURE RELIEF VALVE TO BE SERVICED BY AN AUTHORIZED SAFETY VALVE SERVICING COMPANY EVERY FOUR YEARS.

Safety Codes Officer: MCDONALD, GLEN

Signature: *Glen McDonald*

**NOTE: REQUIREMENTS OF THE SAFETY CODES ACT AND THE REGULATIONS ISSUED THEREUNDER:**

The owner or person in charge shall report all accidents involving a boiler, pressure vessel or pressure piping system to the district Safety Codes Officer immediately and shall send a full report in writing to the Administrator as required by the Act. No repairs or alterations may be made unless authorized by a Safety Codes Officer.