



Client	Canadian Natural Resources Ltd.	LSD	05-03-063-11W6	Location	Narraway
Provincial Reg #	A457189	Inspection Date	09-Apr-2015	Next Inspection Date	DD-MM-YYYY
Equipment Type	Line heater	Inspection Type	VE	Next Insp. Type	
Manufacturer	Maloney Industries Inc	Vessel Status	Not In Service		
Unit #	Line Heater Building	Tag #		NB Stamp	No
Serial #	CC-C4936-3001	CRN #	K1237.12	Year Built	2000
MAWP	30000 KPA @ 93 C	MDMT	-40 C	@ 30000 KPA	Coil 1 (A) 3"
MAWP	13962 KPA @ 93 C	MDMT	-40 C	@ 13962 KPA	Coil 2 (B) 6"
MAWP	13962 KPA @ 93 C	MDMT	-29 C	@ 13962 KPA	Coil 3 (C) 2" (Hot Oil)
Shell Material		Shell Thickness	0.6 in	CA	0.0625 in
Diameter		Length		Vessel Orientation	Horizontal
Head Material		Head Thickness		CA	
ASME STAMP	B31.3	Foreman	Dan Morrison	Service	Sweet

PSV Tag #	See Notes	Service Company		Model #/Type	
CRN#		Set Pressure		Capacity	
Manufacturer		Serial Number		ASME Stamp	
Inlet Size		Outlet Size		Service Date	
Valve Location		PSV Vents to		Valve Connection	

Piping

Are mechanical connections acceptable for service?	Acceptable	Dead Legs	No
Covering	Coated	Condition	Acceptable
Piping Supported Adequately	Yes		

PSV (see notes)

PSV Service Report Available	No	Installation Vertical	Yes	PSV Block Valve	No
Block Valve car Seal in Place	N/A	Car Seal Log Book Maintained	N/A		
Drainage	Acceptable	Supports	Acceptable	Bolting	Acceptable
Gaskets	Acceptable	Seal Wire	Acceptable	Service Tag	Acceptable
Set pressure	Acceptable	CRN	Acceptable		

External

Certificate of Inspection Permit	No	Nameplate - Attached & Legible	Yes	Grounded	Yes		
CUI Checked	Yes	Attachments	No	Manway	No		
Size		Manway Davit Arms	Free to Move	N/A	Carry Bolt w/Washer & Double Nuted	N/A	
Lubricated	N/A	Installation	Partial	Drains	Manual	Ladders and Platforms	Acceptable
Support Structure	Acceptable	External Covering	Acceptable				

Based on the scope and results for this inspection, after all noted issue(s) have been resolved to meet the current code requirements, this vessel will be fit for service.

Additional Comments	RT 100% on coil 1&2, 10% on coil 3. Recommend a thorough inspection if vessel is to be put back into service.				
PSV notes...	- Coil 1 & 2 PSV's inside the building and were acceptable - Coil 3 psv in the injection building on the discharge of the 'Heat String' circulation pump and was acceptable. - All PSV's will require service if vessel is put back in service.				
Highest Corrosion Rate of	N/A	at TML#	N/A		
Remaining Life	N/A	at TML#	N/A		





Figure 1: Vessel Overview



Figure 2: Vessel Nameplate 1




Figure 3: inlet - spool removed



Figure 4: Coil 1 PSV



Figure 5: Coil 1 PSV service tag side A



Figure 6: Coil 1 PSV service tag side B



Figure 6: Coil 2 PSV




Figure 7: Coil 2 PSV service tag side A




Figure 8: Coil 2 PSV service tag side B



Figure 9: Coil 3 PSV service tag side A