

A0475155_HEATER INSPECTION_SEP 2001

Canadian Natural Resources Limited
Production - Facilities Engineering
A0475155 Indirect Fired Heater Coil Certificate of
Inspection

1060-04

Content Date Range: 9/17/2001 to 9/17/2001

Vessel Integrity

Inspection Data

Open: 1/23/2007 Close:

CC+2 0P P



00758583

Vital: Yes
Original: Yes
Confidential: No

Certificate of Inspection

*SADDLE HILLS
11-33-75-7-W6*

ANADARKO CANADA CORPORATION
PO BOX 2595 STN M
425-1 STREET SW
ATTN TERRY MCCONNELL
CALGARY, AB
T2P 4V4

PREFERRED RE-INSP. INTERVAL: Yr.

YEAR BUILT: 2001

CRN: K1977.12

SERIAL #: 126-87-01-C

LOCATION: CALGARY (STOCK)

VOLUME: 0.13 M3

DESCRIPTION: INDIRECT FIRED HEATER COILS

HEATING SURFACE: 10.75 M2

COMPANY CODE:

SURFACE AREA:

MANUFACTURER: MAR-QUINN INDUSTRIES LTD.

Safety Valves

PART	MAX. AUTHORIZED WORKING PRESSURE	MAX. TEMP	MIN. TEMP	VALVE ID	SETTING	CAPACITY	LOCATION
COIL 1	20340 KPA	93 C	0 C	SV1			TO BE INSTALLED
COIL 2	13962 KPA	93 C		SV2			TO BE INSTALLED

OWNER INSTRUCTIONS/REMARKS:

NOT SUBJECT TO ANNUAL FEES AS PER REGULATIONS PART 4 SECTION 28 (h)
DIRECT OR INDIRECT FIRED OIL AND GAS PROCESS HEATERS OF THE COIL TYPE;

VERIFY THAT VESSEL/BOILER IS PROTECTED BY AN ACCEPTABLE ASME CODE PRESSURE RELIEF VALVE, OF ADEQUATE CAPACITY, SET AT NO MORE THAN MAXIMUM PRESSURE AUTHORIZED AND INSTALLED IN ACCORDANCE WITH THE SAFETY CODES ACT & REGULATIONS.

VESSEL/BOILER TO BE INSTALLED IN ACCORDANCE WITH THE SAFETY CODES ACT AND REGULATIONS.

OWNER TO VERIFY INTEGRITY OF VESSEL BY PERIODIC INSPECTION PROGRAM.

Safety Codes Officer: DENYS, METRO

Signature: *M Denys*

REQUIREMENTS OF THE SAFETY CODES ACT AND THE REGULATIONS ISSUED THEREUNDER:

The owner or person in charge shall report all accidents involving a boiler, pressure vessel or pressure piping system to the district Safety Codes Officer immediately and shall send a full report in writing to the Administrator as required by the Act. No repairs or alterations may be made unless authorized by a Safety Codes Officer.