Canadian Natural Resources Limited GENERAL PRESSURE VESSEL INFORMATION Job 10.180192													
District: Fort St		Skid No.											
Facility: Thunder Creek Compressor Station					Location (LSD): d-31-H/93-I-15								
Vessel Name & Equipment Number: Line Heater													
Orientation: Ver	• •												
		<b>Regulatory Inspection</b>											
Status:     Operating     Regulatory Inspection       PRESSURE VESSEL NAMEPLATE DATA													
"A" or "O		CRN Number											
						P 9412.132							
A0528515 Vessel serial number: BW 336.003						Size: 48 in. OD x 15 ft. S/S							
Shell thickness: 9.5 mm					Shell material: SA 36								
Head thickness: 9.5 mm					Head material: SA 36								
Tube wall thickness:						Tube material:							
Tube diameter:						Tube length:							
Channel thickness:						Channel material:							
Design pressure	Shell: 4651 kPa	Shell: 4651 kPa				Operating pressure			Shell:				
	Tubes:	Tubes:								Tubes:			
Design Temp.	Shell: 38°C				Operating temperature			Shell:					
	Tubes:							Tubes:					
X-ray: RT 1					Heat treatment: Nil								
Code parameters: ASME B 31.3					Coated: No								
Manufacturer: Brooks Welding					Year built: 2005								
Corrosion allowance: 1.6 mm						Manway: No							
	P	RESSURE SAFI	ETYV	VALVE	NAM	IEPLATE DA	ТА						
PSV Tag #	Manufacturer /Model / Serial number			Capacity (Scfm/ usgpm)		Size	Block Valve		Location	Serv by / Date			
TCCS 020/         Mercer/8142251T23         4964 kPa         5816           21767G         NS /140256         5816         5816				16 scfm		2 X 2	No		Outlet Piping	Unified 06/23/2016			
	SER	VICE CONDTI	ONS-	-INDICA	ATE A	ALL THAT A	PPLY	Y					
Sweet X Sour C			Oil	Dil			Gas X		Water X				
Amine LPG Con				Conder	ndensate X			Air		Glycol			
Other (Describe	):												

## Inspection Interval \_\_\_\_\_

## \_PSV Service Interval\_\_\_\_

(Determined by MIC in conjunction with Chief Inspector following guidelines of Canadian Natural Resources Limited Owner-User Inspection Program)

Reports reviewed and accepted by: Mechanical Integrity Coordinator\_\_\_\_\_\_Date\_\_\_\_\_

Fill out all forms as completely as possible. <u>All information</u> is important! Use back of sheets to record additional information or sketch if required. Copy of report to be filed by MIC at site, and copy sent to Chief Inspector

External Inspection Items		F	Р	N/A	Comments
<b>Insulation:</b> Verify sealed around man ways,	X				Vessel is fully insulated – no open or torn sections. No
nozzles, no damage present, and there is no					evidence of wet insulation – no stains.
egress of moisture.					
External Condition: Assess paint condition,	Х				Paint in good condition – no exposed metal.
areas peeling, record any corrosion, damage,					
etc (record location, size and depth of					
corrosion or damage)					
Leakage: Record any leakage at flanges,	Х				No leaks detected.
threaded joints, weep holes on repads, etc.					
Saddle: Assess condition of paint, fire					Saddle: This line heater is mounted on pilings and supports
protection, concrete. Look for corrosion,	Х				- no distortion to saddle – no evidence of leaking at saddle
buckling, dents, etc. Look at vessel surface					to shell area.
area near supports. Verify no signs of leakage					
at attachment to vessel and attachment welds					
are acceptable. Ground wire attached?					Skid is grounded.
Anchor Bolts: Hammer tap to ensure	Х				Firmly bolted to skid deck.
secure. Look for cracking in treads or signs of	Λ				r niny bolteu to skiu ueck.
deformation.					
Concrete foundation: Check for cracks,				Х	
				А	
spalling, etc.				37	
Ladder / Platform: Describe general				Х	
condition, ensure support is secure to vessel,					
describe any hazards.					
Nozzle: Assess paint, look for leakage, and	Х				All studs fully engaged to nuts – no short bolts.
ensure stud threads are fully engaged. Record					No deflection, no leaking detected.
any damage, deflection, etc. Are nozzles					No gussets.
gusseted?					
Gauges: Ensure gauges are visible, working,	Х				Pressure gauge: 0 to 200 kPa.
no leakage, and suitable for range of MAWP/					Pressure gauge: 0 to 1000 kPa.
Temp.					
External Piping: Ensure pipe is well	Х				Well supported, no deflection, all clamps in place.
supported. All clamps, supports, shoes, etc. in					Paint is in god condition – no corrosion.
place. Look for evidence of structural					
overload, deflection, etc. Paint condition,					
external corrosion?					
Valving: Ensure no leaks are visible. Valves	Х				Firmly supported – no leaks.
are properly supported and chained if					Junif
necessary.					
<b>PSV:</b> Ensure PSV is set at pressure at or			Х		Located on Discharge Piping, set above MAWP of gas coil.
below that of vessel.					Seal is intact. No block valve.
					Discharge piping is same size as outlet orifice.
<b>NDE methods:</b> Was UT/ MPI done on vessel	X				Ultrasonic thickness survey carried out – no metal
(MI coordinator to review results)	Λ				thickness detected below nominal minus corrosion
(in coordinator to review results)					allowance.
Recommendations or corrective actions: (Ve	L	<b>T</b> <sup>4</sup>			

**Recommendations or corrective actions: (Vessel is Fit for Service or describe corrective actions required)** (MIC to review corrective actions with Operations, discuss with Chief Inspector where necessary, and get remedial action implemented)

Recommendations: Reset PSV at or below MAWP of gas coil.

Summary: This vessel is in good condition, visual external and ultrasonic thickness inspection carried out – no metal thickness detected below nominal minus corrosion allowance.
Vessel is fit for Service.

Inspected By: Dellas Wiedman A. J. S. API 20981 / IBPV 275

**Date:** July 24<sup>th</sup>, 2018



