



Mountain West Services Ltd.

## PSV Inventory

[www.mtnwest.ca](http://www.mtnwest.ca) [\[Company Index Page\]](#) [\[Vessels\]](#) [\[Pipelines\]](#) [\[SMART\]](#) [\[Incidents\]](#) [\[Work Orders\]](#) [\[Management of Change\]](#)

### FLD2337

<b>Status:</b>	In Service	<b>Back Pressure:</b>	0 PSI -- 27579.2 KPa
<b>LSD:</b>	<a href="#">06-08-069-21W5</a>	<b>Inlet Size:</b>	1 IN -- 25.4 MM
<b>District/Unit:</b>	STURGEON LAKE	<b>Outlet Size:</b>	1 IN -- 25.4 MM
<b>Location:</b>	STURLS	<b>Capacity:</b>	44 GPM -- 166.56 L/min
<b>Skid/Equipment Number:</b>	PKG55539	<b>Inlet Block Valves:</b>	No Locked Open?: NA
<b>CRN:</b>	OG0386.9C	<b>Outlet Block Valves:</b>	No Locked Open?: NA
<b>Make::</b>	FARRIS	<b>Process:</b>	SWEET
<b>Model:</b>	27CA33-M20	<b>ANSI Rating Inlet:</b>	MNPT
<b>Code Stamp:</b>	UV	<b>ANSI Rating Outlet:</b>	FNPT
<b>Serial Number:</b>	543020-21-KE	<b>Location on Vessel:</b>	+ 10 ' OUTLET PIPING OFF LINEHEATER, ABOVE ROOF
<b>Set Pressure:</b>	580 PSI -- 3998.98 KPa		

[\[Click here for extended PSV data\]](#)

### List of Service Reports:

<b>Last Inspection:</b> 11/18/2008	<b>Inspecting Company:</b> IDEAL PRECISION VALVE	<b>Condition:</b> New
<b>Service Interval:</b> 60	<b>Company Reference No.:</b> FLD2337	<b>Service:</b> Sweet
<b>Next Inspection:</b> 11/18/2013	<b>Technician Name:</b>	<b>Installed:</b> 3/1/2009
<b>Pre-Test:</b> No	<b>Pre-Test Results:</b>	
<b>Comments:</b>		

<b>Last Inspection:</b> 5/26/2011	<b>Inspecting Company:</b> KINGS	<b>Condition:</b> Good
<b>Service Interval:</b> 60	<b>Company Reference No.:</b> 34505	<b>Service:</b> Sweet
<b>Next Inspection:</b> 5/26/2016	<b>Technician Name:</b>	<b>Installed:</b> 3/1/2009
<b>Pre-Test:</b> Yes	<b>Pre-Test Results:</b> Pass	
<b>Comments:</b>		

Prepped @ 4000 kpa, Seal intact. Data plate - original. Inlet and outlet - dirty, Valve converted - no. Valve replaced - no. Set pressure changed - no. Disassembled and inspected - required disc & gaskets, nozzle required machining. Cleaned, assembled, set and tested. Leakage rate - passed BPM @ 522 psi. Back pressure tested to 50 psi. Painted, taped, sealed, integral tested, paper work completed. Prepared for shipping.

---

## Pictures and Attachments

---

---

## This PSV Protects Vessels:

---

[Vessel Number: 2825892 - LINE HEATER - Side: Coil1 - Primary: YES](#)

[Vessel Number: 2825892 - LINE HEATER - Side: Coil2 - Primary: YES](#)

---

## NCRs:

---

---

## Material Transfer Orders:

---

---

## Satellite Images Found:

---

[\[Click Here For Satellite Picture\]](#)

Record Entered: 2/6/2010 Record Last Updated: 9/17/2011

[\[Back To Start Page\]](#) [\[MtnWest.Ca\]](#)