

Imperial Oil Resources
1911 Broadway Ave.
Redcliff, AB
T0J 2P0

April 17, 2009

Attention: **Greg Compton**

Re: **Ultrasonic Corrosion Survey of Redcliff South Compressor Station**

Dear Sir:

As requested, an Ultrasonic Corrosion Survey was performed on several vessels at the Redcliff South Compressor Station on October 8 and 9, 2008. The **Item List** summary contains a list of all vessels that were inspected during this time. The equipment used for the inspection consisted of a Krautkramer DMS-2 Ultrasonic Instrument in conjunction with a Krautkramer KBA FH2E, $\frac{1}{4}$ " dia., 5 MHz dual element transducer.

Results of the inspection found no indications of internal corrosion to be occurring and all areas appear to be in good condition. Please refer to the **Condition Indicator**, **Graphs**, and **Comment List** sections of the report for a brief summary of the inspection. The data pages contain all the information necessary for your own evaluation of the data.

All static vessel information in the report was obtained from the vessel nameplates during this and previous inspections. Several blanket assumptions have been made in the report. All piping and fittings are assumed to be either SA-106B or SA-234WPB material with a Joint Efficiency of 1.00 and with the same operating pressure and temperature as the associated vessel, and a Corrosion Allowance of .063" has been assumed for vessels and piping when none is listed on the vessel nameplate. Also, all piping associated with a vessel is assumed to have been manufactured at the time of the vessel. All static vessel information and all manufacture dates (or in-service dates) in the report should be confirmed as correct. Any areas where static vessel information is missing from the report, or where the nameplate information is incorrect, can be incorporated into the report if you let me know.

In accordance with Imperial Oil Policy, the critical thickness listed in this report and used for the calculations of Life Expectancies are based on the nominal thickness less the corrosion allowance. Therefore, the Life Expectancies in the report should only be used as a general guide and may or may not be entirely accurate. The **Condition Indicator** summary includes all items that have a calculated life expectancy of less than 100 years. All items with life expectancies greater than 100 years have not been included. Items with life expectancies of less than 10 years will be highlighted in yellow and any items with a remaining thickness below the critical thickness will be highlighted in red. Also, graphs

have been prepared showing various corrosion rates, minimum thickness, and actual point thickness for all items with life expectancies of less than 10 years.

Please refer to the **Condition Indicator, Graphs, and Comment List** sections of the report for a brief summary of the inspection. The data pages contain all the information necessary for your own evaluation of the data.

I hope this report meets with your approval and should you have any questions, please contact me at our office at your convenience.

Sincerely,



Maria Savulescu
CGSB II/SNT II

SUMMIT Inspection Services Ltd.



Imperial Oil Resources
1911 Broadway Ave.
Redcliff, AB
T0J 2P0

November 17, 2003

Attention: **Bob Adrian**

Re: **Baseline Ultrasonic Corrosion Survey of Redcliff South Compressor Station**

Dear Sir:

As requested, a Baseline Ultrasonic Corrosion Survey was performed on all Vessels and Compressor Bottles at the Redcliff South Compressor Station on November 4 and 5, 2003. The equipment used for the inspection consisted of a Krautkramer DMS-2 Ultrasonic Instrument, in conjunction with a KBA FH2E, 1/4" dia., 5 MHz, dual element transducer.

The inspection involved taking Ultrasonic Thickness readings in various locations on vessels, bottles, coolers, and associated piping at the Compressor Station to look for indications of internal corrosion and determine the overall condition of the equipment. In addition to the Ultrasonic Corrosion Survey, an MPI inspection was performed on all nozzles, couplings, and welds on the Unit #1 and Unit #2 Compressor Bottles and Coolers. Please refer to the MPI report located under the **MISC.** tab for details on the MPI inspection.

Results of the Ultrasonic Corrosion Survey found no indications of significant internal corrosion problems in any of the areas inspected and all areas appear to be in good condition. Three bands (860, 862, and 866) on the Unit #1 Compressor E-301 1st Stage Discharge Cooler (bottom) are highlighted in yellow with a life expectancy below 10 years on the **CONDITION INDICATOR** summary. This is due to the readings being slightly below the assumed nominal thickness and the fact the cooler was built in 2003. Please ignore the life expectancies for these three bands as there are no indications of internal corrosion occurring. The nominal thickness of 1.000" is assumed for the cooler and should be confirmed. Please refer to the **CONDITION INDICATOR**, and **COMMENT LIST** summaries in the report for further details on this and other areas of the inspection. The data pages found under the TAB associated with each vessel contain all the information necessary for your own evaluation of the data.

The critical thickness listed in the report and used for the calculations of Life Expectancies are 2/3 nominal thickness as per Imperial Oil policy. Therefore, the Condition Indicator values in the report should only be used as a general guide and may or may not be entirely accurate. The only blanket assumption made in the report is all piping is assumed to be SA 106 B material with a Joint Efficiency of 1.00 and with the same operating pressure and temperature as the associated vessel. However, since no

Code Calculations are being performed, this has no impact on any of the summaries in this report. Also, all piping associated with a vessel is assumed to have been manufactured at the same time as the vessel. Any areas where static vessel information is missing from the report, or where the nameplate information is incorrect, can be incorporated into the report if you let me know.

The **CONDITION INDICATOR** summary includes all items that have a calculated life expectancy of less than 100 years. All items with life expectancies greater than 100 years have not been included. Items with life expectancies of less than 10 years will be highlighted in yellow and any items with a remaining thickness below the critical thickness will be highlighted in red. Because no indications of internal corrosion were found, no graphs have been prepared.

Please refer to the **CONDITION INDICATOR** and **COMMENT LIST** sections of the report for a brief summary of the inspection. The data pages contain all the information necessary for your own evaluation of the data.

I hope this report meets with your approval and should you have any questions, please contact me at our office at your convenience.

Sincerely,



David Clements
CGSB II/SNT III

Western Inspection Ltd.

TABLE OF CONTENTS

Tab #	Tag	Description	Reg #	Serial #
Inlet Area				
1	Inlet Header Piping			
(a)	Pig Receiver			
(b)	Pig Receiver			
(c)	Pig Receiver			
(d)	Piping			
2	V-100 Inlet Separator		A 127554	P 1315
(a)	V-100 Vessel			
(b)	Inlet Piping			
(c)	Outlet Piping			
3	V-101 Pigging Separator		A 2664161	2059.90
(a)	V-101 Vessel			
(b)	Piping			
Dehy Building				
4	C-150 Glycol Absorber Tower		A 188766	83C-3016-01
(a)	C-150 Vessel			
(b)	Inlet Piping			
(c)	Outlet Piping			
5	R-600 Glycol Reboiler			
(a)	R-600 Vessel			
(b)	Accumulator			
6	Glycol Filter			
(a)	Vessel			

Tab #	Tag	Description	Reg #	Serial #
Compressor Building				
8		Unit #1 Compressor (north)		
	(a) V-101 1st. Stage Suction Scrubber	A 137104	405-3-76-6	
	(b) 1st. Stage Suction Scrubber Inlet Piping			
	(c) 1st. Stage Suction Scrubber Outlet Piping	A 137089	405-3-76-9	
	(d) VBK-300 1st. Stage Suction Bottle (south stage)			
	(e) 1st. Stage Suction Bottle Inlet Piping			
	(f) 1st. Stage Suction Bottle Outlet Piping	A 137103	405-3-76-13	
	(g) VBK-301 1st. Stage Discharge Bottle (south stage)			
	(h) 1st. Stage Discharge Bottle Inlet piping			
	(i) 1st. Stage Discharge Bottle Outlet Piping	A 117882	245-76-8	
	(j) VBK-303 1st. Stage Suction Bottle (north stage)			
	(k) 1st. Stage Suction Bottle Inlet Piping	A 117878	245-76-12	
	(l) 1st. Stage Suction Bottle Outlet Piping			
	(m) VBK-302 1st. Stage Discharge Bottle (north stage)			
	(n) 1st. Stage Discharge Bottle Inlet Piping			
	(o) 1st. Stage Discharge Bottle Outlet Piping			
	(p) E-300 1st. Stage Discharge Cooler (top)		768345.3	
	(q) E-301 1st. Stage Discharge Cooler (bottom)		M758006.M1	
9		Unit #2 Compressor (south)		
	(a) V-103 2nd. Stage Suction Scrubber	A 209065	56122	
	(b) 2nd. Stage Suction Scrubber Inlet Piping			
	(c) VBK-310 2nd. Stage Suction Bottle	A 209068	56125	
	(d) 2nd. Stage Suction Bottle Inlet Piping			
	(e) VBK-311 2nd. Stage Discharge Bottle	A 209069	56126	
	(f) V-104 3rd. Stage Suction Scrubber	A 209066	56123	
	(g) 3rd. Stage Suction Scrubber Inlet Piping			
	(h) VBK-312 3rd. Stage Suction Bottle	A 209070	56127	
	(i) VBK-313 3rd. Stage Discharge Bottle	A 209071	56128	
	(j) 3rd. Stage Discharge Bottle Outlet Piping			
	(k) V-105 4th. Stage Suction Scrubber	A 209067	56124	

Tab #	Tag	Description	Reg #	Serial #
(l)	4th. Stage Suction Scrubber Inlet Piping			
(m)	4th. Stage Suction Scrubber Outlet Piping			
(n)	VBK-314 4th. Stage Suction Bottle	A 190318	10940	
(o)	4th. Stage Suction Bottle Inlet Piping	A 190319	10941	
(p)	VBK-315 4th. Stage Discharge Bottle			
(q)	F-210 Fuel Gas Filter		82-705	
(r)	E-310 2nd. Stage Discharge Cooler		828775.3	
(s)	E-311 3rd. Stage Discharge Cooler		828775.4	
(t)	E-312 4th. Stage Discharge Cooler		828775.5	

ITEM LIST

Tab	Item	Description			Next Inspect			
			Nov 2003	Oct 2008				
Inlet Area								
1 Inlet Header Piping								
(a) <u>Pig Receiver</u>			*	*				
100	Top North Shell		*					
103	Bottom North Shell		*					
105	Bottom South Shell		*					
(b) <u>Pig Receiver</u>			*	*				
110	Top North Shell		*					
113	Bottom North Shell		*					
115	Bottom South Shell		*					
(c) <u>Pig Receiver</u>			*	*				
120	Top North Shell		*					
123	Bottom North Shell		*					
125	Bottom South Shell		*					
(d) <u>Piping</u>			*	*				
150	Bottom of 6" Pipe		*					
155	6" Elbow		*					
160	Bottom of 6" Pipe		*					
165	6" Elbow		*					
170	Bottom of 4" Pipe		*					
175	4" Elbow		*					
180	Bottom of 2" Pipe		*					
2 V-100 Inlet Separator								
(a) <u>V-100 Vessel</u>			*	*				
200	Top South Head		*					
205	Top South Shell		*					
210	Upper West Shell		*					
215	Lower East Shell		*					
220	Bottom South Shell		*					
225	Bottom South Head		*					

ITEM LIST

Tab	Item	Description	Next Inspect	
			Nov 2003	Oct 2008
(b) Inlet Piping	230 8" Inlet Elbow		*	
	232 8" Inlet Nozzle		*	
(c) Outlet Piping	238 8" Outlet Nozzle		*	
	239 8" Outlet Elbow		*	
	240 8" Outlet Elbow		*	*

(a) V-101 Vessel	
300	Top East Head
305	Bottom East Head
310	Top East Shell
315	Lower South Shell (west end)
320	Bottom East Shell
325	Bottom West Shell
330	Bottom West Head

(b) Piping	
340 8" Nozzle	*
350 8" Nozzle	*
360 2" Nozzle	*
370 2" Nozzle	*
380 2" Nozzle	*
385 6" Nozzle	*

Dehy Building

4 C-150 Glycol Absorber Tower

(a) C-150 Vessel

- 420 Lower North Shell
- 425 Lower North Shell (across i)
- 430 Bottom West Shell
- 435 Bottom West Head

A 10x10 grid of squares. The last four columns (columns 7, 8, 9, and 10) are shaded blue, while the other six columns are white. This creates a vertical bar of blue squares on the right side of the grid.

ITEM LIST

Tab	Item	Description	Nov 2003	Oct 2008	Next Inspect
(b)	<u>Inlet Piping</u>				
(c)	<u>Outlet Piping</u>		*		
(d)	450 4" Outlet Elbow		*	*	
5	R-600 Glycol Reboiler				
(a)	<u>R-600 Vessel</u>				
	505 Upper West Shell (north of center)	*	*		
	510 Bottom Shell (north of center)	*	*		
	515 West Shell (north end)	*	*		
(b)	<u>Accumulator</u>				
	525 Top Middle Shell	*	*		
	530 Middle West Shell (north of center)	*	*		
	535 Bottom North Shell	*	*		
	540 Bottom South Shell	*	*		
6	Glycol Filter				
(a)	<u>Vessel</u>				
	600 Top West Head	*	*		
	605 Top South Shell	*	*		
	610 Bottom North Shell	*	*		
	Compressor Building				
8	Unit #1 Compressor (north)				
(a)	<u>V-101 1st Stage Suction Scrubber</u>				
	800 Top North Head	*	*		
	801 Top North Shell	*	*		
	802 Bottom South Shell	*	*		
	803 Bottom South Head	*	*		
(b)	<u>1st Stage Suction Scrubber Inlet Piping</u>				
	804 8" Inlet Elbow	*	*		
	805 8" Inlet Nozzle	*	*		
(c)	<u>1st Stage Suction Scrubber Outlet Piping</u>				
	806 8" Outlet Nozzle	*	*		

SUMMIT Inspection

ITEM LIST

Tab	Item	Description	Nov 2003		Oct 2008		Next Inspect
			2003	2008	2003	2008	
(d) VBK-300 1st. Stage Suction Bottle (south stage)							
	810 Bottom East Head		*	*			
	811 Top Middle Shell		*	*			
	812 Bottom Middle Shell		*	*			
	813 Bottom West Shell		*				
	814 Bottom West Head		*	*			
(e) 1st. Stage Suction Bottle Inlet Piping							
	815 8" Inlet Elbow		*	*			
	816 8" Inlet Nozzle		*	*			
(f) 1st. Stage Suction Bottle Outlet Piping							
	817 6" Outlet Nozzle		*				
	818 6" Outlet Nozzle		*				
(g) VBK-301 1st. Stage Discharge Bottle (south stage)							
	820 Bottom East Head		*	*			
	821 Top Middle Shell		*	*			
	822 Bottom East Shell		*				
	823 Bottom West Shell		*				
	824 Top West Head		*				
	828 2" PSV Nozzle		*				
	829 2" PSV Elbow		*				
(h) 1st. Stage Discharge Bottle Inlet piping							
	825 6" Inlet Nozzle		*				
	826 6" Inlet Nozzle		*				
(i) 1st. Stage Discharge Bottle Outlet Piping							
	827 6" 45° Outlet Elbow		*	*			
(j) VBK-303 1st. Stage Suction Bottle (north stage)							
	830 Bottom East Head		*	*			
	831 Top Shell (east of center)		*	*			
	832 Bottom Shell (east of center)		*	*			
	833 Bottom West Shell		*				
	834 Bottom West Head		*	*			

ITEM LIST

Tab	Item	Description	Nov 2003	Oct 2008	Next Inspect
(k) <u>1st. Stage Suction Bottle Inlet Piping</u>					
	835 8" Inlet Elbow		*	*	
	836 8" Inlet Nozzle			*	
(l) <u>1st. Stage Suction Bottle Outlet Piping</u>					
	837 6" Outlet Nozzle		*		
	838 6" Outlet Nozzle		*		
(m) <u>VBK-302 1st. Stage Discharge Bottle (north stage)</u>					
	840 Bottom West Head		*	*	
	841 Top Middle Shell		*	*	
	842 Bottom East Shell		*	*	
	843 Bottom West Shell		*		
	844 Top East Head		*		
(n) <u>1st. Stage Discharge Bottle Inlet Piping</u>					
	845 6" Inlet Nozzle		*		
	846 6" Inlet Nozzle		*		
(o) <u>1st. Stage Discharge Bottle Outlet Piping</u>					
	847 6" Outlet Elbow		*	*	
(p) <u>E-300 1st. Stage Discharge Cooler (top)</u>					
	850 Bottom East Shell of Header Box (south		*	*	
	852 Bottom West Shell of Header Box (sout		*	*	
	854 Bottom East Shell of Header Box (north		*	*	
	856 Bottom West Shell of Header Box (north		*	*	
	857 6" Inlet Nozzle		*		
	858 6" Outlet Nozzle		*		
(q) <u>E-301 1st. Stage Discharge Cooler (bottom)</u>					
	860 Bottom East Shell of Header Box (south		*	*	
	862 Bottom West Shell of Header Box (sout		*	*	
	864 Bottom East Shell of Header Box (north		*	*	
	866 Bottom West Shell of Header Box (north		*	*	
	867 6" Inlet Nozzle		*		
	868 6" Outlet Nozzle		*		

ITEM LIST

Tab	Item	Description	Nov	Oct	2003	2008	Next Inspect
			*	*	*	*	*
9 Unit #2 Compressor (south)							
(a) V-103 2nd. Stage Suction Scrubber	900	Top North Head	*	*	*	*	*
	901	Top North Shell	*	*	*	*	*
	902	Middle West Shell (across inlet)	*	*	*	*	*
	903	Bottom West Shell	*	*	*	*	*
	904	Bottom South Head	*	*	*	*	*
	907	8" Outlet Nozzle	*	*	*	*	*
(b) 2nd. Stage Suction Scrubber Inlet Piping	905	8" Inlet Elbow	*	*	*	*	*
	906	6" Inlet Nozzle	*	*	*	*	*
(c) VBK-310 2nd. Stage Suction Bottle	908	Bottom West Head	*	*	*	*	*
	909	Top Middle Shell	*	*	*	*	*
	910	Bottom East Shell	*	*	*	*	*
	911	Bottom West Shell	*	*	*	*	*
	912	Bottom East Head	*	*	*	*	*
	915	6" Outlet Nozzle	*	*	*	*	*
	916	6" Outlet Nozzle	*	*	*	*	*
(d) 2nd. Stage Suction Bottle Inlet Piping	913	8" 45° Inlet Elbow	*	*	*	*	*
(e) VBK-311 2nd. Stage Discharge Bottle	917	Bottom East Head	*	*	*	*	*
	918	Top Middle Shell	*	*	*	*	*
	919	Bottom East Shell	*	*	*	*	*
	920	Bottom West Shell	*	*	*	*	*
	921	Top West Head	*	*	*	*	*
	922	6" Inlet Nozzle	*	*	*	*	*
	923	6" Inlet Nozzle	*	*	*	*	*

ITEM LIST

Tab	Item	Description	Nov 2003	Oct 2008	Next Inspect
(f) <u>V-104 3rd. Stage Suction Scrubber</u>	924 Top South Head		*	*	
	925 Top South Shell		*	*	
	926 Middle South Shell (across inlet)		*	*	
	927 Bottom East Shell		*	*	
	928 Bottom East Head		*	*	
	931 6" Outlet Nozzle		*	*	
(g) <u>3rd. Stage Scrubber Inlet Piping</u>	929 6" Inlet Elbow		*	*	
	930 6" Inlet Nozzle		*	*	
(h) <u>VBK-312 3rd. Stage Suction Bottle</u>	932 Bottom East Head		*	*	
	933 Top Middle Shell		*	*	
	934 Bottom East Shell		*	*	
	935 Bottom West Shell		*	*	
	936 Bottom West Head		*	*	
	937 6" Inlet Nozzle		*	*	
	938 8" Outlet Nozzle		*	*	
(i) <u>VBK-313 3rd. Stage Discharge Bottle</u>	939 Top East Head		*	*	
	940 Top East Shell		*	*	
	941 Top West Shell		*	*	
	942 Top West Head		*	*	
	943 8" Inlet Nozzle		*	*	
(j) <u>3rd. Stage Discharge Bottle Outlet Piping</u>	944 4" Outlet Nozzle		*	*	
	945 4" Outlet Elbow		*	*	
(k) <u>V-105 4th. Stage Suction Scrubber</u>	946 Top West Head		*	*	
	947 Top West Shell		*	*	
	948 Middle East Shell (across inlet)		*	*	
	949 Bottom West Shell		*	*	
	950 Bottom Head (south side)		*	*	

ITEM LIST

Tab	Item	Description	Nov 2003	Oct 2008	Next Inspect
(l)	<u>4th. Stage Suction Scrubber Inlet Piping</u>				
	951 4" Inlet Elbow		*		
	952 4" Inlet Nozzle		*		
(m)	<u>4th. Stage Suction Scrubber Outlet Piping</u>				
	953 4" Outlet Nozzle		*		
	954 4" Elbow		*		
(n)	<u>VBK-314 4th. Stage Suction Bottle</u>				
	955 Bottom West Head		*		
	956 Top Middle Shell		*		
	957 Bottom East Shell		*		
	958 Bottom West Shell		*		
	959 Bottom East Head		*		
	962 3" Outlet Nozzle		*		
(o)	<u>4th. Stage Suction Bottle Inlet Piping</u>				
	960 4" Inlet Elbow		*		
	961 4" Inlet Nozzle		*		
(p)	<u>VBK-315 4th. Stage Discharge Bottle</u>				
	963 Top East Head		*		
	964 Top East Shell		*		
	965 Top West Shell		*		
	967 3" Inlet Nozzle		*		
	968 3" Outlet Nozzle		*		
(q)	<u>F-210 Fuel Gas Filter</u>				
	970 Top South Shell		*		
	971 Middle South Shell		*		
	972 Bottom South Shell		*		
(r)	<u>E-310 2nd. Stage Discharge Cooler</u>				
	975 Bottom West Shell of Header Box (sout)		*		
	976 Bottom West Shell of Header Box (north)		*		
	977 6" Inlet Nozzle		*		
	978 6" Outlet Nozzle		*		

ITEM LIST

Tab	Item	Description	Nov 2003		Oct 2008		Next Inspect
(s) E-311 3rd. Stage Discharge Cooler							
	979	Top East Shell of Header Box (south en	*	*			
	980	Bottom West Shell of Header Box (sout	*	*			
	981	Bottom East Shell of Header Box (north	*	*			
	982	Bottom West Shell of Header Box (north	*	*			
	983	4" Inlet Nozzle	*				
	984	4" Outlet Nozzle	*				
(t) E-312 4th. Stage Discharge Cooler							
	985	Top East Shell of Header Box (south en	*	*			
	986	Bottom West Shell of Header Box (sout	*	*			
	987	Bottom East Shell of Header Box (north	*	*			
	988	Top West Shell of Header Box (north en	*	*			
	989	3" Inlet Nozzle	*				
	990	3" Outlet Nozzle	*				

CONDITION INDICATOR

Tab	Item	Description	Last Inspection Date	Nominal Thickness mm	Thinnest Reading mm	Critical Thickness mm	Corrosion Rate mm/yr	Condition Indicator Years
Inlet Area								
1 Inlet Header Piping								
(c) <u>Pig Receiver</u>								
120 Top North Shell								
2 V-100 Inlet Separator								
(a) <u>V-100 Vessel</u>								
225 Bottom South Head								
(b) <u>Inlet Piping</u>								
230 8" Inlet Elbow								
3 V-101 Pigging Separator								
(a) <u>V-101 Vessel</u>								
300 Top East Head								
330 Bottom West Head								
(b) <u>Piping</u>								
340 8" Nozzle								
385 6" Nozzle								
Dehy Building								
4 C-150 Glycol Absorber Tower								
(c) <u>Outlet Piping</u>								
450 4" Outlet Elbow								
6 Glycol Filter								
(a) <u>Vessel</u>								
600 Top West Head								

CONDITION INDICATOR

Compressor Building




8 Unit #1 Compressor (north)

Tab	Item	Description	Last Inspection Date	Nominal Thickness mm	Thinnest Reading mm	Critical Thickness mm	Corrosion Rate mm/yr	Condition Indicator	Years
Compressor Building									
(a) <u>V-101 1st. Stage Suction Scrubber</u>	801	Top North Shell	Oct 2008	9.52	8.92	7.92	0.02	52.2	
(b) <u>1st. Stage Suction Scrubber Inlet Piping</u>	805	8" Inlet Nozzle	Oct 2008	22.22	21.54	20.62	0.02	42.8	
(c) <u>1st. Stage Suction Scrubber Outlet Piping</u>	806	8" Outlet Nozzle	Oct 2008	22.22	21.26	20.62	0.03	21.2	
(e) <u>1st. Stage Suction Bottle Inlet Piping</u>	815	8" Inlet Elbow	Oct 2008	12.70	11.99	11.10	0.02	40.1	
(f) <u>1st. Stage Suction Bottle Outlet Piping</u>	818	6" Outlet Nozzle	Oct 2008	21.95	21.54	20.35	0.01	94.8	
(g) <u>VBK-301 1st. Stage Discharge Bottle (south stage)</u>	824	Top West Head	Oct 2008	9.52	7.54	7.92	0.06	-6.2	
(h) <u>1st. Stage Discharge Bottle Inlet piping</u>	828	2" PSV Nozzle	Oct 2008	11.07	10.64	9.47	0.01	86.9	
	829	2" PSV Elbow	Oct 2008	11.07	10.36	9.47	0.02	40.1	
(i) <u>VBK-303 1st. Stage Suction Bottle (north stage)</u>	834	Bottom West Head	Oct 2008	9.52	9.07	7.92	0.01	80.7	
(m) <u>VBK-302 1st. Stage Discharge Bottle (north stage)</u>	840	Bottom West Head	Oct 2008	9.52	9.07	7.92	0.01	80.7	
	844	Top East Head	Oct 2008	9.52	8.31	7.92	0.04	10.1	
(o) <u>1st. Stage Discharge Bottle Outlet Piping</u>	847	6" Outlet Elbow	Oct 2008	7.11	6.60	5.51	0.02	69.4	
(q) <u>E-301 1st. Stage Discharge Cooler (bottom)</u>	867	6" Inlet Nozzle	Oct 2008	11.07	10.87	9.47	0.04	39.6	
	868	6" Outlet Nozzle	Oct 2008	10.97	10.74	9.37	0.04	34.5	
SUMMIT \ Inspection									

CONDITION INDICATOR

Tab	Item	Description	Last Inspection Date	Nominal Thickness mm	Thinnest Reading mm	Critical Thickness mm	Corrosion Rate mm/yr	Condition Indicator	Years
9 Unit #2 Compressor (south)									
(a) <u>V-103 2nd. Stage Suction Scrubber</u>			Oct 2008	12.70	12.27	11.10	0.02	69.7	
901	Top North Shell		Oct 2008	12.70	12.01	11.10	0.03	34.4	
907	8" Outlet Nozzle								
(e) <u>VBK-311 2nd. Stage Discharge Bottle</u>			Oct 2008	10.97	10.59	9.37	0.01	82.5	
922	6" Inlet Nozzle								
(f) <u>V-104 3rd. Stage Suction Scrubber</u>			Oct 2008	12.70	12.22	11.10	0.02	59.7	
926	Middle South Shell (across inlet)								
(g) <u>3rd. Stage Suction Scrubber Inlet Piping</u>			Oct 2008	10.97	9.91	9.37	0.04	12.9	
929	6" Inlet Elbow		Oct 2008	10.97	10.08	9.37	0.03	20.6	
930	6" Inlet Nozzle								
(h) <u>VBK-312 3rd. Stage Suction Bottle</u>			Oct 2008	12.70	12.19	11.10	0.02	55.4	
933	Top Middle Shell		Oct 2008	12.70	12.29	11.10	0.02	75.7	
934	Bottom East Shell		Oct 2008	12.70	12.32	11.10	0.01	82.5	
935	Bottom West Shell		Oct 2008	10.97	10.59	9.37	0.01	82.5	
(i) <u>4th. Stage Suction Scrubber Inlet Piping</u>			Oct 2008	8.56	7.87	6.96	0.03	34.4	
952	4" Inlet Nozzle								
(m) <u>4th. Stage Suction Scrubber Outlet Piping</u>			Oct 2008	8.18	7.82	6.58	0.01	90.2	
953	4" Outlet Nozzle								
(q) <u>F-210 Fuel Gas Filter</u>			Oct 2008	10.97	10.62	9.37	0.01	93.7	
972	Bottom South Shell								
(r) <u>E-310 2nd. Stage Discharge Cooler</u>			Oct 2008	10.97	10.44	9.37	0.02	51.5	
977	6" Inlet Nozzle		Oct 2008	10.97	10.44	9.37	0.02	51.5	
978	6" Outlet Nozzle								

Tab 8, Unit #1 Compressor (north)
Component (g) 1st. Stage Discharge Bottle (south stage)
Item 824, Top West Head, -6.2 years to critical thickness.



COMMENT LIST

Tab Equipment	Date Inspected	Comments	Condition indicator
Inlet Area			
1 Inlet Header Piping (d) Piping 155 6" Elbow	Nov 2003	A dent was found at the bottom of the elbow on the outside radius. The dent measures approximately 1.5" x 1" and is estimated at .060" deep.	
2 V-100 Inlet Separator (a) V-100 Vessel	Nov 2003	The paint is deteriorated and is failing across much of the vessel. Rust and minor external corrosion is occurring in the areas where the paint has failed. The external corrosion is estimated at .005" deep.	