

Canadian Natural Resources Limited
GENERAL PRESSURE VESSEL INFORMATION **Job # 05.002893**

District: Fort St. John BC.	Skid No.
Facility: Jedney Field	Location (LSD): a-7-K/94-G-8
Vessel Name Equipment Number: Inlet Separator	
Orientation: Vertical	
Status: In Service	Regulatory Inspection

PRESSURE VESSEL NAMEPLATE DATA

“A” or “G” or “S” (Sask.) or BC Registration Number. A 443426	CRN Number: M 7382.231
Vessel serial number: 119-85-98	Size: 24in x 10ft
Shell thickness: 28.6mm	Shell material: SA 516 70N
Head thickness: 27.48mm	Head material: SA 516 70N
Tube wall thickness:	Tube material:
Tube diameter:	Tube length:
Channel thickness:	Channel material:
Design pressure	Operating pressure
Shell: 1480 psi	Shell: 110 psi
Tubes:	Tubes:
Design Temp.	Operating temperature
Shell: 100 deg F	Shell:
Tubes:	Tubes:
X-ray: RT 1	Heat treatment: HT
Code parameters: ASME VIII, Div 1	Coated: not stated
Manufacturer: Mar Quinn Industries	Year built: 1998
Corrosion allowance: 3.2mm	Manway: No

PRESSURE SAFETY VALVE NAMEPLATE DATA

PSV Tag #	Manufacture	Model #	Serial #	Set Pressure (psi)	Capacity (scfm)	Service Date
	Crosby	JOS 45/A	C14C2000	1480	9021	6/2006
CRN #	Service By	Block Valve	Location	Size	Code Stamp	
OG 0201.2C	Tyco	No	Shell	1.5" x 2"	UV	

SERVICE CONDITIONS-INDICATE ALL THAT APPLY

Sweet	Sour X	Oil	Gas X	Water X
Amine	LPG	Condensate X	Air	Glycol

Other (Describe):

Inspection Interval _____ **PSV Service Interval** _____
 (Determined by MIC in conjunction with Chief Inspector following guidelines of CNRL Owner-User Inspection Program)

Reports reviewed and accepted by:
Mechanical Integrity Coordinator _____ **Date** _____

Fill out all forms as completely as possible. All information is important! Use back of sheets to record additional information or sketch if required.
Copy of report to be filed by MIC at site, and copy sent to Chief Inspector

External Inspection Items	G	F	P	N/A	Comments
Insulation Verify sealed around manways, nozzles, no damage present, and there is no egress of moisture.				X	Vessel not insulated.
External Condition Assess paint condition, areas peeling, record any corrosion, damage, etc (record location, size and depth of corrosion or damage)	X				Paint in good condition- no exposed metal. No external Corrosion
Leakage Record any leakage at flanges, threaded joints, weep holes on repads, etc.	X				No leaks observed.
Saddle/Skirt Assess condition of paint, fire protection, concrete. Look for corrosion, buckling, dents, etc. Look at vessel surface area near supports. Verify no signs of leakage at attachment to vessel and attachment welds are acceptable. Ground wire attached?	X				Skirt: bolted directly to skid frame. No buckling or dents. No corrosion at attachment welds to vessel. Ground wire attached to skid.
Anchor Bolts Hammer tap to ensure secure. Look for cracking in treads or signs of deformation.	X				Securely fastened – no deformation.
Concrete foundation Check for cracks, spalling, etc.				X	
Ladder / Platform Describe general condition, ensure support is secure to vessel, describe any hazards.				X	
Nozzle Assess paint, look for leakage, and ensure stud threads are fully engaged. Record any damage, deflection, etc. Are nozzles gusseted?	X				Stud threads are fully engaged to nuts. No leaks observed. No damage or deflections. Nozzles are not gusseted.
Gauges Ensure gauges are visible, working, no leakage, and suitable for range of MAWP/ Temp.		X			Gauges are clear and appear functional. Within range of the MAWP. Sight glass valves are weeping.
External Piping Ensure pipe is well supported. All clamps, supports, shoes, etc. in place. Look for evidence of structural overload, deflection, etc. Paint condition, external corrosion?	X				Piping is in good condition and well supported. No apparent overloads or obviously deformed sections. Paint is in good condition.
Valving Ensure no leaks are visible. Valves are properly supported and chained if necessary.	X				No leaks are visible- valves properly supported.
PSV Ensure PSV is set at pressure at or below that of vessel.	X				Located on upper shell - set below the vessel MAWP. Seal intact. No block valve.
NDE methods Was UT/ MPI done on vessel (MI coordinator to review results)	X				Ultrasonic thickness survey carried out – no metal thickness detected below nominal minus corrosion allowance.
Other					
<p>Recommendations or corrective actions : Vessel is Fit for Service or describe corrective actions required) (MIC to review corrective actions with Operations, discuss with Chief Inspector where necessary, and get remedial action implemented) Recommendations: None at this time</p> <p>Summary: This vessel is in overall good condition, visual external inspection and ultrasonic corrosion survey performed, no metal thickness detected below nominal minus corrosion allowance.</p> <p>Vessel is fit for service.</p>					


Inspected By: Keith Kowal (API 510 #26812)

Date: February 7th, 2009

Photos



LSD




Vessel data plate



Vessel overview



Vessel overview



Weeping of the threaded fittings on the sight glass piping.



Gauges are in good condition and within range for the MAWP.



Outlet piping is in good condition and well supported.



Choke is in good condition with no leaks.



Skirt is in good condition with anchor bolts tight.