Canadian Natural Resources Limited GENERAL PRESSURE VESSEL INFORMATION Job# 10.113336										
District: Grand	e Prairie AB.	Skid No.								
Facility: Clear	Hills Gas Gathering	Location (LSD): 6-15-88-12W6M								
Vessel Name Eq	uipment Number: Separat									
Orientation: Ve	rtical									
Status: Ou	t of Service	Regulatory Inspection								
		PRESSURE VES	AMEPLATE DATA							
"A" or "G	" or "S" (Sask.) or BC Regi	CRN Number:								
	A2815118	V0067-21								
Vessel serial nun	nber: 6000A-V02	K9067.21 Size: 16 in. X 90 in.								
Shell thickness:		Shell material: SA 106-B								
Head thickness:		Head material: SA 516-70N								
Tube wall thickn	ess:	Tube material:								
Tube diameter:					Tube length:					
Channel thicknes				Channel material:						
ъ.	Shell: 720 PSI				.•		Shell:			
Design pressure	m 1			Operating pressure			TD 1			
	Tubes:						Tubes			
	Shell: 120 Deg F						Shell:			
Design Temp.	Tubes:			Operating temperature			Tulson			
X-ray: RT 1	Tubes:	Tubes: Heat treatment: yes								
	: ASME VIII, Div 1	Coated: no								
Manufacturer: N		Year built: 1993								
Corrosion allowa		Manway: no								
	PRE	SSURE SAFETY	Y VALV	E NA	AMEPLATE D	ATA				
DOVET #	Mana Castana (Madal)			city Size		11	Landin	C		
PSV Tag #	Serial	Manufacture / Model / Set Pressure Capa Serial (PSI / kPa) (scf				Block Location Valve		Service Date		
		<u> </u>		, <u> </u>						
C-545 Taylor/T-7900-2/C545 720PS		720PSI	299	92	2X2	No		Side Shell	10/2010	
	SERVIC	E CONDITION	S-INDI	CAT	E ALL THAT	APPL	Y		<u> </u>	
Sweet V									Water	
Sweet X Sour Oil							Gas X		vv ater	
Amine	LPG	densate			Air		Glycol			
Other (Describe)	:									
						_				
Inspection IntervalPSV Service Interval (Determined by MIC in conjunction with Chief Inspector following guidelines of CNRL's Owner-User Inspection Program)										
•	•	or following guideling	es of CNR	L's Ov	vner-User Inspection	n Progra	m)			
Reports reviewed an	и ассериен ву.									
Mechanical Into	egrity Coordinator						Oate			

Fill out all forms as completely as possible. <u>All information</u> is important! Use back of sheets to record additional information or sketch if required. Copy of report to be filed by MIC at site, and copy sent to Chief Inspector

External Inspection Items					Comments
External hispection ftems	G	F	Р	N/A	Comments
Insulation Verify sealed around manways,					
nozzles, no damage present, and there is no				X	Vessel is not insulated.
egress of moisture.					
External Condition Assess paint condition,					
areas peeling, record any corrosion, damage,		X			Paint in fair overall condition – minor exposed metal to
etc (record location, size and depth of		Λ			20percent of vessel. General corrosion noted.
corrosion or damage)					
Leakage Record any leakage at flanges,	X				No leaks observed.
threaded joints, weep holes on repads, etc.	Λ				
Saddle/Skirt Assess condition of paint, fire					Skirt: Bolted directly to skid floor.
protection, concrete. Look for corrosion,					No buckling or dents.
buckling, dents, etc. Look at vessel surface	v				No corrosion at attachment welds to vessel.
area near supports. Verify no signs of leakage	X				Ground wire attached to skid.
at attachment to vessel and attachment welds					
are acceptable. Ground wire attached?					
Anchor Bolts Hammer tap to ensure secure.					Anchor bolts are securely fastened.
Look for cracking in treads or signs of	X				No deformation.
deformation.					
Concrete foundation Check for cracks,				3 7	Steel skid
spalling, etc.				X	
Ladder / Platform Describe general					No ladder
condition, ensure support is secure to vessel,				X	
describe any hazards.					
Nozzle Assess paint, look for leakage, and					Stud threads are fully engaged to nuts – no short bolts.
ensure stud threads are fully engaged. Record					No damage or deflections – no leaks.
any damage, deflection, etc. Are nozzles	X				Nozzles are not gusseted.
gusseted?					
Gauges Ensure gauges are visible, working,					Gauges starting to have residue buildup – no leakage.
no leakage, and suitable for range of MAWP/					Suitable for operational range of vessel.
Temp.	X				Pressure gauge 0 – 2000 PSI/ temperature gauge -40 – 120
					Deg F.
External Piping Ensure pipe is well					Piping is well supported; no deflection, all clamps and
supported. All clamps, supports, shoes, etc. in					supports are in place.
place. Look for evidence of structural	X				Paint peeling to 20% of area- corrosion on exposed metal.
overload, deflection, etc. Paint condition,	1				2 mile promise to 20 /0 of area corrobion on exposed metals
external corrosion?					
Valve: Ensure no leaks are visible. Valves are	X				
properly supported and chained if necessary.					Valves are supported properly – no leaks.
PSV Ensure PSV is set at pressure at or below					Located on upper shell of vessel.
that of vessel.					Set at MAWP of vessel – PSV seal in place.
diat of resser	X				Discharge piping is same size as valve outlet.
					No block valve between vessel and PSV.
	ĺ				THE DIOCK VALVE DELWEEN VESSEL AND LOV.

NDE methods Was UT/ MPI done on vessel			Ultrasonic corrosion survey carried out – pipe metal
(MI coordinator to review results)			thickness detected below nominal minus corrosion
			allowance. Thickness calculations carried out:
			UT point 265 (2" elbow) – nominal thickness is 5.5mm / min
			thickness is 4.5mm / T min thickness is 1.6mm.
Other			Vessel skid is being used as a storage area.
		\mathbf{X}	

Recommendations or corrective actions: Vessel is Fit for Service or describe corrective actions required)

(MIC to review corrective actions with Operations, discuss with Chief Inspector where necessary, and get remedial action implemented)

Recommendations: No Recommendations at this time.

Summary: This vessel is in good condition, visual external and ultrasonic thickness inspection carried out - pipe metal thickness detected below nominal minus corrosion allowance. Thickness calculations carried out to ensure sufficient metal exists for safe operation.

Corrosion rate based on greatest thickness loss (shell) 0.045mm per year. Retirement Date to "T"min is year 2171.

Vessel is fit for service.

Inspected By: Matt Wood (API 510 # 42758) **Date:** Aug 29th, 2013

Photo Table



