

Report #: 156816-KK-14
Inspect Date: 05/07/2012
Page: 1 of 11
Insp. Co. Job #: 156816

| Criticality Designation: | | | | Green | | |
|---|-----------------------|------------------------------------|---------------------|---------------------------------------|------------|---------------|
| Insp. Comp: Matrix_Inspection | District: | St Albert - Sout | h | Field: | Hobbe | ma-1775 |
| Location: Hobbema Field | Unit / Skid #: | | | LSD: | | 14-24W4M |
| Jurisdiction #: A0404024 | Equip Tag #: _ | | | | VS- | |
| CRN #: <u>N7751.2</u> | Nat'l Bd #: _ | | | · · · · · · · · · · · · · · · · · · · | 1: | 997 |
| Manufacturer: Argo Sales | | | n: Other: Separator | <u> </u> | Comiles | Const |
| Status: In Service - MAWP Shell: 1440 Psi @ | Equip | o. Type: Vessel: Se Volume: N/A | | | Service: | Sweet |
| MAWP Tube: N/A @ | | ht/Length: N/A | | | Insulated: | |
| | | Diameter.: 20 | in. O.D. | _ | PWHT: | = = |
| Support Skirt | | al CNRL Inventory | | _ | Manway: | |
| C.A.: 1.6 mm Coa | | | J.E.: N/A Rem | ote Access | _ | |
| Component | Material | Nominal Thk | Diameter | OD/ID T | ube Side | Shell Side |
| 1 Main - Shell | N/A | | 20.000 in. | OD | | |
| 2 Top - Head | N/A | | 20.000 in. | OD | | \boxtimes |
| 3 Bottom - Head | N/A | | 20.000 in. | OD | | |
| 4 - | | | | | | |
| 5 - | | | | | | |
| Static Data: Confirmed Chang | ed (See Comments) | \boxtimes | | | | |
| Comments: | | | | | | |
| Data not provided from MaxiTrack prid | | | | | | |
| Confirm data before overwriting datab Limited data avialable from data plate | | | | | | |
| Emiliod data avialable from data plate | • | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| PSV Static Data | | | | | | <u> </u> |
| PSV -1 Tag #: P73179 | Serial #: | 37395-310 | (| CRN: OG1 | 1316.2C | |
| Model #: T-8200-1 | | 5180 SCFM | | sure: 1440 | | |
| Manufacturer: Taylor | | | Service Comp | | | - |
| Inlet Size & Type: 1.00 in The | readed | | Last Service [| Date: 05-0 | 8-2012 | |
| Outlet Size & Type: 1.00 in The | readed | | Block Valve: N/A - | - | | |
| Carseal Intact: Yes | | | | amp: Yes | | |
| Shell Side / Tube Side: Shell Side | le Out for Se | ervice During Insp.: | Y Location of I | PSV: On \ | Vessel | |
| PSV -2 Tag #: N/A | Serial #: | N/A | (| CRN: N/A | | |
| Model #: N/A | Capacity: | | Set Pres | - | | |
| Manufacturer: N/A | | | Service Comp | any: N/A | | |
| Inlet Size & Type: - | | | Last Service [| Date: N/A | | |
| Outlet Size & Type: - | | | Block Valve: | - | | |
| Carseal Intact: | | | Code St | amp: | | |
| Shell Side / Tube Side: | Out for Se | ervice During Insp.: | Location of I | PSV: | | |
| PSV Comments | | | | | | |
| PSV was removed during the external | visual inspection and | d UT corrosion surv | vey. | | | |
| PSV data was provided at a later date | for updating reports | with current service | e data. | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |



Report #: 156816-KK-14
Inspect Date: 05/07/2012
Page: 2 of 11
Insp. Co. Job #: 156816

| | Insp. Company: Matr | ix In | spection | LSD: | 14-09-044-24W4M | Jurisdic | tion # | A04 | 04024 | _ |
|---|---|-------------|--------------|--------------|--|----------|--------|--------------------------|----------------------------|---|
| _ | · · · · · · | | • | | | Garioaio | | | | |
| 느 | xternal Inspection Results | – VE | External in | spection Per | Tormed | 1 | | Г | | _ |
| | Item | N/A | Condition | (0 | Comment Check Status Bar or Press F1 for Help) | | NCR | Action Item Integrity | Action Item Maintenance | |
| | Nameplate | | Accept | faded and h | nard to read | | | | | |
| | Foundation and Supports | | Accept | Secure and | level | | | | | 1 |
| | Anchor Bolts | | Accept | secure and | level | | | | | 1 |
| | Grounding | | Accept | grounded th | nrough building | | | | | |
| | Insulation Condition | \boxtimes | | not insulate | ed | | | | | 1 |
| | PSV | \boxtimes | | PSV remov | ed for service at time of inspection | n | | | | |
| | Shell Heads & Nozzles | | Accept | good condit | tion | | | | | |
| | Metal Surfaces (Paint) | | Accept | isolated sur | face corrosion and scale | | | | | |
| | Aux Equipment | | Accept | good condit | tion | | | | | |
| | Cathodic Protection | \boxtimes | | not applical | ble | | | | | |
| | Alignment | | Accept | good alignn | nent | | | | | |
| | Flange Connections | | Accept | proper bolt | engagment | | | | | 1 |
| | Pressure Gauge | | Accept | clear and le | egible | | | | | 1 |
| | Temperature Gauge | | Accept | clear and le | egible | | | | | 1 |
| | Sight Glass | | Accept | clear and cl | lean | | | | | 1 |
| | Ladder / Platform | \boxtimes | | no ladders | or platforms attached | | | | | |
| | Leaks | | No | no leaks no | oted | | | | | |
| | Piping from Vessel | | Accept | isolated sur | face corrosion and flaking paint | | | | | |
| | Previous UT Survey | | Yes | evidence of | f previous survey | UT Co | ompan | y: unknown | | |
| E | xternal Visual Observations | | | | | | | | | |
| | Nameplate is secure and hard to read, and contains little information. The vessel is secure and level, with properly aligned piping and external attachments. The paint is in fair condition, with scale and minor surface corrosion noted. | | | | | | | | | |
| | The vessel to roof interface is leaking. | | | | | | | | | |
| | There is no access inside the bottom skirt due to the configuration of vessel placement and piping. | | | | | | | | | |
| | The attached piping is in good condition with isolated areas of surface corrosion. | | | | | | | | | |
| | | appe | ars to be in | good conditi | ction. on, and of adequate size and pro ce company to update the static in | | | nis report. | | |
| | The overall condition of this vessel is good. | | | | | | | | | |

Recommendations:

Reseal the vessel to roof interface.

Monitor the surface corrosion on the shell.

Consider cutting an access hole in the bottom skirt to allow access for bottom head and drain inspection.

A UT corrosion survey was performed at the time of the inspection by IRISNDT using DMS2 SN 020448.

Typical locations on the vessel heads, shell, and attachments were selected for the UT survey.

No thickness values of concern were noted during the UT survey. See attached UT values and drawing for complete details.

Clean and maintain buildings and packages to prevent further surface corrosion and potential degradation.

Ensure PSV's are serviced, installed, and rated correctly before putting this equipment back into service post TAR.



Report #: **156816-KK-14**Inspect Date: 05/07/2012
Page: 3 of 11

Page: 3 of 11 Insp. Co. Job #: 156816

| Insp. Company: | Matrix In: | spection | LSD: | 14-09-044-24W4M | Jurisdiction #: | A04 | 04024 | |
|--------------------------|-------------|-------------|----------------|--------------------------------------|-----------------|-------------|------------------|--|
| Internal Inspection Res | ults – VI 1 | V/A (Not Ap | plicable) | | | | | |
| Item | N/A | Condition | | Comment | NCR | Action Item | Action Item | |
| | | Condition | | eck Status Bar or Press F1 for Help) | | Integrity | Maintenance | |
| Shell | | | | nspection Carried Out | | | | |
| Heads | | | | nspection Carried Out | | | <u> <u> </u></u> | |
| Manway | | | | nspection Carried Out | | <u> </u> | <u> <u> </u></u> | |
| Gasket Surfaces | | | | nspection Carried Out | | | | |
| Welds | | | | nspection Carried Out | | | <u> <u> </u></u> | |
| Refractory | | | | nspection Carried Out | | | <u> <u> </u></u> | |
| Heating Coils | | | | nspection Carried Out | | | | |
| Demister Pad | | | | nspection Carried Out | | | <u> <u> </u></u> | |
| Vane Pack | | | | nspection Carried Out | | | <u> <u> </u></u> | |
| Baffles | | | | nspection Carried Out | | <u> </u> | <u> </u> | |
| Trays | | | | spection Carried Out | | ᆜ | Ш | |
| Filter | \boxtimes | | | nspection Carried Out | | | | |
| Internal Coating | \boxtimes | | | spection Carried Out | | | | |
| Tubesheet | | | | spection Carried Out | | | | |
| Tube Bundle | \boxtimes | | No Internal Ir | nspection Carried Out | | | | |
| Internal Visual Observat | ions | | | | | | | |
| No Internal Inspection | Carried (| Dut | | | | | | |
| · | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| Recommendations: | | | | | | | | |
| No Internal Inspection | Carried C | Out | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |



Report #: 156816-KK-14
Inspect Date: 05/07/2012
Page: 4 of 11

Page: 4 of 11 Insp. Co. Job #: 156816

| Insp. Company: Mat | rix Inspe | ction | LSD: | 14-09-0 |)44-24W4M | Jurisdiction #: | A04 | 04024 |
|-----------------------------|-------------|----------|-------------------------------|-------------|-----------------------|-----------------|-------------|-------------|
| Firetube Static Data Vess | el Not Equi | ped with | Firetube | | | | | |
| Diameter: Not Applica | - | • | | Thickness: | Not Applicable | | Bend: Not | Applicable |
| Length: Not Applica | | | | | Not Applicable | | | |
| | UT 🔲 | Report | t#: Not Applica | - | ET 🔲 | Report#: Not | Applicable | |
| Firetube NDE | MT 🗌 | - | t#: Not Applica | | RT 🗆 | Report#: Not | | |
| Performed: | PT 🔲 | - | t#: Not Applica | | Other | Report#: Not | | |
| | | Корон | т и. 1401 / гррпос | abic | | тороп. 1100 | тррпоавіс | |
| Firetube Inspection Result | S | | | | | | <u> </u> | |
| Item | N/A Co | ndition | (0) | | nment | NCR | Action Item | Action Item |
| | | | | | or Press F1 for Help) | | Integrity | Maintenance |
| Burner Stack | | | No Firetube Ir | • | | | | |
| Flange (Throat) | | | No Firetube Ir | | | | | |
| Tube Sheet | | | No Firetube Ir | • | | | | |
| Hot Side | | | No Firetube Ir | | | | | |
| Miter | | | No Firetube Ir | <u> </u> | | | | |
| Return Bend | | | No Firetube Ir | | | | | |
| Supports | | | No Firetube Ir | | | | | |
| Butt Welds | \boxtimes | | No Firetube Ir | nspection C | arried Out | | | |
| Fillet Welds | | | No Firetube Ir | nspection C | arried Out | | | |
| Firetube Visual Observation | าร | | | | | | | |
| | | | | | | | | |
| No Firetube Inspection C | arried Out | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| Recommendations: | | | | | | | | |
| No Firetube Inspection C | arried Out | | | | | | | |
| No i lietabe ilispection o | arried Out | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |



Report #: **156816-KK-14**Inspect Date: 05/07/2012
Page: 5 of 11

Page: 5 of 11 Insp. Co. Job #: 156816

| Insp. Company: Matrix Inspection | LSD:1 | 4-09-044-24W4M | Jurisdiction #: | A0404024 | | |
|--|---------------------|-------------------------------|---------------------------------------|-----------------------|--|--|
| Vessel NDE and Final Summary: | | | | | | |
| | Included | ET | Report#: | | | |
| NDE Performed: MT Report#: | | RT | ─ · | | | |
| PT | | Other | | | | |
| Maxi-Trak Observations Summary (Summarize i | nspection resul | ts Max 255 Characters | : | | | |
| Vessel to roof interface leaks. Surface corrosion on shell from leaking interface. No hand hole access to bottom head or drain in skirt. Overall good condition. | | | | | | |
| Maxi-Trak Recommendations Summary (Summa | rize Recomme | ndations Max 255 Cha | acters): | | | |
| Monitor paint. Reseal the vessel to roof interfadrain access. Ensure PSV connected / rated / rat | ce. Consider cu | irtting an access hole in | · · · · · · · · · · · · · · · · · · · | llow bottom heade and | | |
| Actions Corrected at Time of Inspection: (If action | s were corrected at | the time of Inspection – note | he corrected actions here. |) | | |
| None required. | | | | | | |
| | | | | | | |
| Additional Visual Observations | | | | | | |
| Overall site conditions are very good. It is clear that operations and maintenance sta | · | | · | | | |
| Any other safety concerns or observations from a | associated equ | pment: (for example a | ssociated piping, buil | dings, pumps etc) | | |
| None noted | | | | | | |



Report #: Inspect Date: Page:

156816-KK-14 05/07/2012 6 of 11 156816

A0404024

Insp. Co. Job #:

Jurisdiction #:

Thickness and Remaining Life Evaluation

Matrix Inspection

" Must be Completed"

14-09-044-24W4M

MUST BE COMPLETED AND RESOLVED WITH CNRL IMMEDIATELY UPON DISCOVERY OF LOW WALL THICKNESS AREAS

Step 1: Was any thickness measurement location found to be less than (Nominal WT - Corrosion Allowance)?: No

If YES, proceed to Step 2; if NO, proceed to "Crack Evaluation" and "CNRL Criticality Designation".

LSD:

Step 2: Which component(s) were found below (Nominal WT - Corrosion Allowance)?

Components found below Nom - CA:

Insp. Company:

| Components | | | | |
|------------|--|--|--|--|
| N/A - N/A | | | | |
| N/A - N/A | | | | |
| N/A - N/A | | | | |
| N/A - N/A | | | | |
| N/A - N/A | | | | |

Perform Steps 3 – 8 for each component with actual thickness less than (Nominal WT – Corrosion Allowance).

Step 3: Describe Location and Extent of Corrosion:

Components

Location and Extent of Corrosion

| N/A - N/A | Not Applicable for this Inspection |
|-----------|------------------------------------|
| N/A - N/A | Not Applicable for this Inspection |
| N/A - N/A | Not Applicable for this Inspection |
| N/A - N/A | Not Applicable for this Inspection |
| N/A - N/A | Not Applicable for this Inspection |

Notes:

Not Applicable for this Inspection

Step 4:

- For shells and nozzles, calculate minimum required thickness (T-min) as per ASME Section VIII UG-27.
- For heads, calculate minimum required thickness (T-min) as per ASME Section VIII UG-32.

| Components | T-Min |
|------------|-------|
| N/A - N/A | N/A |



Report #: Inspect Date: 156816-KK-14 05/07/2012

Insp. Co. Job #:

Page: 7 of 11 Job #: 156816

Insp. Company: Matrix Inspection LSD: 14-09-044-24W4M Jurisdiction #: A0404024

Thickness and Remaining Life Evaluation (Continued)

Step 5: Is any measured thickness less than calculated minimum required thickness (T-min)? N/A

If YES, complete Step 6
If NO, proceed to Step 7..

Step 6: Is nature and extent of pitting acceptable as per API 510? N/A

Step 7: Calculate Remaining Life as per API 510. How? (Find last reading; use nominal thickness if nothing available). Short Term Corrosion Rates and Long Term Corrosion Rates.

| Components | Remaining Life (Yrs) |
|------------|-------------------------|
| N/A - N/A | N/A |

Step 8: Contact CNRL Integrity Coordinator to discuss above results.

- Name of CNRL contact: Not Applicable for this Inspection
- Date and time of conversation: Not Applicable for this Inspection

Summary/results of conversation: Not Applicable for this Inspection

Crack Evaluation by Magnetic Particle or Alternative Inspection "Must be Completed"

MUST BE COMPLETED AND RESOLVED WITH CNRL IMMEDIATELY UPON DISCOVERY OF CRACK-LIKE INDICATIONS

Were any indications found to suggest the vessel contained cracks? N/A

If NO, proceed to "CNRL Criticality Designation".

If YES, Contact CNRL Integrity Coordinator to discuss results.

- Name of CNRL contact: Not Applicable for this Inspection
- Date and time of conversation: Not Applicable for this Inspection

Summary/results of conversation:

Not Applicable for this Inspection



156816-KK-14 Report #: Inspect Date: Page:

Insp. Co. Job #:

05/07/2012 8 of 11 156816

A0404024 14-09-044-24W4M Insp. Company: Matrix Inspection LSD: Jurisdiction #:

CNRL Criticality Evaluation – "MUST BE COMPLETED"

The CNRL In-Service Pressure Vessel Inspector MUST answer all the following questions

- Is the vessel fit-for-service? : Yes 1.
- 2. Was the measured thickness less than the calculated minimum required thickness (T-min) for any component?: **No**
- Were MT indications found?: N/A 3.
- Was the remaining life less than 6 years for sour service vessels or less than 10 years for sweet service vessels?: **No** 4.
- Were NCR's or Action Items generated as a result of the inspection? : **No** 5.
- Were UT readings below (Nominal WT Corrosion Allowance) found? : **No**

Information on CNRL Owner User Program - Criticality Designation and Required Review

RED – Vessel Inspection Results are deemed RED if one of the following occurred:

- The measured thickness was less than the calculated minimum required thickness (T-min) for any component.
- MT indications were found.
- The remaining life was calculated to be less than 6 years for sour-service vessels or less than 10 years for sweet-service vessels.

RED inspection reports must be signed off by the CNRL Chief Inspector.

YELLOW - Vessel Inspection Results are deemed YELLOW if one or more of the following occurred:

- The vessel was declared NOT fit-for-service by the 3rd Party In-Service PV Inspector.
- NCR's or Action Items were generated as a result of the inspection.
- UT readings below (Nominal WT Corrosion Allowance) were found.

YELLOW inspection reports must be signed off by the CNRL Pressure Equipment Integrity Coordinator.

GREEN - Vessel Inspection Results are deemed GREEN if all of the following are true:

- The vessel was declared fit-for-service by the 3rd Party In-Service PV Inspector.
- UT readings below (Nominal WT Corrosion Allowance) were NOT found.
- MT indications were NOT found.
- NCR's or Action Items were NOT generated as a result of the VE inspection.

GREEN inspection reports must be signed off by the 3rd Party In-Service Pressure Vessel Inspector.

| Critical | ity Designation | Green |
|---------------|---------------------------|--|
| | | |
| Vehicle #: | Kms: | Inspector (Name): Kris Katryniuk PESL: N/A |
| Time In: | 00:00 Time Out: 00:00 Hrs | Inspector (Signature): Occopation (64420 am API: 510-35238 |
| Time In: | 00:00 Time Out: 00:00 Hrs | CNRL Coordinator (Name): |
| Personnel: | | CNRL Coordinator (Signature): |
| Billing Info: | : | (I am in full agreement with report contents) CNRL Chief Inspector (Signature): |
| | | (I am in full agreement with report contents) |



Report #: Inspect Date: Page:

Insp. Co. Job #:

156816-KK-14 05/07/2012 9 of 11 156816

Equipment Photographs:




01-A0404024 Data Plate



02-A0404024 Overview Inside

Report #: 156816-KK-14
Inspect Date: 05/07/2012
Page: 10 of 11
Insp. Co. Job #: 156816



03-A0404024 Overview Outside



04-A0404024 Staining at Roof Interface

Report #: 156816-KK-14
Inspect Date: 05/07/2012
Page: 11 of 11
Insp. Co. Job #: 156816



05-A0404024 Staining on Sgell from Instrument Leaks



Circuit. No. ___

MAWP: ___


Piping Class ___

____ Service: ___

__ @ Temp. ___

CORROSION INSPECTION SERVICES

Page



Line No. (s) (PLEASE PUT LINE NUMBERS ON APPLICABLE LINES ON THE DRAWING)

Size & Schedule of Piping (PLEASE PUT APPROPRIATE SIZES AND SCHEDULES OF PIPING ON DRAWING)

_ Yr. Blt. _

A0404024 Readings in inches

| | PNT1 | PNT2 | PNT3 |
|-------|-------|-------|-------|
| LOC5 | 0.955 | 0.971 | 0.942 |
| LOC10 | 0.867 | 0.883 | 0.867 |
| LOC15 | 0.884 | 0.885 | 0.882 |
| LOC20 | 0.881 | 0.879 | 0.878 |
| LOC25 | 0.884 | 0.866 | 0.865 |
| LOC30 | 1.057 | 0.967 | 0.966 |
| LOC35 | 0.296 | 0.298 | 0.289 |