	(esources Limited ESSEL INFORM	ATION	Jo	ob # 10.114022 /	10.115211	
District: Fort St. Jo	ohn BC	Skid No.							
Facility: Babcock M									
-	ment Number: Produc		ıhle wa	•			<u>-</u>		
Orientation: Vertica		eu water rank (Dou	ibic wa	m / 400 DDL)					
Status: In Ser	vice	DDECCLIDE VECC	ODT N						
"A" or "C" o	r "S" (Sask.) or BC R		SEL N.	AMEPLATE DA		'DN Nun	ahar:		
A OI O	C56412	egisuation Number.				N/A	ider.		
Tank serial number:				Size: 12 ft x 20					
Shell thickness: 4.8									
Bottom thickness: 6.									
Deck thickness: 4.	8mm			Deck material: SA 36					
Tube diameter:				Tube length:	id No. cation (LSD): a-100-K / 93-I- 00 BBL) Regulatory Inspection CPLATE DATA CRN Num N/A ze: 12 ft x 20 ft tell material: SA 36 cock material: Shell: coerating pressure Shell: coerating temperature AMEPLATE DATA Set Pressure (kPa) Gas Air Service Interval coerating temperature CEALL THAT APPLY Gas Date				
Channel thickness:	1			Channel material:					
Design pressure	Shell: 16 oz			Operating pressure		Shell:			
	Tubes:					Tubes:			
	Shell:					Shell:			
Design Temp.	Tubes:			Operating temp	erature				
V N:1		II. at the atmosphere	NI:1	Tubes	•				
X-ray: Nil	DI 10E								
Code parameters: A	Tanks and Equipmen	<u> </u>							
Corrosion allowance		<u> </u>			3				
Corrosion anowance		RESSURE SAFETY	VALV	•	DATA				
DCV Too #	Manufacture	Model #		Carial #	Cat Duc		Compositor	Service	
PSV Tag #	Manuracture	Wodel #		Serial #			Capacity	Service	
			1		(kP	Pa)	(scfm)	Date	
CRN#	Service By	Block Valve		Location	Siz	ze	Code Stamp		
	SERV	VICE CONDITIONS	S-INDI	ICATE ALL THA	AT APPL	Y			
Sweet	Sour X	Oil			Gas		Water X		
Amine LPG Co				densate		Air		Glycol	
Other (Describe):			•			•			
Inspection Interval	I			_PSV Service Int	erval				
-		pector following guidelines	of CNR			m)			
Reports reviewed and accepted by:									
Mechanical Integrity Coordinator									
	npletely as possible. <u>All in</u> ed by MIC at site, and cop			k of sheets to record a	idditional in	tormation	or sketch if require	d.	

External Inspection Items					Comments
External Inspection Items	G	F	P	N/A	Comments
Insulation Verify sealed around manways,					Tank shell is 100% spray foam insulated.
nozzles, no damage present, and there is no	X				Several areas of suspect bird damage to 6 inch diameter.
egress of moisture.					No exposed metal.
External Condition Assess paint condition,					Painted areas are in good condition – no exposed metal.
areas peeling, record any corrosion, damage,	T 7				No damage. Tank appears to sit straight and level.
etc (record location, size and depth of	X				
corrosion or damage)					
Leakage Record any leakage at flanges,					No leaks observed.
threaded joints, weep holes on repads, etc.	X				110 icans obscived.
Base Assess condition of paint, fire					Tank skid is welded to pilings above ground
protection, concrete. Look for corrosion,	3 7				No buckling or dents.
buckling, dents, etc. Is tank mounted above	X				Ground wire attached to skid
ground water level – on pilings?					
Ground wire attached?					
Anchor Bolts Hammer tap to ensure secure.					
Look for cracking in treads or signs of				X	None
deformation. Is tank resting on deck – welded				Λ	
to supports?					
Concrete foundation There may be a					Steel
concrete ring under the tank. Check for cracks,				X	
spalling, etc.					
Ladder / Platform Describe general					No broken or loose sections.
condition, ensure support is secure to vessel,	X				Ladder bolted to side of tank.
describe any hazards.	7				Paint in good condition- no exposed metal.
Nozzle Assess paint, look for leakage, and					Stud threads are fully engaged to nuts – no leaks.
ensure stud threads are fully engaged. Record					No damage or deflections.
	X				
any damage, deflection, etc. Are nozzles					Nozzles are not gusseted.
gusseted?					
Gauges Ensure gauges are visible, working,					Liquid level gauge board attached to tank external.
no leakage, and suitable for range of MAWP/					Level increments are faded to 20% remaining legibility.
Temp. Remember some tanks require fuel gas		X			Remaining gauges are clean and clear.
or other positive protection so a pressure					Temperature gauge: -20 to 120°C
gauge may be installed.					Interstitial level gauge attached.
External Piping Ensure pipe is well					Well supported – all clamps and supports in place.
supported. All clamps, supports, shoes, etc. in					No overloads or deflections.
place. Look for evidence of structural	X 7				Piping insulated- no damage present- no wet insulation.
overload, deflection, etc. Paint condition,	X				
insulation condition, any wet insulation, any					
external corrosion?					
Valving Ensure no leaks are visible. Valves					
are properly supported and chained if	X				Valves are supported properly- no leaks.
necessary.	1				, arres are supported property- no icans.
PSV Ensure PSV is set at pressure at or below					
that of vessel.				X	No PSV.
NDE methods Was UT/ MPI done on vessel	-				
	X				Ultrasonic corrosion survey carried out, no metal thickness
(MI coordinator to review results)	-				detected below nominal minus corrosion allowance.
Secondary Containment: This may be a					This tank is double walled with a steel ring and vinyl liner
double wall tank with a pressure gauge or	X				in good condition.
level gauge indicator. Also a concrete or steel					No damage.
dike with vinyl liner – describe.					

Recommendations or corrective actions: Vessel is Fit for Service or describe corrective actions required)

(MIC to review corrective actions with Operations, discuss with Chief Inspector where necessary, and get remedial action implemented)

Recommendations: 1. Consider replacing level gauge board.

Summary: Tank is in overall good condition, visual external inspection carried out.

Tank is fit for service

Inspected By: Chris Maxsom

Date: January 31, 2014

Internal Inspection Items		F	P	N/A	Comments
Coating Assess coating. Describe area coated, general condition of coating. Anodes.	X			X	Tank is 100% internally coated with epoxy. Good condition. One area of chipped coating at manway repaired at time of inspection. None.
How many, type, condition. % consumed. Are they being replaced?					
Internal Piping Is there any? If so, carbon or stainless steel. Describe condition, dents, corrosion, erosion, etc. Ensure supports are secure and any bolts are suitable for future use.				X	None.
Bottom Record location, size and depth of all erosion, corrosion or mechanical damage. Describe General condition.	X				Good condition – no areas of failed coating. No damage.
Shell Sections Record number of shell sections. Record location, size and depth of all erosion, corrosion or mechanical damage. Describe General condition.	X				4 shell sections in good condition. No corrosion. No damage.
Roof / Deck Record location, size and depth of all erosion, corrosion or mechanical damage. Describe General condition.	X				Good condition. No corrosion. No damage.
Float	X				Float is intact and in place with free movement
Man Way Access	X				One coating chip repaired at time of inspection.
Nozzles	X				Nozzles are coated, unobstructed and in good condition - Stainless steel suction nozzles – no damage.
Thermal Probe	X				Good condition. No damage.
Welds Inspect all welds, including attachment welds. Record all service-related damages and if there is any discuss with Chief Inspector before closing.	X				All welds are in coated and in good condition.
NDE Inspections Other: Firetube	X			X	No internal NDE at this time Firetube: MT, VE carried out. MT: No cracking detected VE: No external corrosion, pitting or damaged noted.

Recommendations or corrective actions (indicate if fit for service)


Recommendations: No recommendations at this time.

Summary: This tank is in good overall condition, visual internal carried out. MT and VE carried out firetube – no issues.

Tank is fit for service.

Inspected By: Chris Maxsom ABSA #0539 **Date:** September 5, 2014





Data plate





Tank support // Lower shell // Manway Overview - Tank and containment





Interstitial level gauge Temperature gauge



