Canadian Natural Resources Limited GENERAL PRESSURE VESSEL INFORMATION Job # 10.113190												
District: Hamburg Oil – GP South				Skid No. 15138								
Facility: Hamburg Battery				Location (LSD): 15-21-96-10 W6M								
		er: Glycol Contacto	·									
Orientation: Ver		ar. Glycor Contacto	· <u>1</u>									
Status: In Service Regulatory Inspection PRESSURE VESSEL NAMEPLATE DATA												
"A" or "G" or "S" (Sask.) or BC Registration Number.  A0238179				CRN Number H 1668.2								
Vessel serial number: 1813-V100				Size: 20in x 20ft								
Shell thickness: 22.2mm				Shell material: SA 516 70N								
Head thickness: 2			Head material: SA 516 70N									
Tube wall thickness	SS:		Tube material:									
Tube diameter:				Tube length:								
Channel thickness			Channel material:									
Design pressure Shell: 9756 kPa (1415 ps		Pa (1415 psi)	Ope	erating pressure	Shell:							
	Tubes:				Tubes:							
Design Temp.	Shell: 66°C			erating temperature	Shell:							
Tubes:					Tubes:							
X-ray: RT-1				Heat treatment: Nil								
Code parameters: ASME VIII DIV 1				Joint efficiency (if on nameplate):								
Manufacturer: ABAX Energy Services				Year built: 1987								
Corrosion allowan	ce: 1.6mm		Manway No									
		PRESSURE S	AFE]	TY VALVE NAME	PLATE DATA							
Tag Number(s)	Manufacture	Model	Serial Number		Set Pressure Capacit		ý	Set Date				
MWS 68387	Farris	26EA13-120/AL	(	C14193-KA	1416 psi	2858		07/2006				
CRN#	Serviced by	Block valve	I	Location	Size	Code Stamp						
N/S	Unified Valve	No		Гор head	1" x 1.5"	UV						
		SERVICE CONI	OTTO	NS-INDICATE AL	LL THAT APPLY	Y						
Sweet X	Sour			Oil	Gas X		Water X					
Amine	LPG			Condensate	Air		Glycol X					
Other (Describe):												
Inspection IntervalPSV Service Interval  (Determined by MIC in conjunction with Chief Inspector following guidelines of CNRL's Owner-User Inspection Program)  Reports reviewed and accepted by:  Mechanical Integrity Coordinator Date												

<b>External Inspection Items</b>	G	F	P	N/A	Comments
<b>Insulation</b> Verify sealed around manways, nozzles, no damage present, and there is no egress of moisture.				X	
External Condition Assess paint condition, areas peeling, record any corrosion, damage, etc (record location, size and depth of corrosion or damage)					Paint is in good condition, no exposed metal.
Leakage Record any leakage at flanges, threaded joints, weep holes on repads, etc.	Х				No leaks found.
Skirt/ Saddle Assess condition of paint, fire protection, concrete. Look for corrosion, buckling, dents, etc. Look at vessel surface area near supports. Verify no signs of leakage at attachment to vessel and attachment welds are acceptable. Ground wire attached?	X				Skirt is bolted to skid floor. No distortion to skirt, paint is in good condition. No signs of leaks. Attachment welds are acceptable. Ground wire is attached to skid.
Anchor Bolts Hammer tap to ensure secure.  Look for cracking in threads or signs of deformation.	Х				Anchor bolts are secure to skid.
Concrete foundation Check for cracks etc.				X	
Ladder / Platform Describe general condition, ensure support is secure to vessel, and describe any hazards.	Х				Ladder is secure to vessel.  Ladder access is at roof level of skid building.
<b>Nozzle</b> Assess paint, look for leakage, and ensure stud threads are fully engaged. Record any damage, deflection, etc. Are nozzles gusseted?	X				Nozzle paint is in good condition. No damage or deflection noted. No gussets.
Gauges Ensure gauges are visible, working, no leakage, and suitable for range of MAWP/ Temp.	X				Gauges are visible, working, and suitable for range of MAWP and temperature. No leaks found.
External Piping Ensure pipe is well supported. All clamps, supports, shoes, etc. in place. Look for evidence of structural overload, deflection, etc. Paint condition, external corrosion?	X				Piping is well supported, clamps are in place. Paint is in good condition, no exposed metal.
Valving Ensure no leaks are visible. Valves are properly supported and chained if necessary.	X				No leaks found.
<b>PSV</b> Ensure PSV is set at pressure at or below that of vessel. Discharge piping is same size as inlet to valve and is properly supported and routed. Ensure no block valves between psv and vessel or if there are they are locked open.		X			Located on top head – set above MAWP of vessel by 1 PSI. PSV seal in place. Discharge piping is same size as valve outlet. No block valve between vessel and PSV inlet
NDE methods Was UT/ MPI done on vessel (MI coordinator to review results)	X				Ultrasonic thickness survey carried out – no metal thickness detected below nominal minus corrosion allowance.
Other					

Recommendations or corrective actions: Vessel is Fit for Service or describe corrective actions required)

(MIC to review corrective actions with Operations, discuss with Chief Inspector where necessary, and get remedial action implemented)

Recommendations: 1. Service PSV at next available opportunity.

**Summary:** Vessel is in overall good condition, visual external inspection and ultrasonic corrosion survey performed – no metal thickness detected below nominal minus corrosion allowance.

Corrosion rate based on greatest thickness loss (head) 0.004mm per year. Retirement Date to "T"min is year 3495.

Vessel is fit for service.

**Inspected By:** Chris Maxsom **Date:** June 24, 2013





LSD Overview - Skid





Overview - Lower shell Overview - Upper shell





Data plate Pressure gauge

