



PSV DATA
 MFG: FARRIS
 MODEL: 26HA13-120/S7
 SERIAL: 449517-1-A10
 SET PRES: 9929 kPa
 CAPACITY: 21951 scfm
 SERVICED BY: N/S
 SERVICE DATE: N/S
 SIZE: 2" x 3"
 CODE STAMP: UV/NB
 BLOCK VALVE: NO
 CRN: 0G2362.5C

Equip. No. _____ Prov. Reg. No. **487531** C.R.N. **N-0715.213** Serial No. **VS-11359** Yr. Inst. _____
 Code/Div. **ASME VIII, Div1** Size: **36in x 9ft** Manufacturer: **ARGO SALES** Yr. Blt. **2003**
 C. Stamp: **U** Service: **SOUR** PWHT: **HT** Radiography: **RT1** Insulated: **NO**

Design & Materials Data

HEAD:
 Top Mat'l. **SA 516 70N** Top Nom. **39.7mm** Top C.A. **3.2mm**
 Btm. Mat'l. _____ Btm. Nom. _____ Btm. C.A. _____
CHANNEL:
 Material: _____ Nominal: _____ C.A. _____
BOOT
 Head Mat'l. _____ Head Nom. _____ Head C.A. _____
 Shell Mat'l. _____ Shell Nom. _____ Shell C.A. _____
SHELL
 Material: **SA 516 70N** Nominal: **41.2mm** C.A. **3.2mm**
 MAWP Shell Side: **9929 kPa** @ Temp. **38°C**
 MAWP Tube Side: _____ @ Temp. _____

CLIENT	CANADIAN NATURAL RESOURCES	
FACILITY	RIGEL COMPRESSOR STATION	
	LSD d-75-A/94-A-15	
ITEM	INLET SEPARATOR	
BY: DK/NR	DATE: 2011/08	DWG.# 2

UTS DATA

CLIENT: CANADIAN NATURAL RESOURCES
EQUIPMENT: INLET SEPARATOR
CRN#: N-9715.213
PROV REG: A 487531
TESTED ON STREAM

FACILITY: RIGEL COMPRESSOR STATION
SERVICE: SOUR
LOCATION: d-75-A/94-A-15
RTD JOB #: 10.110421
REFER TO DRAWING: 2

Test Point	THICKNESS DATA	Flag	T-Min	C.A.	Nom.	Short Term	Long Term	Ave. mm/py	Retirement Date
<hr/>									
215	Description: UPPER SHELL								
	2011 8								
Min. Thick.	42	38.00		3.2	41.20				
Average:	42.1					0	0		
Analysis:									
<hr/>									
220	Description: MID SHELL								
	2011 8								
Min. Thick.	42	38.00		3.2	41.20				
Average:	42.1					0	0		
Analysis:									
<hr/>									
225	Description: LOWER SHELL								
	2011 8								
Min. Thick.	41.9	38.00		3.2	41.20				
Average:	42					0	0		
Analysis:									
<hr/>									
230	Description: BOTTOM HEAD								
	2011 8								
Min. Thick.	42.2	36.50		3.2	39.70				
Average:	42.5					0	0		
Analysis:									
<hr/>									
<hr/>									

UTS DATA

CLIENT: CANADIAN NATURAL RESOURCES
EQUIPMENT: INLET SEPARATOR PIPING
CRN#:
PROV REG:
TESTED ON STREAM

FACILITY: RIGEL COMPRESSOR STATION
SERVICE: SOUR
LOCATION: d-75-A/94-A-15
RTD JOB #: 10.110421
REFER TO DRAWING: 2

Test Point	THICKNESS DATA				Flag	T-Min	C.A.	Nom.	Short Term	Long Term	Ave. mm/py	Retirement Date
205												
Description:	3" 90° ELBOW											
	2011 8											
Min. Thick.	7.2	6.65	1	7.60					0	0		
Average:	7.5											
Analysis:												
210												
Description:	6" 90° ELBOW											
	2011 8											
Min. Thick.	10.5	9.63	1.4	11.00					0	0		
Average:	10.7											
Analysis:												
235												
Description:	2" CIRC BAND											
	2011 8											
Min. Thick.	8.7	7.61	1.1	8.70					0	0		
Average:	8.9											
Analysis:												
240												
Description:	6" 90° ELBOW											
	2011 8											
Min. Thick.	12.2	9.63	1.4	11.00					0	0		
Average:	12.6											
Analysis:	2011/08 LIMITED SCAN DUE TO EXCESS EXTERNAL CORROSION											