



INSPECTION AND TEST REPORT



www.kingsenergy.com
1-866-660-KING

Owner:	CANADIAN NATURAL RES	AFE:	80023574	Date:		Job:	51272
Instructions:	<input type="checkbox"/> Rental <input type="checkbox"/> Quote <input checked="" type="checkbox"/> Pretest <input checked="" type="checkbox"/> Repair <input type="checkbox"/> Test Only <input type="checkbox"/> New <input type="checkbox"/> Reset <input type="checkbox"/> B.E.R <input type="checkbox"/> VR Update						
L.S.D.:	11-17-097-06W6	Loc:	SEPARATOR	Plant/Area:	CHINCHAGA	Unit/Vessel:	C488580

Valve Data:	-	Seal:	Intact	Style:	FLG_Conv	Inlet:	RF	Outlet:	RF
		Seal ID:	TBG	Bonnet:	Closed	Inlet Size:	1.50 inches	Outlet Size:	3.00 inches
Make:	Mercer	NamePlate:	Orig/Dupl.	Cap:	Closed	Inlet Rating:	300#	Outlet Rating:	150#
CRN:	0G8841.5C	Service:	Gas	Orifice:	F	Capacity:	5032 SCFM	Cold Diff Set:	719 psig
Asset No:	CHN11-17SEP	Product:	Gas	Orifice Area:	0.337 sq in.	Code Stmp:	NB/UV	Set Press:	719 psig
Data Plate:	91-56F11T21U1			Serial No:	154869		Replacing:		

Pilot Data:	Model:		Serial No:	
--------------------	---------------	--	-------------------	--

Pretest Data:	Test1:	Test2:	Test3:	Units:	Notes1:	Customer Request:	Pretest By:	Shaun Hitchco
	660	0	0	psig	Notes2:			

Disassembly:	-	Height:	2 Turns/Revs	Upper BDR:		Lower DBR:		Dis By:	Pat Bennett
---------------------	---	----------------	--------------	-------------------	--	-------------------	--	----------------	-------------

Inspection:	-	Replaced:	N	Converted:	N	Inspected By:	Jay Gibbons
Seat Matl:	Teflon	Bonnet Matl:	Carbon Steel	Sizing Basis:	Blocked Flow	Inlet Condition:	Oily
Body Matl:	Carbon Steel	Bellows Matl:		Spring No:		Outlet Cond:	Good

Part No \ Desc:	Bin Loc:	Condition 1	Condition 2	Recomendation	Work Done	CD Actual
2FX1T1U2 : 91 "F" TFE REPAIR KIT M 1VC1		Worn	Req's Replacing		Replaced	
107032 : DATE TAGS KINGS ENERGY						

Assembly:	-	Converted From:		Converted To:		Assembled By:	
------------------	---	------------------------	--	----------------------	--	----------------------	--

Final Test:	-	Set Press:	719 psig	Gauge 1:		Vacuum Set:			
		Back Press:		Gauge 2:		Leakage Vac:		Test Date:	
Media:	Air	Temp:	70 °F	BLD %:		Vacuum Act:		Tested By:	
Method:	Bench	Corr Factor:	1	Meas Lift:				Witness:	
Simmer:		Cold Diff Set:	719 psig	Leakage:	BPM	Set Press Def:			
Re-Seat:		Act Test Press:							

Final Insp:	Tag:	Painted:	Pallet:	Scaled:	End Protect:	Flex Gasket:	Inspector:	
							Sign Off:	
Reset Comments:	-							
Inspection Comments:	MAJOR KIT REQUIRED							
Final Test Comments:	-							
Sign Off Comments:	-							