



CUSTOMER: CUREL FACILITY: 12-09 Habbayna Battery LSD: 12-09-044-24W4M
 P & ID: _____ DRAWN BY: KK DATE: 05-07-10 DRAWING NO. 136816-KK-01

VESSEL DESCRIPTION: Trial
 Equip. No. _____ Pro. Reg. No. (A) A2548014 C.F.N. HF-5754.2 Serial No. L-8-297 Yr. Inst. _____
 Code/Div. _____ Size: 96" ID / OD X 3.60" Manufacturer: Nasco Yr. Blt. 12-1988
 C. Stamp _____ Service: SWEET PWHT: _____ J.E.: _____ Radiography: RT-4 Insulated: Partial

HEAD
 Top Mat'l 516-70 Top Nom. .688" Top C.A. .0625" Material 516-70 Nominal .375" C.A. .0625"
 Btm Mat'l 516-70 Btm Nom. .520" Btm C.A. .0625" MDMT 75 psi @ Temp -50F

BOOT
 Head Mat'l _____ Head Nom. _____ Head C.A. _____ Top Mat'l _____ Top Nom. _____ Top C.A. _____
 Shell Mat'l _____ Shell Nom. _____ Shell C.A. _____ Btm Mat'l _____ Btm Nom. _____ Btm C.A. _____
 MAWP Shell side: 75 psi @ Temp. 200°F MAWP Tube side: _____ @ Temp. _____

PIPING INFORMATION:
 Circuit. No. _____ Line No. (s) **(PLEASE PUT LINE NUMBERS ON APPLICABLE LINES ON THE DRAWING)**
 Piping Class _____ Service: _____ Yr. Blt. _____
 MAWP: _____ @ Temp. _____ Size & Schedule of Piping **(PLEASE PUT APPROPRIATE SIZES AND SCHEDULES OF PIPING ON DRAWING)**

A2542014 UT Readings

Readings in Inches

	PNT1	PNT2	PNT3
LOC5	0.310	0.311	0.308
LOC10	0.773	0.697	0.696
LOC15	0.387	0.393	0.387
LOC20	0.399	0.397	0.392
LOC25	0.413	0.409	0.408
LOC30	0.398	0.398	0.396
LOC35	0.403	0.405	0.402
LOC40	0.492	0.509	0.492
LOC45	0.266	0.270	0.258
LOC50	0.363	0.333	0.328
LOC55	0.287	0.251	0.250
LOC60	0.256	0.261	0.253
LOC65	0.279	0.270	0.270
LOC70	0.276	0.259	0.258
LOC75	0.262	0.267	0.251