

| Equip. No Prov. Reg. No. (A) C 35011 C.R | R.N. P-0620.21 Serial No. <u>032157-101</u> Yr. Inst |
|---|---|
| Code/Div. ASME VIII, DIV 1 Size: 24in x 24ft Manufactur | rer: PROPAK SYSTEMS Yr. Bit. 2003 |
| C. Stamp: Service: SOUR | PWHT: <u>HT</u> Radiography: <u>RT-1</u> Insulated: <u>NO</u> |
| Design & Materials Data | CLIENT |
| HEAD: Top Mat'l. <u>SA 516 70N</u> Top Nom. <u>24.3mm</u> Top C.A. <u>3.2mm</u> | CANADIAN NATURAL RESOURCES LTD |
| Btm. Mat'l. <u>SA 516 70N</u> Btm. Nom. <u>24.3mm</u> Btm. C.A. <u>3.2mm</u> | FACILITY PEE JAY |
| CHANNEL: Material: C.A. | SOLUTION |
| BOOT Head Mat'l Head Nom Head C.A | |
| Shell Mat'l Shell Nom Shell C.A | GLYCOL GLYCOL |
| Material: <u>SA 516 70N</u> Nominal: <u>25.4mm</u> | CONTACTOR |
| MAWP Tube Side: @ Temp | BY: KB/AN DATE: 01/2015 DWG.# 12A |

UTS DATA

CLIENT: CANADIAN NATURAL RESOURCES LTD

EQUIPMENT: GLYCOL CONTACTOR

SERVICE: SOUR

CRN#: P-0620.21

LOCATION: d-39-E/94-A-16

PROV REG: C 35011

RTD JOB #: 4025400

TESTED ON STREAM

REFER TO DRAWING: 12A

FACILITY: PEE JAY SOLUTION

| Test Point | | | THICKNESS | DATA | Flag | T-Min | C.A. | Nom. | Short Term | Long Term | Ave. mm/py | Retirement Date |
|---------------|-----------|---------|---------------------------------|------|----------|--------|--------|---------|---------------|--------------|---------------|--------------------|
| 1910 | | | | | | | | | | | | |
| Description: | MID SHE | LL | | | | | | | | | | |
| | 2015 1 | 2021 | 2 | | | | | | | | | |
| Min. Thick. | 25.1 | 23.9 | | | 22.20 | 21.9 | 3.2 | 25.40 | .2 | | .2 | |
| Average: | 25.3 | 24.3 | | | | | | | .16 | | .16 | 203 |
| Analysis: | | | | | | | | | | | | |
| 1915 | | | | | | | | | | | | |
| Description: | MID SHE | LL | | | | | | | | | | |
| | 2015 1 | 2021 | 2 | | | | | | | | | |
| Min. Thick. | 25.8 | 22.4 | | | 22.20 | 21.9 | 3.2 | 25.40 | .56 | ; | .56 | |
| Average: | 26 | 22.8 | | | | | | | .53 | | .53 | 2022 |
| Analysis: | 02/2021 N | /IN SCA | N AT MID BAND. | | | | | | | | | |
| 1918 | | | | | | | | | | | | |
| Description: | LOWER | SHELL | | | | | | | | | | |
| | 2021 2 | ? | | | | | | | | | | |
| Min. Thick. | 23 | | | | 22.20 | 21.9 | 3.2 | 25.40 | | | | |
| Average: | 23.7 | | | | | | | | 0 | | 0 | 2029 |
| Analysis: | 02/2021 N | MIN SCA | N AT MID BAND. | | | | | | | | | |
| 1920 | | | | | | | | | | | | |
| Description: | LOWER | SHELL | | | | | | | | | | |
| | 2015 1 | 2021 | 2 | | | | | | | | | |
| Min. Thick. | 26.6 | 26.4 | | | 22.20 | 21.9 | 3.2 | 25.40 | .03 | 3 | .03 | |
| Average: | 26.8 | 26.6 | | | | | | | .03 | | .03 | 2156 |
| Analysis: | | | | | | | | | | | | |
| 1925 | | | | | | | | | | | | |
| Description: | BOTTOM | 1 HEAD | | | | | | | | | | |
| | 2015 1 | 2021 | 2 | | | | | | | | | |
| Min. Thick. | 24.9 | 24.5 | | | 21.10 | 21.1 | 3.2 | 24.30 | .07 | • | .07 | |
| Average: | 25.2 | 24.9 | | | | | | | .05 | | .05 | 2072 |
| Analysis: | 02/2021 N | IIN SCA | N AT NOZZLE. | | | | | | | | | |
| 1927 | | | | | | | | | | | | |
| Description: | 1" CIRC | NOZZLE | | | | | | | | | | |
| | 2015 1 | 2021 | 2 | | | | | | | | | |
| Min. Thick. | 8.7 | 8.6 | | | 3.20 | 2.5 | 3.2 | 6.40 | .02 | 2 | .02 | |
| Average: | 8.9 | 8.8 | | | | | | | .02 | | .02 | 2387 |
| Analysis: | | | SS CALCULATION PRESSURE VESS | | 510 RI | EFEREI | NCES 2 | .5mm AS | MINIM | IUM TH | HICKNES | S |

UTS DATA

CLIENT: CANADIAN NATURAL RESOURCES LTD

EQUIPMENT: GLYCOL CONTACTOR PIPING

CRN#: PROV REG: **FACILITY:** PEE JAY SOLUTION

SERVICE: SOUR

LOCATION: d-39-E/94-A-16 **RTD JOB #:** 4025400

| Т | ESTED | OI | N STR | EAM | REFER | то | DRAV | VING: | 12A | | | | |
|---------------|--------|-----|-------|----------------|-------|----|-------|-------|------|---------------|--------------|---------------|--------------------|
| Test Point | | | | THICKNESS DATA | Flag | | T-Min | C.A. | Nom. | Short Term | Long Term | Ave. mm/py | Retirement Date |
| 1935 | | | | | | | | | | | | | |
| Description: | 4" 90° | ELB | OW | | | | | | | | | | |
| | 2015 | 1 | 2021 | 2 | | | | | | | | | |
| Min. Thick. | 7.6 | | 7.5 | | 7.5 | 3 | 4.1 | 1.1 | 8.60 | .02 | 2 | .02 | |
| Average: | 7.8 | | 7.6 | | | | | | | .03 | 3 | .03 | |
| Analysis: | RETIR | EME | NT DA | TE 2225. | | | | | | | | | |
| 1940 | | | | | | | | | | | | | |
| Description: | 4" 90° | ELB | OW | | | | | | | | | | |
| | 2015 | 1 | 2021 | 2 | | | | | | | | | |
| Min. Thick. | 7.6 | | 7.6 | | 7.5 | 3 | | 1.1 | 8.60 | 0 | | 0 | |
| Average: | 7.8 | | 7.8 | | | | | | | 0 | | 0 | |
| Analysis: | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |

| | GF | Canadian N ENERAL PRESS | | | | N | J | ob 4025400 | | | |
|------------------|--------------------------------------|----------------------------|----------------------------------|--|-------------------------------------|---------|--------------------|------------|--|--|--|
| District: Fort S | Saint John, BC | | | Skid No. | | | | | | | |
| | Jay Solution Gas | | Location (LSD): d-39-E / 94-A-16 | | | | | | | | |
| · · | Equipment Number: Glycol Co | <u> </u> | (LSD). u v) | Z///III | | | | | | | |
| | • | untactui | | | | | | | | | |
| Orientation: V | | | | | | _ | | | | | |
| Status: Ir | 1 Service | PRESSURE VE | CCEI N | | tory Inspect | tion | | | | | |
| "A" or " | "G" or "S" (Sask.) or BC Reg | | | AVIEFLA | IE DATA | CRN Nun | nber: | | | | |
| | , , | , | | | | | | | | | |
| V11 | C35011 umber: 032157-101 | | | P 6020.21 Size: 24 in x 24 ft. | | | | | | | |
| Shell thickness | | | | | <u>in x 24 π.</u> iterial: SA 51 | 6.70N | | | | | |
| Head thickness | | | | | iterial: SA 51 | | | | | | |
| Tube wall thick | | | | Tube ma | | .0 /01 | | | | | |
| Tube diameter | | | | Tube len | | | | | | | |
| Channel thickr | | | | | material: | | | | | | |
| | Shell: 1480 PSI | | | | | Shell: | | | | | |
| Design | | | | Design p | ressure | | | | | | |
| pressure | | | | | | | | | | | |
| | Tubes: | | | | | Tubes | Tubes: | | | | |
| | Shell: 100°F | | | | | Shell: | nell: | | | | |
| Design | | | | Design 7 | Гетр. | | | | | | |
| Temp. | | | | | | | | | | | |
| | Tubes: | | Tubes: | | | | | | | | |
| X-ray: RT 1 | | | | tment: Yes | | | | | | | |
| | ers: ASME VIII, Div 1 | | | Coated: No Year built: 2003 | | | | | | | |
| | Propak Systems wance: 3.2 mm | | | Man way: No | | | | | | | |
| Corrosion and | | COLIDE CAPET | X7 X7 A T X | <u>. </u> | | Γ. Δ | | | | | |
| | rki | ESSURE SAFET | YVALV | E NAME | LAIE DAI | A | | | | | |
| PSV Tag | Manufacture // Model // | Set Pressure | Caj | pacity | Block | Size | Location | Service by | | | |
| Shell | Serial | (PSI / kPa) | (scfm | / usgpm) | Valve | | | / Date | | | |
| 25836F | Mercer / 91- | 1440 DCI | 1121 | 5 C | NI. | 1.5 2 | Lower | Feb 28, | | | |
| | 33G51P27N1 / C016222 | 1440 PSI | 1131 | 5 scfm | No | 1.5 x 2 | shell | 2020 | | | |
| | SERVI | CE CONDTION | NS-INDI | CATE AL | L THAT AF | PPLY | | 1 | | | |
| Sweet X | Sour | | Oil | | | Gas X | | Water X | | | |
| Amine | LPG | | Conde | nsate X | | Air | Air | | | | |
| Other (Describ | e): | | | | | | | | | | |
| Reports reviewed | AIC in conjunction with Chief Inspec | tor following guideli | nes of Cana | _ | rice Interval Resources Limit | | r Inspection Progr | ram) | | | |

Fill out all forms as completely as possible. <u>All information</u> is important! Use back of sheets to record additional information or sketch if required. Copy of report to be filed by MIC at site, and copy sent to Chief Inspector

| External Inspection Items | G | F | P | N/A | Comments |
|---|---|---|---|-----|--|
| Insulation Verify sealed around manways, nozzles, no damage present, and there is no egress of moisture. | X | | | | Vessel is insulated outside skid – insulation wrap – no exposed areas. |
| External Condition Assess paint condition, areas peeling, record any corrosion, damage, etc (record location, size and depth of corrosion or damage) | X | | | | Paint in good general condition – no exposed metal. |
| Leakage Record any leakage at flanges, threaded joints, weep holes on repads, etc. | X | | | | No leaks. |
| Saddle/skirt Assess condition of paint, fire protection, and concrete. Look for corrosion, buckling, dents, etc. Look at vessel surface area near supports. Verify no signs of leakage at attachment to vessel and attachment welds are acceptable. Ground wire attached? | X | | | | Skirt is in good condition – no buckles or distortion. No corrosion at skirt to head area – no leaks. Ground attached to skid. |
| Anchor Bolts Hammer tap to ensure secure. Look for cracking in treads or signs of deformation. | X | | | | Firmly bolted to skid deck. |
| Concrete foundation Check for cracks, spalling, etc. | | | | X | None. |
| Ladder / Platform Describe general condition, ensure support is secure to vessel, and describe any hazards. | | | | X | None. |
| Nozzle Assess paint, look for leakage, and ensure stud threads are fully engaged. Record any damage, deflection, etc. Are nozzles gusseted? | X | | | | All flanged and threaded fittings are fully engaged – No short studs. No deflection – no leaks. Paint is in good condition – no corrosion. |
| Gauges Ensure gauges are visible, working, no leakage, and suitable for range of MAWP/ Temp. | X | | | | Pressure gauge: No pressure gauge. Temperature gauge: 0 to 250 deg F. |
| External Piping Ensure pipe is well supported. All clamps, supports, shoes, etc. in place. Look for evidence of structural overload, deflection, etc. Paint condition, external corrosion? | X | | | | Piping is well supported; no deflection, all clamps and supports are in place. Paint is in good condition — no corroded areas. |
| Valving Ensure no leaks are visible. Valves are properly supported and chained if necessary. | X | | | | Well supported – no leaks. |
| PSV Ensure PSV is set at pressure at or below that of vessel. | X | | | | Located on lower shell – set below MAWP of vessel. Discharge piping is the same size as the outlet to PSV. No block valve present. Seal is intact. PSV vents to closed header. |

| NDE methods Was UT/ MPI done on vessel (MI coordinator to review results) | X | Ultrasonic corrosion survey carried out - pipe metal thickness detected below nominal thickness detected below nominal minus corrosion allowance. There is an increased rate of corrosion at the seal pan area – UT point 1915 – Min thickness is 22.4 mm / nominal thickness is 25.4 mm. In 2010 the minimum thickness was 25.8 mm. UT point 1935 (4" Elbow) – nominal thickness is 8.6mm / min thickness is 1.1mm / T min thickness is 4.1mm. |
|---|---|--|
|---|---|--|

Recommendations or corrective actions: (Vessel is Fit for Service or describe corrective actions required)

(MIC to review corrective actions with Operations, discuss with Chief Inspector where necessary, and get remedial action implemented)

Recommendations: 1. Monitor corrosion on regular set frequency. 2. Plan for a caustic wash on this contactor – it appears that the seal pan may have an amount of solids built up inside the ring causing under deposit corrosion.


Summary: This vessel is in good condition, visual external and ultrasonic thickness inspection carried out – accelerated corrosion rate from 2015 inspection.

Corrosion rate based on greatest thickness loss – min thickness is 22.4 mm / thickness in 2015 was 25.8 mm = loss of 3.4 mm in 6 years = .556 mm per year = T min based on MAWP (1480 PSI) is 21.6 mm = retirement date of yr 2022. Vessel is fit for service.

1. 1 S API 20981 / IBPV 275

Inspected By: Dellas Wiedman Date: Feb 1, 2021

Photo Table







Anchor bolts



Temperature gauge



Glycol piping



PSV



PSV Service Tag

PSV Service Tag