



PRV INSPECTION AND TEST REPORT

BRANCH: Fort St John

UVL ID#: 2425G

Work Order: 306420

Customer PO#:

Customer: CANADIAN NATURAL RESOURCES LTD
Facility: LADYFERN
A#: A516940
Cust. Ref.:
Cust. WO#:

LSD: B-88-H/94-H-01
Vessel SN: N/A
Valve PO:
Cust AFE#:

Date: 05/06/2010
PSV Location: FILTER D.P.
Cust Id:
PO LINE#:
Cost Centre#: 35000240

VALVE DATA

Man.: MERCER Model: 91-17D51V07E1 Serial: 70417 Seat: POP
Conn. Threaded Inlet: 1" MNPT Orifice: D Outlet: 1" FNPT
Set Press. 145 PSI Back Press.: 0 PSI Cold/Diff Set Press: Temp: 70°F Cap: 319 SCFM
Lift Lever Cap Assembly: Closed Code Symbol: UV CRN#: 0G2606.5C

CUSTOMER INSTRUCTIONS

Instructions: Pretest, Service, and Test Pretest Required? [checked] Reset Required? [checked]
Replaces UVL ID#: Replaces Valve Serial#: Replaces Valve Cust ID#
RESET INFO: New Pressure: 25 PSI New Cold/Diff Set: New Capacity: 78 SCFM New Model: 91-17D51V03E1

CONDITION AS RECEIVED

Visual Condition: Good Data Plate Condition: OK Date of last service: 02-10
Seal Condition: Top: Intact Bottom: N/A Insignia: UVL Fittings Attached: Inlet: [] Outlet: []
Inlet: Carbon Inlet Plugged: [] Outlet: Product Outlet Plugged: [] Initial Insp. Signoff: JESSE BOAKE

PRETEST 1

Simmer: 143 PSI Set Press: 145 PSI Reseat: 96 PSI Leakage: 0 BPM Test Gauge: FSJ 1/2
Tested By: GRANT WATSON Pretest Comments: 0 LEAKS

PRETEST 2

Simmer: 143 PSI Set Press: 146 PSI Reseat: 98 PSI Leakage: 0 BPM Test Gauge: FSJ 1/2
Tested By: GRANT WATSON Pretest Comments: IN RANGE, 0 LEAKS - PASS

COMPONENTS INSPECTION

Table with columns: ITEM, CLEAN, OILY, RUSTY, CARBON, OTHER, COMMENTS, OK / REPLACED, REPLACED?, REPAIRS PERFORMED. Rows include DISC, NOZZLE, CAP-LEVER ASSY, COMP SCREW and LOCKNUT, SPRING and BUTTONS, SPINDLE / STEM, STEM RETAINER, DISC HOLDER, GUIDE / UPPER RING, LOWER RING, RING PIN(S), BELLOWS, GASKET / SEALS, CONNECTION ENDS, OTHER.

DISC: : NA ACT - NOZZLE: MIN - VITON ACT - NUMBER: 05-007

Comments:

Disassembly: HARLEY ANDERSON Inspection: HARLEY ANDERSON Reassembly: HARLEY ANDERSON

FINAL TEST

Test Medium: Air Simmer: 24 PSI Set Pressure: 25 PSI
Reseat: 23 PSI Leakage: 0 BPM B.P. Test: 60 PSI Cold/Diff Set: PSI
ADJ. RING SETTING (NOTCHES): Upper: NA Lower: NA Test Gauge: FSJ 1/2 Set Press Def: POP
Tested by:

FINAL INSPECTION:

SEAL: Top: [checked] Bottom: [] End Protectors Installed: [checked] Painted: [checked] Palletized: [] Ship Container: [checked] Flex Gaskets Supplied: []
Final Inspection: HARLEY ANDERSON Customer Inspection:
Comments: NEW CAPACITY CALCULATED AS PER MERCER SLOPE