



CT-500  
DEHYDRATOR  
24" OD TOWER WITH 8 TRAYS  
250, 000 BBL/H  
REGULATOR  
684# ANSI DESIGN

CT-600  
DEHYDRATOR  
30" OD TOWER WITH 8 TRAYS  
375, 000 BBL/H  
REGULATOR  
684# ANSI DESIGN

F-502  
COALESCING FILTER  
VERTICAL, 24" OD x 8'-0" H,  
5/8" S/S,  
3/16" REMOVABLE ELEMENTS  
0.3 MICRON DESIGN

F-700  
COALESCING FILTER  
VERTICAL, 36" OD x 8'-0" H,  
5/8" S/S,  
3/16" REMOVABLE ELEMENTS  
0.3 MICRON DESIGN

ST-701  
STORAGE TANK  
400 BBL (HEATED)

K-703  
FKOD  
100bbl

ES-704  
FLARE STACK

				SOUTH STURGEON COMPRESSOR STATION LSD 15-16-69-22 W5M	
PREPARED BY: SU		SCALE: NTS		PROCESS FLOW DIAGRAM	
DRAWN BY: SU		JOB NUMBER: 20129		DRAWING NUMBER: 002	
PERMIT:		SEAL:		REV NO: 1	
FROM 001 COMPARATOR DRAIN HEADER		FROM 001 H.P. SEPARATOR		FROM 001 FLARE HEADER	
1 AS BUILT 0 ISSUED FOR CONSTRUCTION		BY DATE DPK 01/09/19 DPK 01/03/19		CHECK APP REFERENCE DRAWING	
REV DESCRIPTION		DATE		APP	