T-140
DRAIN TANK
SERVICE DEHYDRAYTOR DRAIN
CAPACITY 2500 LITRES
CONSTRUCTION HEAVY WALL, RIBBED FIBREGLASS

T-300
GLYCOL CONTACTOR
762mm O D x 7620mm S/S
D P 9308 kPa @ 66°C
C A = 1.6mm
8 TRAY ABSORBER

E-300
GAS/GLYCOL EXCHANGER
100mm O D x 152mm O D x 3048mm LG
DOUBLE PIPE EXCHANGER

P-400
GLYCOL PUMP
KIMRAY 21015 PV

E-402
AIR/GLYCOL EXCHANGER
8 PASSES x 1524 mm LG

F-403
GLYCOL FILTER
CUNO IB2
CARTRIDGE TYPE

H-401
GLYCOL REGENERATOR w/ STRIPPING
500,000 BTU/hr
REBOILER 762 mm O D x 3048 mm LG
SURGE TANK 508 mm O D x 3048 mm LG
STILL COLUMN 324 mm O D x 2743 LG

F-500
VENT STACK
168 mm O D x 219 mm
12.2 m HIGH

AMOCO BUY BACK
VENT HEADER
FUEL / START / INSTRUMENT GAS
GAS FROM COMPRESSOR
402-168V-A
300-60F-A
308-60F-A
407-89V-A
106-114P-C
502-60D-A-I
403-168V-A
108-114P-C
109-114P-C
60 PUMPOUT c/w KAMLOK COUPLER
VENT/LUBE OIL KNOCKOUT POT
THIEF HATCH SET @ kPa & VAC
DOWNDRAFT DIVERTER
STEAM OUT - PIPED TO 60mm ABOVE GRADE AND INSULATED c/w VENT TEE ON 45 TOP SECTION
BURNER 60mm VIEWING PORT & 60mm REMOVABLE CAP FOR LIGHTING
GLYCOL FILL O/S BLDG
START-UP BY PASS
DRAIN O/S
INSULATION KIT
INSUL UNION
AMOT LATCH
BY MECH CONTRACTOR
89 PLUG
89 KAMLOK QUICK COUPLER c/w CAP
89 VENT
SLOPE
60 NPT
AMOCO BUY-BACK GAS METER BLDG.
SALES GAS TO M
DEHYDRATOR PACKAGE

DEC 5 1990
FOR INFORMATION ON

NO	BY	DESCRIPTION	DATE
3	BM	AS BUILT	95/10/26
2	SL	REVISED PSV 108 SETTING	90/12/20
1	SCB	ISSUED FOR CONSTRUCTION	90/11/05

REVISIONS

DWG NO | DESCRIPTION
REFERENCE DRAWINGS

PERMITS
PERMIT TO PRACTICE
C I D L PROJECTS LTD
Signature
Date
PERMIT NUMBER P 3270
The Association of Professional Engineers Geologists and Geophysicists of Alberta

THIS DRAWING AND THE DESIGN IT COVERS ARE CONFIDENTIAL AND THE PROPERTY OF C I D L PROJECTS LTD AND SHALL NOT BE DISCLOSED TO OTHERS OR REPRODUCED IN ANY MANNER OR USED FOR ANY PURPOSE WHATSOEVER WITHOUT THE OWNER'S WRITTEN CONSENT

C I D L PROJECTS LTD
CALGARY ALBERTA

CLIENT CANADIAN NATURAL RESOURCES LTD
CALGARY ALBERTA

McMULLEN COMPRESSOR STATION
LSD 10, SEC 24, TWP 77, RGE 26, W4M

PROCESS & INSTRUMENTATION DIAG
DEHYDRATOR/ESDV & FLARE AR

DWN BY C GRIFFETH	DATE 90/08/09	SCALE NONE	
CHKD BY	DATE	DWG NO	D-MCM-320-04
APPD BY	DATE		