Canadian Natural Resources Ltd. GENERAL TANK INFORMATION Job # 10.110419									
District: Ft. St. Jo	ohn B.C.	Skid No.							
Facility: Currant (Location (LSD): b-09-C/94-A-16								
	oment Number: Knock	cout Drum		2000000 (202					
Orientation: Horizo									
Status: In service Regulatory Inspection									
Status. In service TANK NAMEPLATE DATA									
"A" or "G" o	or "S" (Sask.) or BC R	CRN Number:							
	C35006	Non Code							
Tank serial number:		Non Code Size: 30' x 60'							
Shell thickness: 9.5		Shell material: SA 36							
Head thickness: 6.4	mm	Head material: SA 36							
Deck thickness:				Deck material:					
Tube diameter:			Tube length:						
Channel thickness:	-			Channel material:					
Design pressure	Shell: Atmos			Operating pressure		Shell:			
	Tubes:					Tubes:			
Design Temp.	Shell:			Operating temperature		Shell:			
6 1	Tubes:				Tubes:				
X-ray: Nil	÷	Heat treatment: Nil							
Code parameters: N		Coated:							
	ado Flare Systems Inc.	Year built: N/S							
Corrosion allowanc		Manway: Yes VE NAMEPLATE DATA							
		KESSUKE SAFETY		E NAMEPLA I				1	
PSV Tag #	Manufacture	Model #		Serial #		essure	Capacity	Service	
				(F			(scfm)	Date	
	Taylor	Т8200-2		50141-21 1			222	24/02	
								2010	
CRN #	Service By	Block Valve		Location	Size		Code Stamp		
OG1326.2C	Pimm's	no		Top shell	2 x 2		UV NB		
	SERV	VICE CONDITION	<u> </u> S-INDI	ICATE ALL TH	AT APPL	V			
Sweet						Gas	v	Water X	
				Oil X			Λ		
Amine LPG Con				densate		Glycol			
Other (Describe):									
Inspection Interva (Determined by MIC in	conjunction with Chief Insp	pector following guideline	s of CNR	_PSV Service In L's Owner-User Insp		n)			

Reports reviewed and accepted by: Mechanical Integrity Coordinator_____

_Date__

External Inspection Items	G	F	Р	N/A	Comments
		1	1	14/14	
Insulation Verify sealed around manways, nozzles, no damage present, and there is no egress of moisture.				X	No Insulation
External Condition Assess paint condition, areas peeling, record any corrosion, damage, etc (record location, size and depth of corrosion or damage)		x			Paint is in good condition. No signs of damage or distortion
Leakage Record any leakage at flanges, threaded joints, weep holes on repads, etc.	X				No leaks observed.
Base Assess condition of paint, fire protection, concrete. Look for corrosion, buckling, dents, etc. Is tank mounted above ground water level – on pilings?	x				Saddles (x2) are firmly welded to shell. No signs of cracking or leaking from welds. Skid mounted on pilings. Skid tack welded to pilings. Ground wire attached to piling.
Anchor Bolts Hammer tap to ensure secure. Look for cracking in treads or signs of deformation. Is tank resting on deck – welded to supports?				X	
Concrete foundation There may be a concrete ring under the tank. Check for cracks, spalling, etc.				X	None present.
Ladder / Platform Describe general condition, ensure support is secure to vessel, and describe any hazards.				x	None present.
Nozzle Assess paint, look for leakage, and ensure stud threads are fully engaged. Record any damage, deflection, etc. Are nozzles gusseted?	x				Studs are fully engaged. No leaks observed. No damage or deflections. Nozzles are not gusseted
Gauges Ensure gauges are visible, working, no leakage, and suitable for range of MAWP/ Temp. Remember some tanks require fuel gas or other positive protection so a pressure gauge may be installed.	x				Liquid Level Gauge intact.
External Piping Ensure pipe is well supported. All clamps, supports, shoes, etc. in place. Look for evidence of structural overload, deflection, etc. Paint condition, insulation condition, any wet insulation	x				External piping is in good overall condition. Pipe supports, clamps and shoes are in place. No structural overload or deflection.
Valving Ensure no leaks are visible. Valves are properly supported and chained if necessary.	x				No leaks are visible at time of inspection. Valves are supported properly
PSV Ensure PSV is set at pressure at or below that of vessel. Some tanks have positive gas protection for cover – this may be a vacuum breaker – have a good look and check serviceability tag.	X				Located on top shell. Set pressure at 15 PSI Seal intact. No block valves. Discharge piping is same size as valve outlet.

NDE methods Was UT/ MPI done on vessel	X				Ultrasonic corrosion survey carried out – pipe metal thickness
(MI coordinator to review results)					detected below nominal minus corrosion allowance.
Secondary Containment: This may be a					Steel C-ring with vinyl liner.
double wall tank with a pressure gauge or	Χ				No signs of damage or distortion.
level gauge indicator.					
Recommendations or corrective actions : Vessel is Fit for Service or describe corrective actions required)					
(MIC to review corrective actions with Operations, discuss with Chief Inspector where necessary, and get remedial action					
implemented)					
Recommendations Summary: Install Data Plate					
Summary: This vessel is in good condition, visual external and ultrasonic thickness inspection carried out – pipe metal thickness					
detected below nominal minus corrosion allowance.					
Vessel is fit for service.					

Inspected By: Mike Dutcher

Date: August 03, 2011



