



Mountain West Services Ltd.

Inspection Report - Barrick # 7996

[\[www.mtnwest.ca\]](http://www.mtnwest.ca) [\[Company Index Page\]](#) [\[Vessels\]](#) [\[Pipelines\]](#) [\[SMART\]](#) [\[Incidents\]](#) [\[Work Orders\]](#) [\[Management of Change\]](#)

102369- FWKO

VT External

| | | | |
|-------------------------------|----------------|-----------------------------|-------------------|
| Province: | Alberta | Manway: | Yes |
| District: | STURGEON LAKE | Coating: | |
| Location: | STURLS | Inspect Date: | 12/22/2009 |
| LSD: | 10-29-071-23W5 | Inspection Interval: | 60 |
| CRN: | A9372.2 | Next Inspection: | 12/22/2014 |
| Skid/Equipment Number: | PKG54776 | MAWP: | 50 PSI 344.74 KPa |
| Service: | SOUR | Temperature: | 200 F 93.33 C |
| Status: | In Service | Outstanding NCRs: | 0 |

General:

Safety Valves:

PSV [FLD2219](#) Protects the Shell Of the Vessel. Set Pressure of 50 PSI / 344.74 KPa. Capacity: 3469SCFM / 98.23m3/min

| | | | |
|---------------------------|--------------------------------|-------------------------|-----------------------|
| Status: In Service | Examination Methods: VT | Access: External | Cleaning: Good |
|---------------------------|--------------------------------|-------------------------|-----------------------|

External:

All visible shell surfaces and nozzles appear in good condition. Name plate is intact and legible. Vessel supports, foundation, electrical grounding and external coating appear good. Associated piping, supports and components appear in good condition and alignment with no signs of leaks or defects present at the time of inspection. No evidence of short studding or nut rounding at time of inspection. Verify PSV protection and PSV's are properly installed with any block valves locked/sealed open. (PSV's isolating inlet/outlet block valves not locked/sealed open.) Verify vessel has Alberta CRN and A# stamping, PSV has correct code stamp, set pressure and MWS tagging, and was last serviced within the required interval guidelines. Assign inspection interval.

Internal:

Recommendations:

PSV's isolating inlet/outlet block valve requires installation of a lock or seal to the open position.

Inspector's Declaration: I have witnessed the above inspections and certify that they have been done in accordance with our manual and that the information is accurate. I certify that the status of the pressure equipment detailed here is:

Suitable to be returned to service: Yes

Repairs complete: N/A

Repairs are still required: No

Suggested Inspection Interval: 60

Inspector: Leo Nedelec, MWS **Date:**
12/22/2009

Chief Inspector: I certify that the information on this report is true and that all inspections required by the Owner/User Quality Assurance Program# AQP-9013 which expires in 12/11/2010 have been done.

Chief Inspector: Jim Damiani Cert 00037
Date: 12/27/2009

[\[Back To Start Page\]](#) [\[MtnWest.Ca\]](#)