



**V-310**  
**GLYCOL CONDENSATOR**  
 SIZE: 810 mm x 1830 mm LONG (SERIES)  
 MFG: N/A  
 SN: 99-100-1  
 CRN: 17/70-31  
 A No.: 445902  
 MFG: SERVAL PROCESS INDUSTRIES

**V-315**  
**FUEL GAS SCRUBBER**  
 SIZE: 210 mm x 762 mm TALL  
 MFG: N/A  
 SN: 86-817-116  
 CRN: N/A  
 A No.: 445902  
 MFG: SERVAL PROCESS INDUSTRIES

**F-310**  
**GLYCOL FILTER**  
 MFG: N/A  
 MFG: N/A  
 MAMP: N/A

**E-320**  
**AIR/GLYCOL EXCHANGER**  
 MFG: CATADOME  
 MFG: W/2424  
 DUTY: 12,000 BTU/HR

**H-315**  
**BUILDING HEATER**  
 MFG: KIRBY  
 MFG: 8015 PV  
 CAP: 90 GPH

**P-300 & 301**  
**GLYCOL CIRCULATION PUMPS**  
 MFG: FLUREK  
 MFG: CT-112-GFM  
 SN: V-122-1  
 CRN: F-106-12  
 MAMP: 10A P/S @ 21°C

**F-316**  
**GLYCOL FILTER**  
 MFG: N/A  
 MFG: N/A  
 MAMP: N/A

**H-320**  
**GLYCOL RECONCENTRATOR**  
 SIZE: 810 mm x 1830 mm LONG (SERIES)  
 MFG: N/A  
 SN: N/A  
 CRN: N/A  
 DUTY: N/A

**VENT TO DRAIN**  
 48-600  
 60-150  
 89-AS-FL-559

AutoCAD 14 MILB63G-220-0009

NO.	DATE	REVISIONS	DESIGN	DESIGN	APPR.	ENGINEERING
3	27 07 08	AS IS AS PER FIELD VISIT	WRM	WRM		
2	19 08 08	DEHYZATOR # 1 REMOVED FROM SERVICE	WRM	WRM		
1	16 05 06	AS-IS	WRM	WRM		

  

NO.	DATE	TITLE
		REFERENCE DRAWINGS
		MILB63G-220-0029 MECHANICAL FLOW DIAGRAMS
		MILB63G-221-0001 PROCESS FLOW DIAGRAM
		D-MC-210-03 PLOT PLAN

  

APPROVED	FOR CONSTRUCTION
BY: _____ DATE: YY MM DD	BY: _____ DATE: YY MM DD

  

PROFESSIONAL AND PERMIT STAMPS AFFIXED HEREUNDER SHALL APPLY ONLY TO REVISION(S)	PROFESSIONAL AND PERMIT STAMPS

**NORTHERN DRAFTING SERVICES LTD.**  
 OFFICE DESIGN AND DOCUMENTATION  
 11-250-785-0131

**Canadian Natural**

b-63-C, 94-H-2 MILLIGAN # 1 BATTERY  
 DEHYDRATION  
 MECHANICAL FLOW DIAGRAM

CLIENT FILE NO. \_\_\_\_\_ SCALE \_\_\_\_\_  
 CLIENT DRAWING NUMBER \_\_\_\_\_ NTS \_\_\_\_\_  
 CLIENT DWG NUMBER \_\_\_\_\_ MILB63G-220-0009

33-AS-FG-416  
 FUEL GAS SUPPLY  
 MILB63G-220-0022

114-CS-04-103  
 FROM COMPRESSION  
 MILB63G-220-0008

114-CS-04-104  
 SALES GAS  
 MILB63G-220-0010