



**PRESSURE VESSEL
VISUAL INSPECTION
REPORT**

Report #: **123844-DB-09**
Inspect Date: 07/16/2010
Page: 1 of 10
Insp. Co. Job #: 123844

Criticality Designation:

Green

Insp. Comp: Matrix Inspection District: Slave Lake Field: North Britnell
Location: 06-26-082-20 W4 Unit / Skid #: Pad # 24 POLYMER LSD: 06-26-082-20 W4
Jurisdiction #: C43478 Equip Tag #: #B-176 Serial #: FK0D-JH-T75-13446
CRN #: N/A Nat'l Bd #: N/A Year Built: 2004
Manufacturer: Bilton Welding and Manufacturing Equipment Description: Other: Flare knock out drum. (Facility)
Status: In Service - Equip. Type: Vessel: Flare K.O. Drum Service: Sweet
MAWP Shell: 14.9 Psi @ Volume: Code Stamp: ☒ Y ☐ N
MAWP Tube: @ Height/Length: 120 in. Insulated: ☒ Y ☐ N
MDMT: -20 °F RT: N/A Size/Diameter.: 72 in. O.D. PWHT: ☐ Y ☒ N
Support Legs Vessel on Original CNRL Inventory List: ☐ Y ☒ N Manway: ☒ Y ☐ N
C.A.: N/A Coated: N/A Clad: No J.E.: N/A Remote Access: ☐ -

Component	Material	Nominal Thk	Diameter	OD/ID	Tube Side	Shell Side
1 Main - Shell	SA-516-70N	0.375 in.	72.000 in.	OD	☐	☒
2 East - Head	SA-516-70N	0.375 in.	72.000 in.	OD	☐	☒
3 West - Head	SA-516-70N	0.375 in.	72.000 in.	OD	☐	☒
4 -					☐	☐
5 -					☐	☐

Static Data: Confirmed ☒ Changed (See Comments) ☐

Comments:

Nameplate secure and legible.
Contains adequate information.

PSV Static Data

PSV -1 Tag #: N/A Serial #: N/A CRN: N/A
Model #: N/A Capacity: N/A Set Pressure: N/A
Manufacturer: N/A Service Company: N/A
Inlet Size & Type: - Last Service Date: N/A
Outlet Size & Type: - Block Valve: - -
Carseal Intact: Code Stamp:
Shell Side / Tube Side: Out for Service During Insp.: Location of PSV:

PSV -2 Tag #: N/A Serial #: N/A CRN: N/A
Model #: N/A Capacity: N/A Set Pressure: N/A
Manufacturer: N/A Service Company: N/A
Inlet Size & Type: - Last Service Date: N/A
Outlet Size & Type: - Block Valve: - -
Carseal Intact: Code Stamp:
Shell Side / Tube Side: Out for Service During Insp.: Location of PSV:

PSV Comments

NOT APPLICABLE VESSEL IS ATMOSPHERIC.



PRESSURE VESSEL VISUAL INSPECTION REPORT

Report #: **123844-DB-09**
 Inspect Date: 07/16/2010
 Page: 2 of 10
 Insp. Co. Job #: 123844

Insp. Company: Matrix_Inspection LSD: 06-26-082-20 W4 Jurisdiction #: C43478

External Inspection Results – VE External Inspection Performed

Item	N/A	Condition	Comment (Check Status Bar or Press F1 for Help)	NCR	Action Item Integrity	Action Item Maintenance
Nameplate	☐	Accept	Name plate attached and legible	☐	☐	☐
Foundation and Supports	☐	Accept	Ground wire clean and tightly attached to skid	☐	☐	☐
Anchor Bolts	☐	Accept	Anchor bolts in good condition, and tight	☐	☐	☐
Grounding	☐	Accept	Ground wire clean and tightly attached to skid	☐	☐	☐
Insulation Condition	☒		Not applicable	☐	☐	☐
PSV	☒		Not applicable	☐	☐	☐
Shell Heads & Nozzles	☐	Accept	In good condition, insulation in good condition	☐	☐	☐
Metal Surfaces (Paint)	☒		Not applicable	☐	☐	☐
Aux Equipment	☒		Not applicable	☐	☐	☐
Cathodic Protection	☒		Not applicable	☐	☐	☐
Alignment	☐	Accept	Alignment is good	☐	☐	☐
Flange Connections	☐	Accept	Flanges are tight, bolts good condition	☐	☐	☐
Pressure Gauge	☒		Not applicable	☐	☐	☐
Temperature Gauge	☒		Not applicable	☐	☐	☐
Sight Glass	☒		Not applicable	☐	☐	☐
Ladder / Platform	☒		Not applicable	☐	☐	☐
Leaks	☐	No	No evidence of leakage	☐	☐	☐
Piping from Vessel	☐	Accept	Piping in good condition, well supported, no evidence of leakage			
Previous UT Survey	☐	No	No previous inspection	UT Company:		

External Visual Observations

Davot arm is in good condition and functional
 Piping well supported and clean
 No evidence of product leakage
 Piping in good condition, well supported, no evidence of leakage
 Flanges are tight, bolts good condition
 Ground wire clean and tightly attached to skid
 Anchor bolts in good condition, and tight
 In good condition, insulation in good condition

Recommendations:

No problems noted



**PRESSURE VESSEL
VISUAL INSPECTION
REPORT**

Report #: **123844-DB-09**
Inspect Date: 07/16/2010
Page: 3 of 10
Insp. Co. Job #: 123844

Insp. Company: Matrix Inspection LSD: 06-26-082-20 W4 Jurisdiction #: C43478

Internal Inspection Results – VI N/A (Not Applicable)

Item	N/A	Condition	Comment (Check Status Bar or Press F1 for Help)	NCR	Action Item Integrity	Action Item Maintenance
Shell	☒		No Internal Inspection Carried Out	☐	☐	☐
Heads	☒		No Internal Inspection Carried Out	☐	☐	☐
Manway	☒		No Internal Inspection Carried Out	☐	☐	☐
Gasket Surfaces	☒		No Internal Inspection Carried Out	☐	☐	☐
Welds	☒		No Internal Inspection Carried Out	☐	☐	☐
Refractory	☒		No Internal Inspection Carried Out	☐	☐	☐
Heating Coils	☒		No Internal Inspection Carried Out	☐	☐	☐
Demister Pad	☒		No Internal Inspection Carried Out	☐	☐	☐
Vane Pack	☒		No Internal Inspection Carried Out	☐	☐	☐
Baffles	☒		No Internal Inspection Carried Out	☐	☐	☐
Trays	☒		No Internal Inspection Carried Out	☐	☐	☐
Filter	☒		No Internal Inspection Carried Out	☐	☐	☐
Internal Coating	☒		No Internal Inspection Carried Out	☐	☐	☐
Tubesheet	☒		No Internal Inspection Carried Out	☐	☐	☐
Tube Bundle	☒		No Internal Inspection Carried Out	☐	☐	☐

Internal Visual Observations

No Internal Inspection Carried Out

Recommendations:

No Internal Inspection Carried Out



PRESSURE VESSEL
VISUAL INSPECTION
REPORT

Report #: **123844-DB-09**
Inspect Date: 07/16/2010
Page: 4 of 10
Insp. Co. Job #: 123844

Insp. Company: Matrix Inspection LSD: 06-26-082-20 W4 Jurisdiction #: C43478

Firetube Static Data N/A (Not Applicable)

Diameter: Not Applicable Nom Thickness: Not Applicable Bend: Not Applicable
Length: Not Applicable Firetube Description: Not Applicable
Firetube NDE UT ☐ Report#: Not Applicable ET ☐ Report#: Not Applicable
Performed: MT ☐ Report#: Not Applicable RT ☐ Report#: Not Applicable
PT ☐ Report#: Not Applicable Other ☐ Report#: Not Applicable

Firetube Inspection Results

Item	N/A	Condition	Comment (Check Status Bar or Press F1 for Help)	NCR	Action Item Integrity	Action Item Maintenance
Burner	☒		No Firetube Inspection Carried Out	☐	☐	☐
Stack	☒		No Firetube Inspection Carried Out	☐	☐	☐
Flange (Throat)	☒		No Firetube Inspection Carried Out	☐	☐	☐
Tube Sheet	☒		No Firetube Inspection Carried Out	☐	☐	☐
Hot Side	☒		No Firetube Inspection Carried Out	☐	☐	☐
Miter	☒		No Firetube Inspection Carried Out	☐	☐	☐
Return Bend	☒		No Firetube Inspection Carried Out	☐	☐	☐
Supports	☒		No Firetube Inspection Carried Out	☐	☐	☐
Butt Welds	☒		No Firetube Inspection Carried Out	☐	☐	☐
Fillet Welds	☒		No Firetube Inspection Carried Out	☐	☐	☐

Firetube Visual Observations

No Firetube Inspection Carried Out

Recommendations:

No Firetube Inspection Carried Out



PRESSURE VESSEL
VISUAL INSPECTION
REPORT

Report #: **123844-DB-09**
Inspect Date: 07/16/2010
Page: 5 of 10
Insp. Co. Job #: 123844

Insp. Company: Matrix Inspection LSD: 06-26-082-20 W4 Jurisdiction #: C43478

Vessel NDE and Final Summary:

UT	☒	Report#:	ET	☐	Report#:
NDE Performed: MT	☐	Report#:	RT	☐	Report#:
PT	☐	Report#:	Other	☐	Report#:

Maxi-Trak Observations Summary (Summarize inspection results Max 255 Characters):

Vessel is in good external condition.
Insulation in good condition, as well as vessel components

Maxi-Trak Recommendations Summary (Summarize Recommendations Max 255 Characters):

This vessel and the components associated with it are in good external condition.
Continue to reinspect at regular intervals.

Actions Corrected at Time of Inspection: (If actions were corrected at the time of Inspection – note the corrected actions here.)

Not applicable

Additional Visual Observations

Vessel is in good condition externally.

Any other safety concerns or observations from associated equipment: (for example associated piping, buildings, pumps etc...)

Minor fouling on top from removal of old filter.



PRESSURE VESSEL
VISUAL INSPECTION
REPORT

Report #: **123844-DB-09**
Inspect Date: 07/16/2010
Page: 6 of 10
Insp. Co. Job #: 123844

Insp. Company: _____ Matrix_ Inspection _____ LSD: 06-26-082-20 W4 Jurisdiction #: C43478

Thickness and Remaining Life Evaluation “Must be Completed”

MUST BE COMPLETED AND RESOLVED WITH CNRL IMMEDIATELY UPON DISCOVERY OF LOW WALL THICKNESS AREAS

Step 1: Was any thickness measurement location found to be less than (Nominal WT – Corrosion Allowance)? **No**

If YES, proceed to Step 2; if NO, proceed to “Crack Evaluation” and “CNRL Criticality Designation”.

Step 2: Which component(s) were found below (Nominal WT – Corrosion Allowance)?

Components found below Nom - CA:

Components
N/A - N/A
N/A - N/A
N/A - N/A
N/A - N/A
N/A - N/A

Perform Steps 3 – 8 for each component with actual thickness less than (Nominal WT – Corrosion Allowance).

Step 3: Describe Location and Extent of Corrosion:

Components	Location and Extent of Corrosion
N/A - N/A	Not Applicable for this Inspection
N/A - N/A	Not Applicable for this Inspection
N/A - N/A	Not Applicable for this Inspection
N/A - N/A	Not Applicable for this Inspection
N/A - N/A	Not Applicable for this Inspection

Notes:

Not Applicable for this Inspection

Step 4:

- For shells and nozzles, calculate minimum required thickness (T-min) as per ASME Section VIII UG-27.
- For heads, calculate minimum required thickness (T-min) as per ASME Section VIII UG-32.

Components	T-Min
N/A - N/A	N/A
N/A - N/A	N/A
N/A - N/A	N/A
N/A - N/A	N/A
N/A - N/A	N/A



PRESSURE VESSEL
VISUAL INSPECTION
REPORT

Report #: **123844-DB-09**
Inspect Date: 07/16/2010
Page: 7 of 10
Insp. Co. Job #: 123844

Insp. Company: Matrix Inspection LSD: 06-26-082-20 W4 Jurisdiction #: C43478

Thickness and Remaining Life Evaluation (Continued)

Step 5: Is any measured thickness less than calculated minimum required thickness (T-min)? **N/A**

*If YES, complete Step 6
If NO, proceed to Step 7..*

Step 6: Is nature and extent of pitting acceptable as per API 510? **N/A**

Step 7: Calculate Remaining Life as per API 510. How? (Find last reading; use nominal thickness if nothing available). Short Term Corrosion Rates and Long Term Corrosion Rates.

Components	Remaining Life (Yrs)
N/A - N/A	N/A
N/A - N/A	N/A
N/A - N/A	N/A
N/A - N/A	N/A
N/A - N/A	N/A

Step 8: Contact CNRL Integrity Coordinator to discuss above results.

- Name of CNRL contact: Not Applicable for this Inspection
- Date and time of conversation: Not Applicable for this Inspection

Summary/results of conversation:
Not Applicable for this Inspection

Crack Evaluation by Magnetic Particle or Alternative Inspection “Must be Completed”

MUST BE COMPLETED AND RESOLVED WITH CNRL IMMEDIATELY UPON DISCOVERY OF CRACK-LIKE INDICATIONS


Were any indications found to suggest the vessel contained cracks? **No**

If NO, proceed to “CNRL Criticality Designation”.

If YES, Contact CNRL Integrity Coordinator to discuss results.

- Name of CNRL contact: Not Applicable for this Inspection
- Date and time of conversation: Not Applicable for this Inspection

Summary/results of conversation:
Not Applicable for this Inspection



Inspector (Name):	DENNIS BOWLBY	PESL:	
Inspector (Signature):		API:	34104
CNRL Coordinator (Name):			
CNRL Coordinator (Signature):			
CNRL Chief Inspector (Signature):	(I am in full agreement with report contents)		
	(I am in full agreement with report contents)		

Equipment Photographs:



FIGURE_001_NAMEPLATE



FIGURE_002_OVERVIEW



FIGURE_003_GROUND



FIGURE_004_SUPPORTS