	G	Canadian Na ENERAL PRESSUR		Resources Ltd. SEL INFORM	ATION		Job# 105.0	00390	
District: Fort St J	John, BC		Skid No.						
Facility: Ladyfern		Location (LSD): b-17-I/94-H-01							
-	-			Location (LS)	<i>D)</i> ;	94-11- 01			
Vessel Name Equip	pment Number: Inlet	Separator - Train 3	/ V 310						
Orientation: Horiz	zontal								
Status: In Ser	rvice			Regulatory	Inspection				
		PRESSURE VESS	SEL NA	MEPLATE D	ATA				
"A" or "G" o	CRN Number:								
X7 1 1 1	RAE# 5248			G' (/N \$7 A)	. 411	P-2191.	21		
Vessel serial number Shell thickness: 88.				Size: 66" X 314"					
Head thickness: 88.				Shell material: SA-516-70N Head material: SA-516-70N					
Tube wall thickness				Head material: SA-516-70N Tube material:					
Tube diameter:	· ·			Tube length:					
Channel thickness:				Channel material:					
Chamier unexness:	Shell: 13790 Kpa			Operating pressure		Shell: 0 Kpa			
Design pressure									
	Tubes:				Tubes:				
Design Temp.		Operating temperature		Shell: 0 deg C					
Design Temp.	Tubes:	Tubes:			Operating temperature		Tubes:		
X-ray: RT-1				Heat treatment: Yes					
Code parameters: A	SME Sec VIII			Coated: No					
Manufacturer: Prop		Year built: 2001							
Corrosion allowance		Manway: Yes							
	P	RESSURE SAFETY	VALV						
PSV Tag #	Manufacture Model #			Serial #	Set Pressure		Capacity	Service	
				(K _I		oa)	(scfm)	Date	
9902F	Mercer	95-73.1M1307NS		26445	9791		102668	01/2006	
CRN#	Service By	Block Valve	Location		Size		Code Stamp		
0G2606.5C	N/S	Yes – Both Locked open	Iı	Inlet piping		6 "	UV/NB		
	SER	VICE CONDITIONS	S-INDIO	CATE ALL TE	IAT APPL	Y			
G T		VICE CONDITIONS		CHIL HEE H					
Sweet X	Sour					Gas X		Water X	
Amine	Amine LPG Co			ondensate X		Air		Glycol	
Other (Describe):									
Inspection Interva (Determined by MIC in		pector following guidelines		PSV Service In 2's Owner-User Insp		m)			
Reports reviewed and ac Mechanical Integr					Σ)ate			
T211 4 11 6							1 . 1 . 6		

External Inspection Items	G	F	P	N/A	Comments
Insulation Verify sealed around manways, nozzles, no damage present, and there is no egress of moisture.		X			Half of the vessel is wrapped with insulated tarps – this appears to be a temporary condition.
External Condition Assess paint condition, areas peeling, record any corrosion, damage, etc (record location, size and depth of corrosion or damage)	X				Paint is in good overall condition – No chipped or exposed metal - no previous corrosion.
Leakage Record any leakage at flanges, threaded joints, weep holes on repads, etc.	X				No leaking detected.
Saddle Assess condition of paint, fire protection, and concrete. Look for corrosion, buckling, dents, etc. Look at vessel surface area near supports. Verify no signs of leakage at attachment to vessel and attachment welds are acceptable. Ground wire attached?	X				No distortion to saddles – no leaks at saddle to shell welds. No exposed metal – no corrosion. Ground cable attached to skid unit & pilings.
Anchor Bolts Hammer tap to ensure secure. Look for cracking in treads or signs of deformation.	X				Separator is firmly bolted to skid floor. No signs of deformation.
Concrete foundation Check for cracks, spalling, etc.				X	None.
Ladder / Platform Describe general condition, ensure support is secure to vessel, and describe any hazards.				X	None.
Nozzle Assess paint, look for leakage, and ensure stud threads are fully engaged. Record any damage, deflection, etc. Are nozzles gusseted?	X				All threads connections fully engaged. No deflection – no leaks. No gussets.
Gauges Ensure gauges are visible, working, no leakage, and suitable for range of MAWP/Temp.	X				Gauges are visible, appears to be functional, no leaks and suitable for range of MAWP/Temp. Pressure gauge: 0-14000 Kpa @ 0 Kpa. Temperature gauge: 10-150 deg C @ 0 deg C.
External Piping Ensure pipe is well supported. All clamps, supports, shoes, etc. in place. Look for evidence of structural overload, deflection, etc. Paint condition, external corrosion?	X				Well supported – no deflection – all clamps and shoes in place. Piping is painted and in good condition – no exposed metal or surface corrosion found.
Valving Ensure no leaks are visible. Valves are properly supported and chained if necessary.	X				Well supported – no leaks.
PSV Ensure PSV is set at pressure at or below that of vessel.	X				Located on inlet piping - set below the Inlet Separator's MAWP. Discharge piping is larger than the inlet to PSV. Block valve locked open. Seal is intact. PSV vents to flare.
NDE methods Was UT/ MPI done on vessel (MI coordinator to review results) Other	X				Ultrasonic thickness survey carried out-no metal thickness detected below nominal.

Recommendations or corrective actions: Vessel is Fit for Service or describe corrective actions required)

(MIC to review corrective actions with Operations, discuss with Chief Inspector where necessary, and get remedial action implemented)

Recommendations: 1. No recommendations at this time.

Summary: This vessel is in good over all condition, visual external and ultrasonic thickness survey carried out-no metal thickness detected below nominal.

Vessel is fit for service.

Inspected By: Joseph Holdstock Date: June-06-2010.





LSD location


PAF 52.49

CERTIFIED BY
PROPAK SYSTEMS LTD.
AIROPRE ALBERTA, CANADA
MAWP 1000 PSI AT 100 PSI
SERIAL NO. 01150 201 YEAR BUILT 2011
TAG V 310

IIVIN 3 IN IT SPAVNIOR
HEAD MATERIAL SA 516 (0N
HEAD THICKNESS 3.25 IN. 82.55 MM
SHELL MATERIAL SA 516 (0N
SHELL THICKNESS 3.50 IN. 88.9 MM
MAWP 13700 KPA AT 118 °C
MDMT -28.8 °C AT 13190 KPA











Pressure Gauge



•

PSV location