



Pressure Equipment Static Data

General Information						
Date:	July 11, 2021	Location:	Surface:	B-17-I/94-H-1		
Client/Owner:	CNRL		UWI/DH:	B-17-I/94-H-1		
District/Region:	Fort St John	Location Access:	All Year			
Area:	Ladyfern	Inspection Type:	<input type="checkbox"/> Inventory <input type="checkbox"/> Internal <input checked="" type="checkbox"/> External <input type="checkbox"/> UT <input type="checkbox"/> MT			
Facility:	Compressor					
Pressure Equipment Information						
Equip Name:	Inlet Separator		CA (in):	N/A	mm:	
Manufacturer:	Propak Systems		MDMT:	- 20 F		
Provincial #:	N/A	Unit /Skid #:	Inlet Separator C Skid		PWHT:	Yes
S/N:	01150-201	Equip #:	C73757		RT:	RT-1
CRN:	P2191.21	Year Built:	2001		Manway:	Yes
NB #:	N/A	Orientation:	Horizontal			
Zones						
	MAWP (PSI)	MAWT (F)	MAWP (KPA)	MAWT (C)	Comment	
Shell Side	2000	244				
Tube Side						
Components						
	Dia (OD) in.	Type	Material	Nominal (in)	Nominal (mm)	Comment
Shell	66	Plate	SA-516-70N	3.500		
Head	66	Ellipsoidal	SA-516-70N	3.250		
Pressure Safety Valve(s)						
Zone:	Shell Side					
Equip #	N/A					
Location	Piping - Flanged					
Set Press (PSI)	1420					
Capacity	102668	SCFM				
Set Press (KPA)						
Manufacturer	Mercer					
S/N	26445					
Model	95-73.1M1307NS					
CRN	0G2606.5C					
Inlet Size (in)	4	Locked Open?				
Outlet Size (in)	6					
Inlet I/V	Yes	Yes				
Outlet I/V	Yes	Yes				
Service Co.	Unified					
Serv. Date	Jun-2018					
Service Status and Conditions						
Status:	In Service		Service:	Sweet		Primary Contents - Shell:
			Concentration:			Gas
						Primary Contents - Tube:
Comments						



Pressure Vessel External Inspection

Date: July 11, 2021		Equip Name: Inlet Separator	
Inspector: Curtis Graham		Prov #: N/A	
Client/Owner: CNRL		S/N: 01150-201	
District/Region: Fort St John		Unit /Skid #: Inlet Separator C Skid	
Area: Ladyfern		Equip #: C73757	
Facility: Compressor		Location:	Surface: B-17-I/94-H-1
			UWI/DH: B-17-I/94-H-1
Component	Condition	Comment	
Nameplate	Concern	NCR - Admin / Regulatory: No A# found. Good condition. Securely attached and legible.	
Grounding	Acceptable	Vessel is grounded through skid.	
Foundation/Supports	Acceptable	Vessel is well supported on saddles, no concerns noted.	
Ladder/Platform	N/A		
Insulation/Cladding	N/A		
Shell	Acceptable	Shell is in good condition, no concerns noted.	
Heads	Acceptable	Heads are in good condition, no concerns noted.	
Nozzles/Threadolets	Acceptable	All nozzles are in good condition. No deflection, short bolting or other concerns noted.	
Piping/Valves	Acceptable	All associated piping is in good condition. All bolting is properly installed and secure. No leaks or other concerns noted.	
Appurtenances & Instrumentation	Acceptable	Instrumentation is in good condition, no leaks noted. Pressure gauge is in good condition. Range is suitable and operating within design limits.	
Sight Glass/Level Gauges	Acceptable	All sight glasses are in good condition. Rated for current vessel service with no concerns noted.	
Other	N/A		
PSV	Acceptable	PSV is in good condition. Service seal is intact, no piping restrictions or other concerns noted. PSV has CRN and applicable code stamping present.	
NDE Methods	Acceptable	UT survey and AUT performed by Avalanche. No concerns at this time.	
Inspection Summary	NCR - Admin / Regulatory: No A# found.		
	No other concerns noted at time of inspection.		
Recommendations			NCR #
Review MDR to confirm if vessel has an A# and stamp A# in nameplate.			

Fit for Service:	Yes	Signature of Inspector:									
<small>* Fit for Service is only a recommendation based on the results of the current inspection.</small>		Cert #	API 510: 51479								
			AB/SK: 785								
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr style="background-color: #e1eef6;"> <th colspan="2" style="text-align: center;">Recommended Intervals:</th> </tr> <tr> <td style="width: 50%;">VE</td> <td style="width: 50%; text-align: center;">yrs</td> </tr> <tr> <td>UT</td> <td style="text-align: center;">yrs</td> </tr> <tr> <td>PSV</td> <td style="text-align: center;">yrs</td> </tr> </table>		Recommended Intervals:		VE	yrs	UT	yrs	PSV	yrs	Technical Manager or Delegate:	Curtis Graham
		Recommended Intervals:									
		VE	yrs								
		UT	yrs								
PSV	yrs										
		Cert #	API 510: 51479								
			AB/SK: 785								


PHOTOS



LSD Sign



Site Overview



Nameplate



C#




Overview


PHOTOS




Manway



PSV Overview




PSV Nameplate



Serviced Duplicate PSV Nameplate



PSV Service Tag





AUT CORROSION MAPPING EXAMINATION REPORT

GENERAL INFORMATION									
DATE:	July 09, 2021			REPORT #:	AUT-CG09JUL2021A				
CLIENT/OWNER:	CNRL			AVALANCHE JOB #:	20-448		CLIENT JOB #:		
DISTRICT/REGION:	Fort St John			PROJECT:	AUT Inspections		CLIENT PO #:		
AREA:	Ladyfern			LOCATION:	SURFACE:	b-17-I/94-H-1			
FACILITY:	Plant				UWI/DH:	b-17-I/94-H-1			
ITEMS EXAMINED:	Inlet Separator C73757								
METHOD(S) / SURFACE CONDITION									
MATERIAL / THICKNESS:	CARBON STEEL			PROCEDURE:	AUT-01				
SURFACE CONDITION:	Painted			ACCEPTANCE CRITERIA:	CLIENT EVALUATION				
SCANNING FROM / TEMP:	OD			18	SPECIFICATION(S):	AS PER CLIENT SPEC.			
AUT EQUIPMENT DETAILS									
MANUFACTURER:	AUT SOLUTIONS			CAL BLOCK(S):	0.750" - 1.5" STEP - C/S				
MODEL:	BANDIT			CAL BLOCK SN(S):	G11196				
RASTER LENGTH:	24"			REFLECTOR:	BACKWALL				
SERIAL #:	1005			CAL RANGE:	0.750" - 1.500"				
CAL DATE:	09-Jul-21			SIG RESP (FSH):	80%				
SOFTWARE:	PROSCAN			COUPLANT:	Water				
TRANSDUCERS					ENCODER				
MFG	TYPE	FREQ	SIZE	SERIAL #	MODEL	RESOLUTION	CAL DISTANCE		
AUT SOLUTIONS	DUAL	5MHz	0.500"	JBA158	BSP-A+	5 MHz	1.500"		
MANUAL UT EQUIPMENT									
EQUIPMENT TYPE:	DMS GO	SERIAL #:	SOPLS2012010	CAL DATE:	04-Jan-21		CABLE LENGTH/TYPE:	3' / DUAL LEMO	
REF REFLECTOR:	TYPE:	COUPLANT:	UT-X	CAL BLOCKS:	1" - 10 STEP - C/S				
PROBE TYPE	ANGLE	WAVE	FREQ	SIZE	MFG	SERIAL #	RANGE	REF LVL	SCAN LEVEL (DB)
DUAL	0	LONG	5MHz	0.250"	STRESSTEL	21A0CL0	1.000"	56	62
SINGLE									
TEST RESULTS									
SCOPE:									
<p>A ZERO DEGREE AUT MAP SCAN WAS CONDUCTED ON AREAS OF THE 66" O.D. INLET SEPARATOR SHELL. INSPECTION WAS DONE ON 35% OF THE SHELL AREA AS REQUESTED BY THE CLIENT. ALL ACCESSIBLE SECTIONS WERE INSPECTED FROM THE EXTERNAL SURFACE TO MAP OUT POSSIBLE WALL LOSS AND CORRODED AREAS OF THE SCANNED LOCATIONS. ALL AREAS IDENTIFIED WITH CORROSION ARE TO BE VERIFIED WITH MANUAL ZERO DEGREE UT.</p> <p>4 SCANS WERE UTILIZED TO OBTAIN COVERAGE OF THE SHELL AREAS.</p> <p>A ZERO DEGREE UT INSPECTION OF THE NORTH AND SOUTH HEADS WERE ALSO DONE AS REQUESTED BY THE CLIENT.</p>									
RESULTS:									
<p>NO INTERNAL CORROSION LOCATED IN THE AUT SCANNED AREAS.</p> <p>NO INTERNAL CORROSION LOCATED IN THE NORTH & SOUTH HEADS. SEE PG-2 FOR HEAD READINGS AND DESCRIPTIONS.</p> <p>SEE PAGE 3 FOR SCAN TEST RESULTS</p> <p>SEE PAGES 5 THROUGH TO 8 FOR C-SCANS, SCAN LOCATIONS AND DESCRIPTIONS.</p>									
TECHNICIAN:	Curtis Graham			ASSISTANT:	Darrin Robak				
SIGNATURE:				CLIENT:					
CGSB/SNT CERTS:	6560 UT II / MT II / PT II			SIGNATURE:					

TEST RESULTS / PHOTOS



NORTH HEAD



SOUTH HEAD

TML	NOM	LOW	AVG	COMMENT
05	3.25" (Min)	3.445"	3.556"	NO CONCERNS LOCATED
10	3.25" (Min)	3.507"	3.560"	NO CONCERNS LOCATED



AUT CORROSION MAPPING DETAILED SCAN RESULTS

SCAN #	X START	X STOP	Y START	Y STOP	X-Incr.	Y-Incr	Readings	AVERAGE READING	MINIMUM THICKNESS	NOMINAL	% Wall Loss	Comments / Corrosion Mechanism
1	0	115	0	24	0.5	0.25	22407	3.605	3.586	3.500	0.0%	No concerns
2	0	207	0	24	0.5	0.25	40255	3.621	3.582	3.500	0.0%	No concerns
3	0	207	0	24	0.5	0.25	40255	3.624	3.616	3.500	0.0%	No concerns
4	0	207	0	24	0.5	0.25	40255	3.624	3.594	3.500	0.0%	No concerns

*NOTE: ALL READINGS ARE IN INCHES.

WALL LOSS COLORING:

- 20%-34%
- 35%-49%
- 50%+

PHOTOS



NAMEPLATE




OVERVIEW



OVERVIEW

SCAN 1 START LOCATION: 30" SOUTH FROM NORTH HEAD TO SHELL CIRC WELD, AND 14" DOWN FROM EAST LONG SEAM WELD.

NOTE: RED SECTIONS ARE DUE TO PROBE LIFTOFF (NRI'S).




SCAN 1 (C SCAN)



SCAN 1 LOCATION

SCAN 2 START LOCATION: 4" NORTH FROM 2ND CIRC WELD (FROM NORTH END), AND 28.5" DOWN FROM EAST LONG SEAM WELD.




SCAN 2 (C SCAN)



SCAN 2 LOCATION

SCAN 3 START LOCATION: 26" NORTH FROM 2ND CIRC WELD (FROM NORTH END), AND 15" DOWN FROM EAST LONG SEAM WELD.




SCAN 3 (C SCAN)



SCAN 3 LOCATION

SCAN 4 START LOCATION: 10" SOUTH FROM 2ND CIRC WELD (FROM NORTH END), AND 25.5" UP FROM LONG SEAM WELD.



SCAN 4 (C SCAN)




SCAN 4 LOCATION



NON-DESTRUCTIVE EXAMINATION REPORT

GENERAL INFORMATION									
DATE:	July 09, 2021			REPORT #:	UT-CG09JUL2021B				
CLIENT/OWNER:	CNRL			AVALANCHE JOB #:	20-448		CLIENT JOB #:		
DISTRICT/REGION:	Fort St John			PROJECT:	SW/UT Insp		CLIENT PO #:		
AREA:	Ladyfern			LOCATION:	SURFACE:	b-17-I/94-H-1			
FACILITY:	Plant				UWI/DH:	b-17-I/94-H-1			
ITEMS EXAMINED:	Inlet Separator C73757								
METHOD(S) / SURFACE CONDITION									
INSPECTION METHOD(S):	<input type="checkbox"/> MT <input type="checkbox"/> PT <input checked="" type="checkbox"/> UT <input type="checkbox"/> HT <input type="checkbox"/> VT			ACCEPTANCE CRITERIA:	CLIENT EVALUATION				
PROCEDURE(S):	UT-01			UT-02	SPECIFICATION(S):	AS PER CLIENT SPEC.			
SURFACE CONDITION:	<input type="checkbox"/> Clean Base Metal <input type="checkbox"/> As Ground <input type="checkbox"/> Wire Wheel Cleaned <input type="checkbox"/> As Welded <input type="checkbox"/> Machined <input type="checkbox"/> Sand Blast								
<input checked="" type="checkbox"/> Other:	Painted			MATERIAL / THICKNESS:	CARBON STEEL				
MT/PT									
MINIMUM LIGHT INTENSITY: ≥ 100 fc Visible, ≥ 1000 μ W/cm ²									
LIGHTING TYPE:	<input type="checkbox"/> Ambient Lighting <input type="checkbox"/> Flashlight <input type="checkbox"/> 100W Flood Light <input type="checkbox"/> Halogen Light <input type="checkbox"/> Blacklight								
EQUIPMENT TYPE	SERIAL #	CALIBRATION DATE			MT CONSUMABLES			APPLICATION:	
BLACKLIGHT					MEDIUM:		CONTRAST:	<input type="checkbox"/> SPRAY	
LIGHT METER					<input type="checkbox"/> BWMPI	<input type="checkbox"/> WFMPI	<input type="checkbox"/> DRY / COLOR:	<input type="checkbox"/> PUFFER	
YOKE					<input type="checkbox"/> AC	<input type="checkbox"/> CONTINUOUS	<input type="checkbox"/> 120V	LEG SPACING: 3" - 8"	
PRODUCT	MANUFACTURER / TYPE	BATCH #			DWELL (MIN)	APPLICATION METHOD		METHOD TYPE	
PENETRANT:									
CLEANER:									
DEVELOPER:									
UT									
EQUIPMENT TYPE:	Epoch 650	SERIAL #:	160252309	CAL DATE:	04-Jan-21		CABLE LENGTH/TYPE:	3' / DUAL LEMO	
<input checked="" type="checkbox"/> 0°	<input checked="" type="checkbox"/> Shearwave	COUPLANT:	UT-X	CAL BLOCKS:	1" - 10 STEP - C/S				
REF REFLECTOR:	TYPE:	SIZE:		DEPTH:			SIG RESP (FSH):		
PROBE TYPE	ANGLE	WAVE	FREQ	SIZE	MFG	SERIAL #	RANGE	REF LVL	SCAN LEVEL (DB)
DUAL	0	LONG	5MHz	0.250"	STRESSTEL	21A00CL0	1.000"	54	60
SINGLE	45	SHEAR	2.25MHz	0.375"	OLYMPUS	1063722	10.000"	48	54
SINGLE	60	SHEAR	2.25MHz	0.375"	OLYMPUS	1063722	10.000"	46	52
HT									
EQUIPMENT TYPE	SERIAL #	CALIBRATION DATE			UNIT	MIN HARDNESS VALUE		MAX HARDNESS VALUE	
LEEB HL200									
TEST RESULTS									
SCOPE:									
A SWUT WAS CONDUCTED ON ALL ACCESSIBLE MANWAY TO SHELL WELDS OF THE INLET SEPARATOR C73757 AS REQUESTED BY THE CLIENT.									
RESULTS:									
NO RELEVANT INDICATIONS WERE LOCATED WITH SWUT. WELDS EXAMINED ARE ACCEPTABLE AS PER CODE.									
TECHNICIAN:	Curtis Graham				ASSISTANT:	Darrin Robak			
SIGNATURE:					CLIENT:				
CGSB/SNT CERTS:	6560 UT II / MT II / PT II				SIGNATURE:				

PHOTOS



NAMEPLATE



CNRL C#



VESSEL OVERVIEW



MANWAY OVERVIEW